

AN AMERICAN NATIONAL STANDARD

Hydrants for Utility and Maintenance Use

ANSI/ASME A112.21.3M - 1985

(REVISION OF ANSI A112.21.3 - 1976)

REAFFIRMED 1995

FOR CURRENT COMMITTEE PERSONNEL
PLEASE SEE ASME MANUAL AS-11

SPONSORED AND PUBLISHED BY

THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS

United Engineering Center 345 East 47th Street New York, N. Y. 10017

Date of Issuance: October 31, 1985

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda or written interpretations of the requirements of this Standard issued to this Edition.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment which provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations issued in accordance with governing ASME procedures and policies which preclude the issuance of interpretations by individual volunteers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

Copyright © 1985 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All Rights Reserved
Printed in U.S.A.

FOREWORD

(This Foreword is not part of ANSI/ASME A112.21.3-1985.)

In the broadest definition, a hydrant, as covered by this Standard, is a device with a water supply shut-off valve and with a means to connect a hose in a safe and sanitary manner. Hydrants covered herein serve as utility hose terminals for general building and grounds maintenance. This Standard does not cover fire hydrants (plugs).

As the building industry became more sophisticated, it was apparent that convenient water supply was necessary at various locations in the building walls and in the grounds surrounding the buildings. This requirement spurred the development of hydrants for both wall and ground installations.

Two general categories were established:

- (1) nonfreeze (frost proof) hydrants designed to be installed in areas which are subject to freezing temperatures;
- (2) hydrants for wall and ground installations in areas where freezing temperatures are not encountered.

Hydrants are equipped with removable operating keys or handles to discourage misuse and vandalism.

Many hydrants installed directly in the walls of buildings are equipped with attractive functional boxes to enclose the hydrant head, thereby concealing the nozzle so that it presents neither a displeasing appearance nor an obstruction on the wall. Ground or yard hydrants are similarly equipped to conceal and protect the nozzles. Post hydrants were developed to provide easy access to water supply where concealment is not a factor.

The American National Standards Committee A112 was organized July 27, 1955 for the standardization of plumbing materials and equipment. The first organizational meeting was held on July 22, 1958. At the meeting on May 1, 1964, Panel No. 21 was created to establish standards on roof drains, floor drains, backwater valves, and other drainage specialties. Its scope was as follows: the recommendation of suitable existing standards, in cooperation with interested sponsors, or the development of adequate new standards as are needed for roof drains, floor drains, and other drains as used or installed in plumbing systems. The Committee has since been reorganized as an ASME Standards Committee.

This Standard was revised and approved by Panel 21, the ASME A112 Standards Committee, and ASME. Subsequently this modified version was adopted by the American National Standards Institute on January 25, 1985.

AMERICAN NATIONAL STANDARDS COMMITTEE A112 Standardization of Plumbing Materials and Equipment

(The following is the roster of the Committee at the time of approval of this Standard.)

OFFICERS

J. C. Church, *Chairman*
C. E. Lynch, *Secretary*

COMMITTEE PERSONNEL

AIR CONDITIONING AND REFRIGERATION INSTITUTE

L. P. Benua, EBCO Manufacturing Co., Columbus, Ohio
R. J. Denny, *Alternate*, Air Conditioning and Refrigeration Institute, Arlington, Virginia

AMERICAN IRON AND STEEL INSTITUTE

G. T. Rochford, Jr., American Iron and Steel Institute, Washington, D.C.
B. J. Enright, *Alternate*, Raytown, Missouri

AMERICAN SOCIETY OF MECHANICAL ENGINEERS

R. V. Benazzi, Juros, Baum & Bolles, New York, New York

THE AMERICAN SOCIETY OF PLUMBING ENGINEERS

D. F. Dickerson, Donald F. Dickerson Associates, Van Nuys, California
W. W. Chan, *Alternate*, American Society of Plumbing Engineers, Sherman Oaks, California

AMERICAN SOCIETY OF SANITARY ENGINEERING

J. C. Church, Mamaroneck, New York
G. R. Jerus, *Alternate*, Meyer, Strong & Jones, P. C., New York, New York
L. M. Reading, *Alternate*, American Society of Sanitary Engineering, Detroit, Michigan

ASSOCIATION OF ASBESTOS CEMENT PIPE PRODUCERS

T. R. Gillen, Association of Asbestos Cement Pipe Producers, Arlington, Virginia

ASSOCIATION OF HOME APPLIANCE MANUFACTURERS

E. Gruenwald, Hobart Corp., Troy, Ohio
W. Blanck, *Alternate*, Association of Home Appliance Manufacturers, Chicago, Illinois

BUILDING OFFICIALS AND CODE ADMINISTRATORS INTERNATIONAL

D. P. Jack, Hampton, Virginia
J. A. Ballanco, *Alternate*, Building Officials and Code Administrators International, Homewood, Illinois

CAST IRON SOIL PIPE INSTITUTE

J. A. Woodward, Costa Mesa, California

CONFERENCE OF STATE SANITARY ENGINEERS

C. C. Crumley, Michigan Department of Public Health, Lansing, Michigan

COPPER DEVELOPMENT ASSOCIATION, INC.

A. Cohen, Copper Development Association, Inc., Greenwich, Connecticut

INTERNATIONAL ASSOCIATION OF PLUMBING AND MECHANICAL OFFICIALS

N. J. Latter, International Association of Plumbing and Mechanical Officials, Los Angeles, California

LEAD INDUSTRIES ASSOCIATION

E. D. Martin, Lead Industries Association, New York, New York

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS INDUSTRY

C. S. Anning, Elcen Metal Products, South Melrose Park, Illinois

NATIONAL ASSOCIATION OF HOME BUILDERS

C. D. Goines, National Association of Home Builders, Washington, D.C.

M. M. Mintz, *Alternate*, National Association of Home Builders, Washington, D.C.

NATIONAL ASSOCIATION OF PLUMBING-HEATING-COOLING CONTRACTORS

R. E. White, National Association of Plumbing-Heating-Cooling Contractors, South Bend, Indiana

NATIONAL CLAY PIPE INSTITUTE

R. M. Clementson, National Clay Pipe Institute, Washington, D.C.

NATIONAL ENVIRONMENTAL HEALTH ASSOCIATION

G. A. Prince, Denver, Colorado

PLUMBING AND DRAINAGE INSTITUTE

A. O. Roche, Jr., Plumbing and Drainage Institute, Indianapolis, Indiana

PLUMBING MANUFACTURERS INSTITUTE

C. Selover, Delta Faucet Co., Indianapolis, Indiana

R. W. Church, *Alternate*, Plumbing Manufacturers Institute, Glen Ellyn, Illinois

SOCIETY OF THE PLASTICS INDUSTRY

S. Mruk, New Providence, New Jersey

STATE OF NEW YORK HOUSING AND CODES BUREAU

A. Y. Kaplan, New York State Housing and Buildings Codes Bureau, New York, New York

U.S. DEPARTMENT OF COMMERCE – NATIONAL BUREAU OF STANDARDS

L. S. Galowin, National Bureau of Standards, Washington, D.C.

U.S. DEPARTMENT OF DEFENSE

M. E. Carr, U.S. Department of Defense, Washington, D.C.

U.S. DEPARTMENT OF THE NAVY

R. Cuendet, U.S. Naval Facilities Engineering Command, Alexandria, Virginia

INDIVIDUAL MEMBERS

R. S. Wyly, Kensington, Maryland

L. S. Neilson, Fresh Meadows, New York

P. J. Higgins, P. J. Higgins & Associates, Damascus, Maryland

**PERSONNEL OF PANEL NO. 21 – ROOF DRAINS, FLOOR DRAINS,
AND OTHER DRAINS**

A. O. Roche, Jr., Chairman, Plumbing and Drainage Institute, Indianapolis, Indiana

J. C. Church, Mamaroneck, New York

G. J. Flegel, Josam Manufacturing Company, Michigan City, Indiana

J. M. Soriano, Jay R. Smith Manufacturing Company, Montgomery, Alabama

MEMBERS OF TASK FORCE ON HYDRANTS FOR PANEL NO. 21

A. O. Roche, Jr., Chairman, Plumbing and Drainage Institute, Indianapolis, Indiana

G. J. Flegel, Josam Manufacturing Company, Michigan City, Indiana

M. W. Marshall, Tyler Pipe Industries, Tyler, Texas

J. M. Soriano, Jay R. Smith Manufacturing Company, Montgomery, Alabama

CONTENTS

Foreword	iii
Standards Committee Roster	v

1 Scope and Purpose	1
2 Definitions	1
3 Connections	2
4 Materials	2
5 Variations	8
6 Testing and Operation	9
7 General Requirements	9

Figures

1 Schematic Illustration of Basic Elements of a Hydrant (Details Vary With Type and Manufacturer)	3
2A Recommended Installation With Valve Behind Building Wall in Heated Area to Prevent Freezing (Exposed Head)	4
2B Recommended Installation With Valve Behind Building Wall in Heated Area to Prevent Freezing (Concealed Head)	4
2C Recommended Installation in Walls Where There Is No Danger of Freezing	4
2D Recommended Installation (Plan View) With Valve Behind Building Wall in Heated Area to Prevent Freezing	5
2E Recommended Installation in Walls Where There Is No Danger of Freezing	5
2F Recommended Installation With Valve Below Frost Line to Prevent Freezing (Box Type)	6
2G Recommended Installation With Valve Below Frost Line to Prevent Freezing (Post Type)	6
3A Thread or Solder Union Elbow	6
3B Straight Inlet Connection, Integral With Valve Housing	7
3C Combination Straight or Union Elbow	7
3D Ground Hydrant Inlet Connection	7
3E Thread or Solder Elbow	7
3F Straight and Angle Outlet Connection	8

Tables

1 Nominal Size of Outlet Connection	2
2 Discharge Capacity Test	9
3 Life Test	9

Appendix

I Metric (SI) Conversion Table	10
--	----

AN AMERICAN NATIONAL STANDARD

HYDRANTS FOR UTILITY AND MAINTENANCE USE

1 SCOPE AND PURPOSE

1.1 Scope

The scope of this Standard is the development of standards for hydrants including nonfreeze wall, ground, post, and floor types and moderate climate wall and floor types, which are used in buildings and grounds as water supply terminals, employed principally for lawn and flower bed watering hoses and normal building maintenance functions.

This Standard covers definitions, connections, materials, variations, testing and operation, and general requirements for the hydrant types included in the scope.

1.2 Purpose

The purpose of this Standard is to supply plumbing code authorities and others with full knowledge of the minimum design and quality criteria for hydrants necessary for sound performance and safe and sanitary installations. It is not intended as a specification guide.

NOTES:

- (1) Figures used in this Standard are intended only to describe and portray typical hydrants and are not intended to restrict design or be used for specification purposes.
- (2) All hydrant installations shall be in conformance with local codes, with protection against backflow and contamination provided. See para. 5.2 for information on vacuum breakers.

2 DEFINITIONS

2.1 Hydrants — General

The term *hydrant* as used in this Standard refers to a manufactured device that conveys water from supply pipe to a hose thread outlet, incorporating valve(s) with opening and closing means at the point of use, with all

working parts accessible for maintenance. Opening and closing means shall be a removable (loose set) operating key engaging a recessed operating stem. (See Fig. 1.)

2.2 Hydrant Types

nonfreeze wall hydrant, exposed outlet — a hydrant for installation in building walls with outlet exposed, in which the valve is operable at temperatures below 32°F (0°C). (See Fig. 2A.)

nonfreeze wall hydrant, concealed outlet — a hydrant for installation in building walls with the outlet concealed, in which the valve is operable at temperatures below 32°F (0°C). (See Fig. 2B.)

wall hydrant for moderate climate, concealed outlet — a hydrant for installation in building walls with the outlet concealed, in which the valve is not operable at valve body temperatures below 32°F (0°C). (See Fig. 2C.)

hot and cold nonfreeze wall hydrant, concealed outlet — a hydrant with hot and cold water inlet connections for installation in building walls with the outlet concealed, in which the valves are operable at temperatures below 32°F (0°C). (See Fig. 2D.)

hot and cold wall hydrant for moderate climate, concealed outlet — a hydrant with hot and cold water inlet connections for installation in building walls with the outlet concealed, in which the valves are not operable at valve body temperatures below 32°F (0°C). (See Fig. 2E.)

nonfreeze ground (yard) hydrant, concealed outlet — a hydrant for installation in the ground with the outlet concealed at grade and the inlet below the frost line, in which the valve is operable at temperatures below 32°F (0°C). (See Fig. 2F.)

nonfreeze ground (yard) post hydrant, exposed outlet — a hydrant for installation in the ground with the outlet extended above grade and the inlet below the frost line, in which the valve is operable at temperatures below 32°F (0°C). (See Fig. 2G.)