


**ASME B31.3-2008**  
(Revision of ASME B31.3-2006)

# Process Piping

**ASME Code for Pressure Piping, B31**

**AN AMERICAN NATIONAL STANDARD**



**ASME B31.3-2008**  
(Revision of ASME B31.3-2006)

# Process Piping

---

**ASME Code for Pressure Piping, B31**

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**



Copyright © 2008 by the American Society of Mechanical Engineers.  
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: December 31, 2008

The next edition of this Code is scheduled for publication in 2010. This Code will become effective 6 months after the Date of Issuance. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations, Code Cases, and errata are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Three Park Avenue, New York, NY 10016-5990

Copyright © 2008 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved  
Printed in U.S.A.



# CONTENTS

Foreword .....	xi
Committee Personnel .....	xiii
Introduction .....	xvii
Summary of Changes .....	xix
<b>Chapter I    Scope and Definitions</b> .....	<b>1</b>
300    General Statements .....	1
<b>Chapter II    Design</b> .....	<b>10</b>
<b>Part 1    Conditions and Criteria</b> .....	<b>10</b>
301    Design Conditions .....	10
302    Design Criteria .....	12
<b>Part 2    Pressure Design of Piping Components</b> .....	<b>18</b>
303    General .....	18
304    Pressure Design of Components .....	20
<b>Part 3    Fluid Service Requirements for Piping Components</b> .....	<b>30</b>
305    Pipe .....	30
306    Fittings, Bends, Miters, Laps, and Branch Connections .....	30
307    Valves and Specialty Components .....	32
308    Flanges, Blanks, Flange Facings, and Gaskets .....	32
309    Bolting .....	33
<b>Part 4    Fluid Service Requirements for Piping Joints</b> .....	<b>33</b>
310    General .....	33
311    Welded Joints .....	33
312    Flanged Joints .....	34
313    Expanded Joints .....	34
314    Threaded Joints .....	34
315    Tubing Joints .....	35
316    Caulked Joints .....	35
317    Soldered and Brazed Joints .....	35
318    Special Joints .....	35
<b>Part 5    Flexibility and Support</b> .....	<b>36</b>
319    Piping Flexibility .....	36
321    Piping Support .....	41
<b>Part 6    Systems</b> .....	<b>43</b>
322    Specific Piping Systems .....	43
<b>Chapter III    Materials</b> .....	<b>45</b>
323    General Requirements .....	45
325    Materials — Miscellaneous .....	54
<b>Chapter IV    Standards for Piping Components</b> .....	<b>55</b>
326    Dimensions and Ratings of Components .....	55
<b>Chapter V    Fabrication, Assembly, and Erection</b> .....	<b>58</b>
327    General .....	58
328    Welding .....	58
330    Preheating .....	64
331    Heat Treatment .....	65
332    Bending and Forming .....	69
333    Brazing and Soldering .....	70
335    Assembly and Erection .....	70



<b>Chapter VI</b>	<b>Inspection, Examination, and Testing</b> .....	72
340	Inspection .....	72
341	Examination .....	72
342	Examination Personnel .....	79
343	Examination Procedures .....	79
344	Types of Examination .....	79
345	Testing .....	80
346	Records .....	83
<b>Chapter VII</b>	<b>Nonmetallic Piping and Piping Lined With Nonmetals</b> .....	84
A300	General Statements .....	84
<b>Part 1</b>	<b>Conditions and Criteria</b> .....	84
A301	Design Conditions .....	84
A302	Design Criteria .....	84
<b>Part 2</b>	<b>Pressure Design of Piping Components</b> .....	86
A303	General .....	86
A304	Pressure Design of Piping Components .....	86
<b>Part 3</b>	<b>Fluid Service Requirements for Piping Components</b> .....	87
A305	Pipe .....	87
A306	Fittings, Bends, Miters, Laps, and Branch Connections .....	87
A307	Valves and Specialty Components .....	88
A308	Flanges, Blanks, Flange Facings, and Gaskets .....	88
A309	Bolting .....	88
<b>Part 4</b>	<b>Fluid Service Requirements for Piping Joints</b> .....	88
A310	General .....	88
A311	Bonded Joints in Plastics .....	88
A312	Flanged Joints .....	89
A313	Expanded Joints .....	89
A314	Threaded Joints .....	89
A315	Tubing Joints .....	89
A316	Caulked Joints .....	89
A318	Special Joints .....	89
<b>Part 5</b>	<b>Flexibility and Support</b> .....	90
A319	Flexibility of Nonmetallic Piping .....	90
A321	Piping Support .....	91
<b>Part 6</b>	<b>Systems</b> .....	91
A322	Specific Piping Systems .....	91
<b>Part 7</b>	<b>Materials</b> .....	92
A323	General Requirements .....	92
A325	Materials — Miscellaneous .....	93
<b>Part 8</b>	<b>Standards for Piping Components</b> .....	93
A326	Dimensions and Ratings of Components .....	93
<b>Part 9</b>	<b>Fabrication, Assembly, and Erection</b> .....	94
A327	General .....	94
A328	Bonding of Plastics .....	94
A329	Fabrication of Piping Lined With Nonmetals .....	100
A332	Bending and Forming .....	100
A334	Joining Nonplastic Piping .....	100
A335	Assembly and Erection .....	100
<b>Part 10</b>	<b>Inspection, Examination, and Testing</b> .....	101
A340	Inspection .....	101
A341	Examination .....	101
A342	Examination Personnel .....	102
A343	Examination Procedures .....	102



A344	Types of Examination .....	102
A345	Testing .....	103
A346	Records .....	103
<b>Chapter VIII</b>	<b>Piping for Category M Fluid Service .....</b>	<b>104</b>
M300	General Statements .....	104
<b>Part 1</b>	<b>Conditions and Criteria .....</b>	<b>104</b>
M301	Design Conditions .....	104
M302	Design Criteria .....	104
<b>Part 2</b>	<b>Pressure Design of Metallic Piping Components .....</b>	<b>105</b>
M303	General .....	105
M304	Pressure Design of Metallic Components .....	105
<b>Part 3</b>	<b>Fluid Service Requirements for Metallic Piping Components .....</b>	<b>105</b>
M305	Pipe .....	105
M306	Metallic Fittings, Bends, Miters, Laps, and Branch Connections .....	105
M307	Metallic Valves and Specialty Components .....	105
M308	Flanges, Blanks, Flange Facings, and Gaskets .....	106
M309	Bolting .....	106
<b>Part 4</b>	<b>Fluid Service Requirements for Metallic Piping Joints .....</b>	<b>106</b>
M310	Metallic Piping, General .....	106
M311	Welded Joints in Metallic Piping .....	106
M312	Flanged Joints in Metallic Piping .....	106
M313	Expanded Joints in Metallic Piping .....	106
M314	Threaded Joints in Metallic Piping .....	106
M315	Tubing Joints in Metallic Piping .....	106
M316	Caulked Joints .....	106
M317	Soldered and Brazed Joints .....	106
M318	Special Joints in Metallic Piping .....	106
<b>Part 5</b>	<b>Flexibility and Support of Metallic Piping .....</b>	<b>107</b>
M319	Flexibility of Metallic Piping .....	107
M321	Piping Support .....	107
<b>Part 6</b>	<b>Systems .....</b>	<b>107</b>
M322	Specific Piping Systems .....	107
<b>Part 7</b>	<b>Metallic Materials .....</b>	<b>107</b>
M323	General Requirements .....	107
M325	Materials — Miscellaneous .....	107
<b>Part 8</b>	<b>Standards for Piping Components .....</b>	<b>107</b>
M326	Dimensions and Ratings of Components .....	107
<b>Part 9</b>	<b>Fabrication, Assembly, and Erection of Metallic Piping .....</b>	<b>108</b>
M327	General .....	108
M328	Welding of Metals .....	108
M330	Preheating of Metals .....	108
M331	Heat Treatment of Metals .....	108
M332	Bending and Forming of Metals .....	108
M335	Assembly and Erection of Metallic Piping .....	108
<b>Part 10</b>	<b>Inspection, Examination, Testing, and Records of Metallic Piping .....</b>	<b>108</b>
M340	Inspection .....	108
M341	Examination .....	108
M342	Examination Personnel .....	109
M343	Examination Procedures .....	109
M344	Types of Examination .....	109
M345	Testing .....	109
M346	Records .....	109



<b>Parts 11 Through 20, Corresponding to Chapter VII</b> .....	109
MA300      General Statements .....	109
<b>Part 11      Conditions and Criteria</b> .....	109
MA301      Design Conditions .....	109
MA302      Design Criteria .....	109
<b>Part 12      Pressure Design of Nonmetallic Piping Components</b> .....	109
MA303      General .....	109
MA304      Pressure Design of Nonmetallic Components .....	109
<b>Part 13      Fluid Service Requirements for Nonmetallic Piping Components</b> .....	109
MA305      Pipe .....	109
MA306      Nonmetallic Fittings, Bends, Miters, Laps, and Branch Connections .....	109
MA307      Valves and Specialty Components .....	109
MA308      Flanges, Blanks, Flange Facings, and Gaskets .....	110
MA309      Bolting .....	110
<b>Part 14      Fluid Service Requirements for Nonmetallic Piping Joints</b> .....	110
MA310      General .....	110
MA311      Bonded Joints .....	110
MA312      Flanged Joints .....	110
MA313      Expanded Joints .....	110
MA314      Threaded Joints .....	110
MA315      Tubing Joints in Nonmetallic Piping .....	110
MA316      Caulked Joints .....	110
MA318      Special Joints .....	110
<b>Part 15      Flexibility and Support of Nonmetallic Piping</b> .....	110
MA319      Piping Flexibility .....	110
MA321      Piping Support .....	110
<b>Part 16      Nonmetallic and Nonmetallic Lined Systems</b> .....	110
MA322      Specific Piping Systems .....	110
<b>Part 17      Nonmetallic Materials</b> .....	110
MA323      General Requirements .....	110
<b>Part 18      Standards for Nonmetallic and Nonmetallic Lined Piping Components</b> .....	110
MA326      Dimensions and Ratings of Components .....	110
<b>Part 19      Fabrication, Assembly, and Erection of Nonmetallic and Nonmetallic Lined Piping</b> .....	110
MA327      General .....	110
MA328      Bonding of Plastics .....	111
MA329      Fabrication of Piping Lined With Nonmetals .....	111
MA332      Bending and Forming .....	111
MA334      Joining Nonplastic Piping .....	111
MA335      Assembly and Erection .....	111
<b>Part 20      Inspection, Examination, Testing, and Records of Nonmetallic and Nonmetallic Lined Piping</b> .....	111
MA340      Inspection .....	111
MA341      Examination .....	111
MA342      Examination Personnel .....	111
MA343      Examination Procedures .....	111
MA344      Types of Examination .....	111
MA345      Testing .....	111
MA346      Records .....	111
<b>Chapter IX   High Pressure Piping</b> .....	112
K300      General Statements .....	112
<b>Part 1      Conditions and Criteria</b> .....	112
K301      Design Conditions .....	112
K302      Design Criteria .....	113



<b>Part 2</b>	<b>Pressure Design of Piping Components</b>	115
K303	General	115
K304	Pressure Design of High Pressure Components	115
<b>Part 3</b>	<b>Fluid Service Requirements for Piping Components</b>	119
K305	Pipe	119
K306	Fittings, Bends, and Branch Connections	119
K307	Valves and Specialty Components	119
K308	Flanges, Blanks, Flange Facings, and Gaskets	119
K309	Bolting	120
<b>Part 4</b>	<b>Fluid Service Requirements for Piping Joints</b>	120
K310	General	120
K311	Welded Joints	120
K312	Flanged Joints	120
K313	Expanded Joints	120
K314	Threaded Joints	120
K315	Tubing Joints	121
K316	Caulked Joints	121
K317	Soldered and Brazed Joints	121
K318	Special Joints	121
<b>Part 5</b>	<b>Flexibility and Support</b>	121
K319	Flexibility	121
K321	Piping Support	121
<b>Part 6</b>	<b>Systems</b>	121
K322	Specific Piping Systems	121
<b>Part 7</b>	<b>Materials</b>	122
K323	General Requirements	122
K325	Miscellaneous Materials	126
<b>Part 8</b>	<b>Standards for Piping Components</b>	126
K326	Dimensions and Ratings of Components	126
<b>Part 9</b>	<b>Fabrication, Assembly, and Erection</b>	127
K327	General	127
K328	Welding	127
K330	Preheating	129
K331	Heat Treatment	130
K332	Bending and Forming	130
K333	Brazing and Soldering	131
K335	Assembly and Erection	131
<b>Part 10</b>	<b>Inspection, Examination, and Testing</b>	131
K340	Inspection	131
K341	Examination	131
K342	Examination Personnel	133
K343	Examination Procedures	133
K344	Types of Examination	133
K345	Leak Testing	134
K346	Records	135
<b>Figures</b>		
300.1.1	Diagram Illustrating Application of B31.3 Piping at Equipment	3
302.3.5	Stress Range Factor, $f$	17
304.2.1	Nomenclature for Pipe Bends	21
304.2.3	Nomenclature for Miter Bends	21
304.3.3	Branch Connection Nomenclature	23
304.3.4	Extruded Outlet Header Nomenclature	25
304.5.3	Blanks	29
319.4.4A	Moments in Bends	39
319.4.4B	Moments in Branch Connections	39



323.2.2A	Minimum Temperatures Without Impact Testing for Carbon Steel Materials .....	48
323.2.2B	Reduction in Minimum Design Metal Temperature Without Impact Testing .....	50
328.3.2	Typical Backing Rings and Consumable Inserts .....	60
328.4.2	Typical Butt Weld End Preparation .....	60
328.4.3	Trimming and Permitted Misalignment .....	60
328.4.4	Preparation for Branch Connections .....	61
328.5.2A	Fillet Weld Size .....	62
328.5.2B	Typical Details for Double-Welded Slip-On and Socket Welding Flange Attachment Welds .....	62
328.5.2C	Minimum Welding Dimensions for Socket Welding Components Other Than Flanges .....	63
328.5.4A	Typical Welded Branch Connections .....	63
328.5.4B	Typical Welded Branch Connections .....	63
328.5.4C	Typical Welded Branch Connections .....	63
328.5.4D	Acceptable Details for Branch Attachment Welds .....	63
328.5.4E	Acceptable Details for Branch Attachment Suitable for 100% Radiography .....	64
328.5.5	Typical Fabricated Laps .....	64
335.3.3	Typical Threaded Joints Using Straight Threads .....	71
341.3.2	Typical Weld Imperfections .....	76
A328.5	Typical Plastic Piping Joints .....	99
K323.3.3	Example of an Acceptable Impact Test Specimen .....	125
K328.4.3	Pipe Bored for Alignment: Trimming and Permitted Misalignment .....	128
K328.5.4	Some Acceptable Welded Branch Connections Suitable for 100% Radiography .....	129
<b>Tables</b>		
300.4	Status of Appendices in B31.3 .....	9
302.3.3C	Increased Casting Quality Factors, $E_c$ .....	15
302.3.3D	Acceptance Levels for Castings .....	15
302.3.4	Longitudinal Weld Joint Quality Factor, $E_j$ .....	16
302.3.5	Weld Joint Strength Reduction Factor, $W$ .....	19
304.1.1	Values of Coefficient $Y$ for $t < D/6$ .....	20
304.4.1	BPV Code References for Closures .....	27
308.2.1	Permissible Sizes/Rating Classes for Slip-On Flanges Used as Lapped Flanges .....	32
314.2.1	Minimum Thickness of Male Threaded Components .....	35
323.2.2	Requirements for Low Temperature Toughness Tests for Metals .....	46
323.2.2A	Tabular Values for Minimum Temperatures Without Impact Testing for Carbon Steel Materials .....	49
323.3.1	Impact Testing Requirements for Metals .....	51
323.3.4	Charpy Impact Test Temperature Reduction .....	52
323.3.5	Minimum Required Charpy V-Notch Impact Values .....	53
326.1	Component Standards .....	56
330.1.1	Preheat Temperatures .....	66
331.1.1	Requirements for Heat Treatment .....	67
341.3.2	Acceptance Criteria for Welds and Examination Methods for Evaluating Weld Imperfections .....	73
A323.2.2	Requirements for Low Temperature Toughness Tests for Nonmetals .....	93
A323.4.2C	Recommended Temperature Limits for Reinforced Thermosetting Resin Pipe .....	93
A323.4.3	Recommended Temperature Limits for Thermoplastics Used as Linings .....	94
A326.1	Component Standards .....	95
A341.3.2	Acceptance Criteria for Bonds .....	102



K302.3.3D	Acceptable Severity Levels for Steel Castings .....	115
K305.1.2	Required Ultrasonic or Eddy Current Examination of Pipe and Tubing for Longitudinal Defects .....	119
K323.3.1	Impact Testing Requirements .....	124
K323.3.5	Minimum Required Charpy V-Notch Impact Values .....	126
K326.1	Component Standards .....	127
K341.3.2	Acceptance Criteria for Welds .....	132
<b>Appendices</b>		
A	Allowable Stresses and Quality Factors for Metallic Piping and Bolting	
	Materials .....	137
	Specification Index for Appendix A .....	138
	Notes for Appendix A Tables .....	141
	<b>Table A-1 Basic Allowable Stresses in Tension for Metals</b> .....	145
	Iron	
	Castings .....	145
	Carbon Steel	
	Pipes and Tubes .....	146
	Pipes (Structural Grade) .....	150
	Plates, Bars, Shapes, and Sheets .....	150
	Plates, Bars, Shapes, and Sheets (Structural) .....	152
	Forgings and Fittings .....	152
	Castings .....	152
	Low and Intermediate Alloy Steel	
	Pipes .....	154
	Plates .....	156
	Forgings and Fittings .....	158
	Castings .....	160
	Stainless Steel	
	Pipes and Tubes .....	162
	Plates and Sheets .....	166
	Forgings and Fittings .....	168
	Bar .....	172
	Castings .....	172
	Copper and Copper Alloy	
	Pipes and Tubes .....	174
	Plates and Sheets .....	174
	Forgings .....	176
	Castings .....	176
	Nickel and Nickel Alloy	
	Pipes and Tubes .....	178
	Plates and Sheets .....	180
	Forgings and Fittings .....	182
	Rod and Bar .....	184
	Castings .....	184
	Titanium and Titanium Alloy	
	Pipes and Tubes .....	186
	Plates and Sheets .....	186
	Forgings .....	186
	Zirconium and Zirconium Alloy	
	Pipes and Tubes .....	186
	Plates and Sheets .....	186
	Forgings and Bar .....	186
	Aluminum Alloy	
	Seamless Pipes and Tubes .....	188
	Welded Pipes and Tubes .....	189
	Structural Tubes .....	189



	Plates and Sheets .....	190
	Forgings and Fittings .....	192
	Castings .....	193
	<b>Table A-1A Basic Casting Quality Factors, <math>E_c</math></b> .....	194
	<b>Table A-1B Basic Quality Factors for Longitudinal Weld Joints in Pipes, Tubes, and Fittings, <math>E_j</math></b> .....	195
	Carbon Steel .....	195
	Low and Intermediate Alloy Steel .....	195
	Stainless Steel .....	196
	Copper and Copper Alloy .....	196
	Nickel and Nickel Alloy .....	197
	Titanium and Titanium Alloy .....	197
	Zirconium and Zirconium Alloy .....	197
	Aluminum Alloy .....	197
	<b>Table A-2 Design Stress Values for Bolting Materials</b> .....	198
	Carbon Steel .....	198
	Alloy Steel .....	198
	Stainless Steel .....	198
	Copper and Copper Alloy .....	204
	Nickel and Nickel Alloy .....	204
	Aluminum Alloy .....	206
B	Stress Tables and Allowable Pressure Tables for Nonmetals .....	208
C	Physical Properties of Piping Materials .....	213
D	Flexibility and Stress Intensification Factors .....	228
E	Reference Standards .....	232
F	Precautionary Considerations .....	238
G	Safeguarding .....	242
H	Sample Calculations for Branch Reinforcement .....	243
J	Nomenclature .....	247
K	Allowable Stresses for High Pressure Piping .....	260
L	Aluminum Alloy Pipe Flanges .....	274
M	Guide to Classifying Fluid Services .....	277
P	Alternative Rules for Evaluating Stress Range .....	279
Q	Quality System Program .....	281
S	Piping System Stress Analysis Examples .....	282
V	Allowable Variations in Elevated Temperature Service .....	295
X	Metallic Bellows Expansion Joints .....	298
Z	Preparation of Technical Inquiries .....	303
<b>Index</b>	.....	304



# FOREWORD

(08)

Responding to evident need and at the request of The American Society of Mechanical Engineers, the American Standards Association initiated Project B31 in March 1926, with ASME as sole administrative sponsor. The breadth of the field involved required that membership of the Sectional Committee be drawn from some 40 engineering societies, industries, government bureaus, institutes, and trade associations.

Initial publication in 1935 was as the American Tentative Standard Code for Pressure Piping. Revisions from 1942 through 1955 were published as American Standard Code for Pressure Piping, ASA B31.1. It was then decided to publish as separate documents the various industry Sections, beginning with ASA B31.8-1955, Gas Transmission and Distribution Piping Systems. The first Petroleum Refinery Piping Code Section was designated ASA B31.3-1959. ASA B31.3 revisions were published in 1962 and 1966.

In 1967–1969, the American Standards Association became first the United States of America Standards Institute, then the American National Standards Institute. The Sectional Committee became American National Standards Committee B31 and the Code was renamed the American National Standard Code for Pressure Piping. The next B31.3 revision was designated ANSI B31.3-1973. Addenda were published through 1975.

A draft Code Section for Chemical Plant Piping, prepared by Section Committee B31.6, was ready for approval in 1974. It was decided, rather than have two closely related Code Sections, to merge the Section Committees and develop a joint Code Section, titled Chemical Plant and Petroleum Refinery Piping. The first edition was published as ANSI B31.3-1976.

In this Code, responsibility for piping design was conceptually integrated with that for the overall processing facility, with safeguarding recognized as an effective safety measure. Three categories of Fluid Service were identified, with a separate Chapter for Category M Fluid Service. Coverage for nonmetallic piping was introduced. New concepts were better defined in five Addenda, the last of which added Appendix M, a graphic aid to selection of the proper Fluid Service category.

The Standards Committee was reorganized in 1978 as a Committee operating under ASME procedures with ANSI accreditation. It is now the ASME Code for Pressure Piping, B31 Committee. Section committee structure remains essentially unchanged.

The second edition of Chemical Plant and Petroleum Refinery Piping was compiled from the 1976 Edition and its five Addenda, with nonmetal requirements editorially relocated to a separate Chapter. Its new designation was ANSI/ASME B31.3-1980.

Section Committee B31.10 had a draft Code for Cryogenic Piping ready for approval in 1981. Again, it was decided to merge the two Section Committees and develop a more inclusive Code with the same title. The work of consolidation was partially completed in the ANSI/ASME B31.3-1984 Edition.

Significant changes were made in Addenda to the 1984 Edition: integration of cryogenic requirements was completed; a new stand-alone Chapter on high-pressure piping was added; and coverage of fabrication, inspection, testing, and allowable stresses was reorganized. The new Edition was redesignated as ASME/ANSI B31.3-1987 Edition.

Addenda to subsequent Editions, published at three-year intervals, have been primarily to keep the Code up-to-date. New Appendices have been added, however, on requirements for bellows expansion joints, estimating service life, submittal of Inquiries, aluminum flanges, and quality control in the 1990, 1993, 1999, and 2002 Editions, all designated as ASME B31.3.

In a program to clarify the application of all Sections of the Code for Pressure Piping, changes are being made in the Introduction and Scope statements of B31.3, and its title is changed to Process Piping.

Under direction of ASME Codes and Standards management, metric units of measurement are being emphasized. With certain exceptions, SI metric units were listed first in the 1996 Edition and were designated as the standard. Instructions for conversion are given where metric data



are not available. U.S. customary units also are given. By agreement, either system may be used.

In this Edition of the Code, SI metric units are given first, with U.S. customary units in parentheses. Appendices H and X, the tables in Appendices A and K, and Tables C-1, C-3, and C-6 in Appendix C are exceptions. Values in metric units are to be regarded as the standard, unless otherwise agreed between the contracting parties. Instructions are given, in those tables that have not been converted for converting tabular data in U.S. units to appropriate SI units.

Interpretations, Code Cases, and errata to the B31.3 Code on Process Piping are published on the following ASME web page: <http://cstools.asme.org/csconnect/CommitteePages.cfm?Committee=N10020400>.



# ASME B31 COMMITTEE

## Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

### COMMITTEE OFFICERS

**M. L. Nayyar**, *Chair*  
**K. C. Bodenhamer**, *Vice Chair*  
**N. Lobo**, *Secretary*

### COMMITTEE PERSONNEL

<b>R. J. T. Appleby</b> , ExxonMobil Upstream Research Co.	<b>J. E. Meyer</b> , Louis Perry & Associates, Inc.
<b>C. Becht IV</b> , Becht Engineering Co.	<b>E. Michalopoulos</b> , Management Authority of West Macedonia
<b>A. E. Beyer</b> , Fluor Enterprises, Inc.	<b>M. L. Nayyar</b> , Bechtel Power Corp.
<b>K. C. Bodenhamer</b> , Enterprise Products Co., Inc.	<b>R. G. Payne</b> , Alstom Power, Inc.
<b>J. S. Chin</b> , TransCanada Pipeline U.S.	<b>J. T. Powers</b> , Worley Parsons
<b>D. L. Coym</b> , Worley Parsons	<b>E. H. Rinaca</b> , Dominion Resources, Inc.
<b>J. A. Drake</b> , Spectra Energy Transmission	<b>M. J. Rosenfeld</b> , Kiefner & Associates, Inc.
<b>P. D. Flenner</b> , Flenner Engineering Services	<b>R. J. Silvia</b> , Process Engineers and Constructors, Inc.
<b>D. M. Fox</b> , Atmos Energy	<b>W. J. Sperko</b> , Sperko Engineering Services, Inc.
<b>J. W. Frey</b> , Stress Engineering Service, Inc.	<b>G. W. Spohn III</b> , Coleman Spohn Corp.
<b>D. R. Frikken</b> , Becht Engineering Co.	<b>F. W. Tatar</b> , FM Global
<b>R. A. Grichuk</b> , Fluor Corp.	<b>K. A. Vilminot</b> , Black & Veatch
<b>R. W. Haupt</b> , Pressure Piping Engineering Associates, Inc.	<b>A. L. Watkins</b> , The Perry Nuclear Power Plant
<b>L. E. Hayden, Jr.</b> , Engineering Consultant	<b>K. H. Wooten</b> , ConocoPhillips Pipe Line Co.
<b>G. A. Jolly</b> , Vogt Valves/Flowserve Corp.	<b>A. Soni</b> , <i>Delegate</i> , Engineers India Ltd.
<b>N. Lobo</b> , The American Society of Mechanical Engineers	<b>W. J. Koves</b> , <i>Ex-Officio Member</i> , UOP LLC
<b>W. J. Mauro</b> , American Electric Power	<b>A. P. Rangus</b> , <i>Ex-Officio Member</i> , Bechtel
	<b>C. J. Melo</b> , <i>Alternate</i> , Worley Parsons

### B31.3 PROCESS PIPING SECTION COMMITTEE

<b>C. Becht IV</b> , <i>Chair</i> , Becht Engineering Co.	<b>D. B. Kadakia</b> , TD Williamson, Inc.
<b>J. E. Meyer</b> , <i>Vice Chair</i> , Louis Perry & Associates, Inc.	<b>W. J. Koves</b> , UOP LLC
<b>J. D. Wendler</b> , <i>Secretary</i> , The American Society of Mechanical Engineers	<b>J. C. Luf</b> , URS Washington Division
<b>B. L. Agee</b> , GE Gas Turbines	<b>W. N. McLean</b> , Newco Valves
<b>R. M. Bojarczuk</b> , ExxonMobil Research & Engineering Co.	<b>R. A. McLeod</b> , Shaw Group
<b>D. D. Christian</b> , Victaulic	<b>R. J. Medvick</b> , Swagelok
<b>D. L. Coym</b> , Worley Parsons	<b>V. B. Molina III</b> , Air Products & Chemicals, Inc.
<b>J. A. D'Avanzo</b> , DuPont Engineering	<b>C. A. Moore</b> , Smith Fibercast
<b>C. E. Davila</b> , Crane Valves	<b>J. R. Offutt</b> , Chevron
<b>D. W. Diehl</b> , COADE, Inc.	<b>J. M. Prawdzik</b> , BP
<b>D. R. Edwards</b> , ConocoPhillips	<b>D. W. Raho</b> , Metallurgist
<b>J. P. Ellenberger</b> , WFI Division, Bonney Forge	<b>A. P. Rangus</b> , Bechtel
<b>R. W. Engle</b> , The Dow Chemical Co.	<b>G. C. Reinhardt II</b> , Team Industries, Inc.
<b>W. H. Eskridge, Jr.</b> , Aker Kvaerner Engineering & Construction	<b>K. S. Shipley</b> , The Equity Engineering Group, Inc.
<b>D. J. Fetzner</b> , BP Exploration Alaska, Inc.	<b>R. J. Silvia</b> , Process Engineers & Constructors, Inc.
<b>D. R. Fraser</b> , NASA Ames Research Center	<b>J. L. Smith</b> , Jacobs Engineering Group
<b>D. R. Frikken</b> , Becht Engineering Co.	<b>F. W. Tatar</b> , FM Global
<b>D. C. Glover</b> , KBR, Inc.	<b>Q. N. Truong</b> , Refinery Technology, Inc.
<b>O. R. Greulich</b> , NASA	<b>G. E. Woods</b> , Technip USA
<b>R. A. Grichuk</b> , Fluor Corp.	<b>C. G. Ziu</b> , Orion Fittings, Inc.
<b>B. S. Harris</b> , Consultant	<b>C. J. Melo</b> , <i>Alternate</i> , Worley Parsons
<b>R. W. Haupt</b> , Pressure Piping Engineering Associates, Inc.	<b>J. T. Wier</b> , <i>Honorary Member</i>
<b>J. F. Hodgins</b> , Car-Ber Testing Services	<b>D. Saile</b> , <i>Contributing Member</i> , Shell Global Solutions International
<b>T. W. Johnson</b> , Lummus Technology	<b>R. W. Temple</b> , <i>Contributing Member</i> , R. W. Temple Associates
	<b>F. Zezula</b> , <i>Contributing Member</i> , BP Exploration Co.



### B31.3 INTERNATIONAL REVIEW GROUP

**R. W. Engle**, *Chair*, The Dow Chemical Co.  
**D. W. Bikker**, DuPont de Nemours  
**G. Evans**, BP Exploration  
**H.-W. Lange**, Lisega A.G.  
**M. S. Mokhtar**, SBM Offshore, Inc.

**T. J. Naughton**, Jacob's Engineering  
**G. Suresh**, Dow Chemical International  
**L. Sylvain**, Total France  
**H. Van Leengoed**, Jacobs Nederland  
**S. Wei-Yeow**, Aker Kvaerner Engineering South East Asia

### B31.3 SUBGROUP ON DESIGN

**D. W. Diehl**, *Chair*, COADE, Inc.  
**R. M. Bojarczuk**, ExxonMobil Research & Engineering Co.  
**J. P. Breen**, Becht Engineering Co.  
**R. K. Broyles**, Senior Flexonics Pathway  
**D. R. Edwards**, ConocoPhillips  
**J. P. Ellenberger**, WFI Division, Bonney Forge  
**R. W. Haupt**, Pressure Piping Engineering Associates, Inc.

**W. J. Koves**, UOP LLC  
**J. C. Luf**, URS Washington Division  
**C. Nath**, DuPont Engineering  
**C. D. Pham**, SBM Offshore, Inc.  
**K. S. Shipley**, The Equity Engineering Group, Inc.  
**G. E. Woods**, Technip USA

### B31.3 SUBGROUP ON EDIT

**R. W. Engle**, *Chair*, The Dow Chemical Co.  
**C. Becht IV**, Becht Engineering Co.

**D. R. Frikken**, Becht Engineering Co.  
**J. E. Meyer**, Louis Perry & Associates, Inc.

### B31.3 SUBGROUP ON FABRICATION, EXAMINATION, AND TESTING

**R. J. Silvia**, *Chair*, Process Engineers and Constructors, Inc.  
**R. D. Campbell**, Bechtel National, Inc.  
**W. H. Eskridge, Jr.**, Aker Kvaerner Engineering & Construction  
**D. J. Fetzner**, BP Exploration Alaska, Inc.  
**J. F. Hodgins**, Car-Ber Testing Services  
**R. A. McLeod**, Shaw Group  
**A. D. Nalbandian**, Thielsch Engineering, Inc.

**J. R. Offutt**, Chevron  
**G. C. Reinhardt II**, Team Industries, Inc.  
**R. A. Sierra**, Fluor  
**W. J. Sperko**, Sperko Engineering Services, Inc.  
**L. S. Varone**, Shaw, Stone & Webster  
**C. T. Widder**, Jacobs Technology

### B31.3 SUBGROUP ON GENERAL REQUIREMENTS

**J. A. D'Avanzo**, *Chair*, DuPont Engineering  
**D. D. Christian**, Victaulic  
**D. L. Coym**, Worley Parsons  
**C. E. Davila**, Crane Valves  
**D. B. Kadakia**, T. D. Williamson, Inc.

**W. N. McLean**, Newco Valves  
**R. A. McLeod**, Shaw Group  
**C. J. Melo**, Worley Parsons  
**C. Y. Shyu**, ExxonMobil Development Co.

### B31.3 SUBGROUP ON HIGH PRESSURE PIPING

**F. W. Tatar**, *Chair*, FM Global  
**D. R. Fraser**, NASA Ames Research Center  
**O. R. Greulich**, NASA  
**T. W. Johnson**, Lummus Technology

**R. J. Medvick**, Swagelok  
**A. P. Rangus**, Bechtel  
**Q. N. Truong**, Refinery Technology, Inc.



### B31.3 SUBGROUP ON MATERIALS

**R. A. Grichuk**, *Chair*, Fluor Corp.  
**B. L. Agee**, GE Gas Turbines  
**M. Katcher**, Haynes International  
**J. M. Prawdzik**, BP

**D. W. Raho**i, Metallurgist  
**J. L. Smith**, Jacobs Engineering Group  
**X. Tang**, Swagelok

### B31.3 SUBGROUP ON NON-METALLIC PIPING

**C. A. Moore**, *Chair*, Smith Fibercast  
**G. Burnett**, Ipex, Inc.  
**M. A. Clark**, Nibco, Inc.  
**R. B. Davis**, Ershigs, Inc.  
**B. S. Harris**, Consultant

**D. A. McGriff**, ISCO Industries, LLC  
**T. R. McPherson**, IPS Corp.  
**G. J. Peak**, Spears Manufacturing Co.  
**C. G. Ziu**, Orion Fittings, Inc.

### B31.3 SUBGROUP ON ULTRA-HIGH PURITY SYSTEMS

**V. B. Molina III**, *Chair*, Air Products & Chemicals, Inc.  
**G. A. Babuder**, Swagelok

**E. P. Coghlan**, ON Semiconductor  
**P. J. Guerrieri, Sr.**, Integrated Mechanical Services, Inc.

### B31 FABRICATION AND EXAMINATION COMMITTEE

**A. P. Rangus**, *Chair*, Bechtel  
**R. J. Horvath, Jr.**, *Secretary*, The American Society of Mechanical Engineers  
**J. P. Ellenberger**, WFI Division, Bonney Forge  
**R. J. Ferguson**, Metallurgist  
**D. J. Fetzner**, BP Exploration Alaska, Inc.  
**P. D. Flenner**, Flenner Engineering Services  
**W. W. Lewis**, E. I. DuPont

**S. P. Licud**, Bechtel National, Inc.  
**A. D. Nalbandian**, Thielsch Engineering, Inc.  
**R. I. Seals**, Consultant  
**R. J. Silvia**, Process Engineers & Constructors, Inc.  
**W. J. Sperko**, Sperko Engineering Services, Inc.  
**E. F. Summers, Jr.**, Babcock & Wilcox Construction Co.  
**P. L. Vaughan**, ONEOK Partners

### B31 MATERIALS TECHNICAL COMMITTEE

**R. A. Grichuk**, *Chair*, Fluor Corp.  
**N. Lobo**, *Secretary*, The American Society of Mechanical Engineers  
**M. H. Barnes**, Scantec, Inc.  
**J. A. Cox**, Lieberman Consulting LLC  
**R. P. Deubler**, Fronex Power Systems LLC  
**P. J. Dobson**, Cummins & Barnard, Inc.  
**W. H. Eskridge, Jr.**, Aker Kvaerner Engineering & Construction

**C. L. Henley**, Black & Veatch  
**D. W. Raho**i, Metallurgist  
**R. A. Schmidt**, Hackney Ladish, Inc.  
**H. R. Simpson**, Industry and Energy Associates, LLC  
**J. L. Smith**, Jacobs Engineering Group  
**Z. Djilali**, *Corresponding Member*, BEREP

### B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

**W. J. Koves**, *Chair*, UOP LLC  
**G. A. Antaki**, *Vice Chair*, Becht Engineering Co., Inc.  
**C. E. O'Brien**, *Secretary*, The American Society of Mechanical Engineers  
**C. Becht IV**, Becht Engineering Co.  
**J. P. Breen**, Engineering Advisor  
**J. P. Ellenberger**, WFI Division, Bonney Forge  
**D. J. Fetzner**, BP Exploration Alaska, Inc.  
**J. A. Graziano**, Tennessee Valley Authority  
**J. D. Hart**, SSD, Inc.  
**R. W. Haupt**, Pressure Piping Engineering Associates, Inc.

**B. P. Holbrook**, Babcock Power, Inc.  
**G. D. Mayers**, Alion Science & Technology  
**T. Q. McCawley**, TQM Engineering, PC  
**R. J. Medvick**, Swagelok  
**J. C. Minichiello**, AREVA NP  
**A. W. Paulin**, Paulin Resource Group  
**R. A. Robleto**, Senior Technical Advisor  
**M. J. Rosenfeld**, Kiefner & Associates, Inc.  
**G. Stevick**, Berkeley Engineering & Research, Inc.  
**E. A. Wais**, Wais and Associates, Inc.  
**E. C. Rodabaugh**, *Honorary Member*, Consultant



### B31 CONFERENCE GROUP

- A. Bell**, Bonneville Power Administration  
**G. Bynog**, The National Board of Boiler and Pressure Vessel Inspectors  
**R. A. Coomes**, Commonwealth of Kentucky, Department of Housing/Boiler Section  
**D. H. Hanrath**  
**C. J. Harvey**, Alabama Public Service Commission  
**D. T. Jagger**, Ohio Department of Commerce  
**M. Kotb**, Régie du Bâtiment du Québec  
**K. T. Lau**, Alberta Boilers Safety Association  
**R. G. Marini**, New Hampshire Public Utilities Commission  
**I. W. Mault**, Manitoba Department of Labour  
**A. W. Meiring**, Fire and Building Boiler and Pressure Vessel Division/Indiana
- R. F. Mullaney**, Boiler and Pressure Vessel Safety Branch/Vancouver  
**P. Sher**, State of Connecticut  
**M. E. Skarda**, Arkansas Department of Labor  
**D. A. Starr**, Nebraska Department of Labor  
**D. J. Stursma**, Iowa Utilities Board  
**R. P. Sullivan**, The National Board of Boiler and Pressure Vessel Inspectors  
**J. E. Troppman**, Division of Labor/State of Colorado Boiler Inspections  
**C. H. Walters**, National Board of Boiler and Pressure Vessel Inspectors  
**W. A. M. West**, Lighthouse Assistance, Inc.  
**T. F. Wickham**, Rhode Island Department of Labor



# INTRODUCTION

(08)

The ASME B31 Code for Pressure Piping consists of a number of individually published Sections, each an American National Standard, under the direction of ASME Committee B31, Code for Pressure Piping.

Rules for each Section reflect the kinds of piping installations considered during its development, as follows:

B31.1 Power Piping: piping typically found in electric power generating stations, in industrial and institutional plants, geothermal heating systems, and central and district heating and cooling systems

B31.3 Process Piping: piping typically found in petroleum refineries, chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants, and related processing plants and terminals

B31.4 Pipeline Transportation Systems for Liquid Hydrocarbons and Other Liquids: piping transporting products which are predominately liquid between plants and terminals and within terminals, pumping, regulating, and metering stations

B31.5 Refrigeration Piping: piping for refrigerants and secondary coolants

B31.8 Gas Transportation and Distribution Piping Systems: piping transporting products which are predominately gas between sources and terminals, including compressor, regulating, and metering stations; gas gathering pipelines

B31.9 Building Services Piping: piping typically found in industrial, institutional, commercial, and public buildings, and in multi-unit residences, which does not require the range of sizes, pressures, and temperatures covered in B31.1

B31.11 Slurry Transportation Piping Systems: piping transporting aqueous slurries between plants and terminals and within terminals, pumping, and regulating stations

This is the B31.3 Process Piping Code Section. Hereafter, in this Introduction and in the text of this Code Section B31.3, where the word *Code* is used without specific identification, it means this Code Section.

It is the owner's responsibility to select the Code Section which most nearly applies to a proposed piping installation. Factors to be considered by the owner include: limitations of the Code Section; jurisdictional requirements; and the applicability of other codes and standards. All applicable requirements of the selected Code Section shall be met. For some installations, more than one Code Section may apply to different parts of the installation. The owner is also responsible for imposing requirements supplementary to those of the Code if necessary to assure safe piping for the proposed installation.

Certain piping within a facility may be subject to other codes and standards, including but not limited to the following:

ANSI Z223.1 National Fuel Gas Code: piping for fuel gas from the point of delivery to the connection of each fuel utilization device

NFPA Fire Protection Standards: fire protection systems using water, carbon dioxide, halon, foam, dry chemicals, and wet chemicals

NFPA 99 Health Care Facilities: medical and laboratory gas systems

building and plumbing codes, as applicable, for potable hot and cold water, and for sewer and drain systems

The Code sets forth engineering requirements deemed necessary for safe design and construction of pressure piping. While safety is the basic consideration, this factor alone will not necessarily govern the final specifications for any piping installation. The designer is cautioned that the Code is not a design handbook; it does not do away with the need for the designer or for competent engineering judgment.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented, as necessary, with specific requirements to assure uniform application of principles and to guide selection and application of piping elements.



The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

This Code Section includes the following:

- (a) references to acceptable material specifications and component standards, including dimensional requirements and pressure–temperature ratings
- (b) requirements for design of components and assemblies, including piping supports
- (c) requirements and data for evaluation and limitation of stresses, reactions, and movements associated with pressure, temperature changes, and other forces
- (d) guidance and limitations on the selection and application of materials, components, and joining methods
- (e) requirements for the fabrication, assembly, and erection of piping
- (f) requirements for examination, inspection, and testing of piping

ASME Committee B31 is organized and operates under procedures of The American Society of Mechanical Engineers that have been accredited by the American National Standards Institute. The Committee is a continuing one, and keeps all Code Sections current with new developments in materials, construction, and industrial practice. New editions are published at intervals of two years.

Code users will note that clauses in the Code are not necessarily numbered consecutively. Such discontinuities result from following a common outline, insofar as practical, for all Code Sections. In this way, corresponding material is correspondingly numbered in most Code Sections, thus facilitating reference by those who have occasion to use more than one Section.

It is intended that this edition of Code Section B31.3 not be retroactive. Unless agreement is specifically made between contracting parties to use another issue, or the regulatory body having jurisdiction imposes the use of another issue, the latest edition issued at least 6 months prior to the original contract date for the first phase of activity covering a piping installation shall be the governing document for all design, materials, fabrication, erection, examination, and testing for the piping until the completion of the work and initial operation.

Users of this Code are cautioned against making use of Code revisions without assurance that they are acceptable to the proper authorities in the jurisdiction where the piping is to be installed.

The B31 Committee has established an orderly procedure to consider requests for interpretation and revision of Code requirements. To receive consideration, such request must be in writing and must give full particulars in accordance with Appendix Z.

The approved reply to an inquiry will be sent directly to the inquirer. In addition, the question and reply will be published as part of an Interpretation supplement.

A Case is the prescribed form of reply when study indicates that the Code wording needs clarification, or when the reply modifies existing requirements of the Code or grants permission to use new materials or alternative constructions. The Case will be published as part of a Case supplement.

The ASME B31 Standards Committee took action to eliminate Code Case expiration dates effective September 21, 2007. This means that all Code Cases in effect as of this date will remain available for use until annulled by the ASME B31 Standards Committee.

A request for revision of the Code will be placed on the Committee's agenda. Further information or active participation on the part of the proponent may be requested during consideration of a proposed revision.

Materials ordinarily are listed in the stress tables only when sufficient usage in piping within the scope of the Code has been shown. Requests for listing shall include evidence of satisfactory usage and specific data to permit establishment of allowable stresses, maximum and minimum temperature limits, and other restrictions. Additional criteria can be found in the guidelines for addition of new materials in the ASME Boiler and Pressure Vessel Code, Section II and Section VIII, Division 1, Appendix B. (To develop usage and gain experience, unlisted materials may be used in accordance with para. 323.1.2.) Metric versions of Tables A-1 and A-2 are in the course of preparation. Please refer to the B31.3 Process Piping Web pages at <http://cstools.asme.org/csconnect/CommitteePages.cfm>.



# ASME B31.3-2008 SUMMARY OF CHANGES

Following approval by the B31 Committee and ASME, and after public review, ASME B31.3-2008 was approved by the American National Standards Institute on September 19, 2008.

Changes given below are identified on the pages by a margin note, **(08)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
xi, xii	Foreword	Last paragraph revised
xvii, xviii	Introduction	Third to last paragraph revised
2, 4	300.2	<i>elevated temperature fluid service</i> added
10	301.1	Revised in its entirety
	301.2.2(a)	Revised
11	301.5.3	Revised
13	302.3.2	Footnote (2) revised
15, 18	302.3.5	(1) Subparagraphs (c) and (e) revised (2) Subparagraph (f) added
	302.3.6(a)	In second paragraph, cross-reference to Table Y-3 deleted
19	Table 302.3.5	Added
28	304.5.1(a)	Revised
29	304.7.2	Subparagraphs (b) and (d) revised
30	305.2.4	Added
32	308.2.3	First cross-reference revised
33, 34	311.2	(1) Subparagraphs 311.2.3 through 311.2.6 redesignated as 311.2.4 through 311.2.7, respectively (2) New subpara. 311.2.3 added
38	319.4.1(c)	Footnote 9 revised
42, 43	321.3.2	Revised
	322.6.3(a)	Revised
56, 57	Table 326.1	(1) ASME B16.28 deleted (2) For AWWA C115, title revised (3) For MSS SP-43, Note reference added (4) Note (3) revised
65	331.1.1(e)	Added
71	335.10	Added
77	341.3.4(f)	Added
	341.4.1	Title revised



<i>Page</i>	<i>Location</i>	<i>Change</i>
78	341.4.4	Added
81	345.2.3	Subparagraphs (a) and (b) revised
82	345.3.3	Subparagraphs (a), (b), and (c) revised
	345.4.2	Subparagraphs (a) and (b) revised
87	A304.5.1(a)	Revised
	A304.7.2	Title revised
88	A307	Title revised
93, 94	A326.4	Revised
95, 96	Table A326.1	(1) First body heading and various titles revised (2) Under Nonmetallic Fittings, Valves, and Flanges, ASTM D 2846M, D 5685, F 423, F 491, F 492, F 546, F 599, F 781, and MSS SP-122 added (3) Under Nonmetallic Pipes and Tubes, ASTM D 2846M, F 423, F 441M, F 442M, F 491, F 492, F 546, F 599, and F 781 added (4) Under Miscellaneous, ASTM D 2672 deleted
109	MA307	Revised
113, 114	K302.3.1(d)	Revised
	K302.3.2(b)(1)	(1) Revised (2) Footnote 1 added
	K302.3.2(b)(2)	In second paragraph, Table Y-3 cross-reference deleted
	K302.3.2(c)(2)	Table Y-3 cross-reference deleted
	K302.3.2(d)	Revised
	K302.3.3(a)	Revised
115	K302.3.6(a)	Revised
117	K304.4(b)	Revised
	K304.5.1(b)	Revised
	K304.5.2(b)	Revised
	K304.5.3	Revised
	K304.7.2	(1) First paragraph revised (2) Subparagraph (c) revised
118	K304.8.2(a)	Revised
	K304.8.3(a)	Footnote 10 (formerly footnote 9) revised
	K304.8.5	First paragraph revised
120	K309	Revised
127	Table K326.1	Under Metallic Fittings, Valves, and Flanges, ASME B16.48 added



<i>Page</i>	<i>Location</i>	<i>Change</i>
132	Table K341.3.2	(1) Acceptable Value Limits revised (2) Note (3) revised
134, 135	K345	Revised in its entirety
138–140	Specification Index for Appendix A	Revised
141, 144	Notes for Appendix A Tables	Note (78) added
150, 151	Table A-1	Under Carbon Steel, third body subheading revised
152, 153	Table A-1	Under Carbon Steel, first body subheading revised
178	Table A-1	Under Nickel and Nickel Alloy, Pipes and Tubes, for Ni–Mo–Cr B 619 N06455, P-No. revised
180, 181	Table A-1	(1) For Ni–Mo–Cr B 622 N06455, B 619 N10276, B 622 N10276, B 619 N06022, and B 622 N06022, P-No revised (2) For Low C–Ni–Cr–Mo B 619 N06059 and B 622 N06059, P-No. revised (3) Ni–Mo B 619, B 622, and B 626 N10675 added
182, 183	Table A-1	(1) Under Plates and Sheets, for Low C–Ni–Fe–Cr–Mo–Cu B 625 N08031, P-No. added (2) For Low C–Ni–Mo–Cr B 575 N06455 and N10276, P-No. revised (3) For Ni–Cr–Mo–Cb B 575 N06022, P-No. revised (4) For Low C–Ni–Cr–Mo B 575 N06059, P-No. added (5) Ni–Mo B 333 N10675 added (6) Under Forgings and Fittings, for Ni B 366 N02200, Ni–Fe–Cr B 564 N08811, and Ni–Cr–Fe B 366 N06600, S-No. replaced by P-No.
184, 185	Table A-1	(1) For Ni–Cr–Mo–Fe B 366 N06002, and Low C–Ni–Fe–Cr–Mo–Cu B 366 and B 564 N08031, S-No. replaced by P-No. (2) For Ni–Mo–Cr B 366 and B 564 N10276, P-No. revised (3) For Ni–Mo–Cr B 366 and Ni–Cr–Mo B 564 N06022, P-No. revised (4) For Low C–Ni–Cr–Mo B 366 and B 564 N06059, S-No. replaced by P-No. (5) Ni–Mo B 366, B 462, and B 564 N10675 added (6) Under Rod and Bar, for Low C–Ni–Fe–Cr–Mo–Cu B 649 N08031, S-No. replaced by P-No.



<i>Page</i>	<i>Location</i>	<i>Change</i>
		(7) For Ni–Mo–Cr B 574 N06455, P-No. revised
		(8) For Low C–Ni–Cr–Mo B 574 N06059, S-No. replaced by P-No.
		(9) Ni–Mo B 335 N10675 added
		(10) Under Castings, for Ni–Cr–Mo A 494 CX-2MW, S-No. replaced by P-No.
191	Table A-1	Under Aluminum Alloy, Plates and Sheets, for second B 209 Grade 5083, Temper revised
193	Table A-1	Under Castings, for B 26 Temper F, Specified Min. Yield Strength and stress values revised
195	Table A-1B	Under Low and Intermediate Alloy Steel, for A 333 and A 671, Note (78) added to second line
196	Table A-1B	For A 672 and A 691, Note (78) added to second line
197	Table A-1B	Under Nickel and Nickel Alloy, B 626 added
209	Specification Index for Appendix B	(1) Titles for ASTM D 2997, ASTM F 441, AWWA C302, and AWWA C950 revised (2) Note (1) revised
210	Notes for Appendix B Tables	(1) Note (4) deleted (2) Note (5) redesignated as (4)
211	Table B-1	Revised in its entirety
226	Table C-6	General Note added
231	Table D300	Note (7) revised
232–236	Appendix E	(1) ASTM A 36, A 508, B 333, B 335, B 338, B 363, B 462, B 564, B 619, B 622, and B 861 revised (2) ASTM B 336, B 626, and D 5685 added (3) ASME A13.1 added (4) ASME B16.28 deleted (5) ICC Uniform Building Code added (6) MSS SP-122 added (7) NACE MR0103 added (8) Address for ICC added
240	F323.4(b)(6)	Text and footnote 1 revised
241	F335.10	Added
247–258	Appendix J	Revised
275	L303.3	ASME B16.5 cross-references corrected by errata in five places to read Annex C, Table C1, Group Ia, Group I, or Group Ib



<i>Page</i>	<i>Location</i>	<i>Change</i>
279	P302.3.5	First paragraph revised
	P319.4.4(a)	Nomenclature for $i_a$ revised
286	S302.1	First paragraph revised
287, 288	S302.6.1	First paragraph revised
	S302.6.2	Revised
	S302.7	Revised
289	S302.8	First paragraph revised
292, 294	S303.8	Last paragraph revised
295–297	V303.1	Revised in its entirety
	V304	Revised in its entirety
299	X302.1.2(c)	Revised
300	Fig. X302.1.3	General Note (b) revised
302	X302.2.3(a)	Revised
304–316	Index	Revised

NOTES:

- (1) The interpretations to ASME B31.3 issued between November 1, 2005 and October 31, 2007 follow the last page of this edition as a separate supplement, Interpretations Volume 21.
- (2) After the interpretations, a separate supplement containing Cases 178, 180, and 181 follows.



INTENTIONALLY LEFT BLANK



# Chapter I

## Scope and Definitions

### 300 GENERAL STATEMENTS

(a) *Identification.* This Process Piping Code is a Section of the American Society of Mechanical Engineers Code for Pressure Piping, ASME B31, an American National Standard. It is published as a separate document for convenience of Code users.

(b) *Responsibilities*

(1) *Owner.* The owner of a piping installation shall have overall responsibility for compliance with this Code, and for establishing the requirements for design, construction, examination, inspection, and testing which will govern the entire fluid handling or process installation of which the piping is a part. The owner is also responsible for designating piping in certain fluid services and for determining if a specific Quality System is to be employed. [See paras. 300(d)(4), (d)(5), (e), and Appendix Q.]

(2) *Designer.* The designer is responsible to the owner for assurance that the engineering design of piping complies with the requirements of this Code and with any additional requirements established by the owner.

(3) *Manufacturer, Fabricator, and Erector.* The manufacturer, fabricator, and erector of piping are responsible for providing materials, components, and workmanship in compliance with the requirements of this Code and of the engineering design.

(4) *Owner's Inspector.* The owner's Inspector (see para. 340) is responsible to the owner for ensuring that the requirements of this Code for inspection, examination, and testing are met. If a Quality System is specified by the owner to be employed, the owner's Inspector is responsible for verifying that it is implemented.

(c) *Intent of the Code*

(1) It is the intent of this Code to set forth engineering requirements deemed necessary for safe design and construction of piping installations.

(2) This Code is not intended to apply to the operation, examination, inspection, testing, maintenance, or repair of piping that has been placed in service. The provisions of this Code may optionally be applied for those purposes, although other considerations may also be necessary.

(3) Engineering requirements of this Code, while considered necessary and adequate for safe design, generally employ a simplified approach to the subject. A designer capable of applying a more rigorous analysis

shall have the latitude to do so; however, the approach must be documented in the engineering design and its validity accepted by the owner. The approach used shall provide details of design, construction, examination, inspection, and testing for the design conditions of para. 301, with calculations consistent with the design criteria of this Code.

(4) Piping elements should, insofar as practicable, conform to the specifications and standards listed in this Code. Piping elements neither specifically approved nor specifically prohibited by this Code may be used provided they are qualified for use as set forth in applicable Chapters of this Code.

(5) The engineering design shall specify any unusual requirements for a particular service. Where service requirements necessitate measures beyond those required by this Code, such measures shall be specified by the engineering design. Where so specified, the Code requires that they be accomplished.

(6) Compatibility of materials with the service and hazards from instability of contained fluids are not within the scope of this Code. See para. F323.

(d) *Determining Code Requirements*

(1) Code requirements for design and construction include fluid service requirements, which affect selection and application of materials, components, and joints. Fluid service requirements include prohibitions, limitations, and conditions, such as temperature limits or a requirement for safeguarding (see para. 300.2 and Appendix G). Code requirements for a piping system are the most restrictive of those which apply to any of its elements.

(2) For metallic piping not in Category M or high pressure fluid service, Code requirements are found in Chapters I through VI (the base Code), and fluid service requirements are found in

- (a) Chapter III for materials
- (b) Chapter II, Part 3, for components
- (c) Chapter II, Part 4, for joints

(3) For nonmetallic piping and piping lined with nonmetals, all requirements are found in Chapter VII. (Paragraph designations begin with "A.")

(4) For piping in a fluid service designated by the owner as Category M (see para. 300.2 and Appendix M), all requirements are found in Chapter VIII. (Paragraph designations begin with "M.")

(5) For piping in a fluid service designated by the owner as Category D (see para. 300.2 and Appendix M),



piping elements restricted to Category D Fluid Service in Chapters I through VII, as well as elements suitable for other fluid services, may be used.

(6) Metallic piping elements suitable for Normal Fluid Service in Chapters I through VI may also be used under severe cyclic conditions unless a specific requirement for severe cyclic conditions is stated.

(e) *High Pressure Piping.* Chapter IX provides alternative rules for design and construction of piping designated by the owner as being in High Pressure Fluid Service.

(1) These rules apply only when specified by the owner, and only as a whole, not in part.

(2) Chapter IX rules do not provide for Category M Fluid Service. See para. K300.1.4.

(3) Paragraph designations begin with "K."

(f) *Appendices.* Appendices of this Code contain Code requirements, supplementary guidance, or other information. See para. 300.4 for a description of the status of each Appendix.

### 300.1 Scope

Rules for the Process Piping Code Section B31.3<sup>1</sup> have been developed considering piping typically found in petroleum refineries; chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants; and related processing plants and terminals.

#### 300.1.1 Content and Coverage

(a) This Code prescribes requirements for materials and components, design, fabrication, assembly, erection, examination, inspection, and testing of piping.

(b) This Code applies to piping for all fluids, including

- (1) raw, intermediate, and finished chemicals
- (2) petroleum products
- (3) gas, steam, air, and water
- (4) fluidized solids
- (5) refrigerants
- (6) cryogenic fluids

(c) See Fig. 300.1.1 for a diagram illustrating the application of B31.3 piping at equipment. The joint connecting piping to equipment is within the scope of B31.3.

**300.1.2 Packaged Equipment Piping.** Also included within the scope of this Code is piping which interconnects pieces or stages within a packaged equipment assembly.

**300.1.3 Exclusions.** This Code excludes the following:

(a) piping systems designed for internal gage pressures at or above zero but less than 105 kPa (15 psi), provided the fluid handled is nonflammable, nontoxic, and not damaging to human tissues as defined in 300.2,

<sup>1</sup>B31 references here and elsewhere in this Code are to the ASME B31 Code for Pressure Piping and its various Sections, which are identified and briefly described in the Introduction.

and its design temperature is from  $-29^{\circ}\text{C}$  ( $-20^{\circ}\text{F}$ ) through  $186^{\circ}\text{C}$  ( $366^{\circ}\text{F}$ )

(b) power boilers in accordance with BPV Code<sup>2</sup> Section I and boiler external piping which is required to conform to B31.1

(c) tubes, tube headers, crossovers, and manifolds of fired heaters, which are internal to the heater enclosure

(d) pressure vessels, heat exchangers, pumps, compressors, and other fluid handling or processing equipment, including internal piping and connections for external piping

### 300.2 Definitions

(08)

Some of the terms relating to piping are defined below. For welding, brazing, and soldering terms not shown here, definitions in accordance with AWS Standard A3.0<sup>3</sup> apply.

*air-hardened steel:* a steel that hardens during cooling in air from a temperature above its transformation range.

*anneal heat treatment:* see *heat treatment*.

*arc cutting:* a group of cutting processes wherein the severing or removing of metals is effected by melting with the heat of an arc between an electrode and the base metal. (Includes carbon-arc cutting, metal-arc cutting, gas metal-arc cutting, gas tungsten-arc cutting, plasma-arc cutting, and air carbon-arc cutting.) See also *oxygen-arc cutting*.

*arc welding (AW):* a group of welding processes which produces coalescence of metals by heating them with an arc or arcs, with or without the application of pressure and with or without the use of filler metal.

*assembly:* the joining together of two or more piping components by bolting, welding, bonding, screwing, brazing, soldering, cementing, or use of packing devices as specified by the engineering design.

*automatic welding:* welding with equipment which performs the welding operation without adjustment of the controls by an operator. The equipment may or may not perform the loading and unloading of the work.

*backing filler metal:* see *consumable insert*.

*backing ring:* material in the form of a ring used to support molten weld metal.

*balanced piping system:* see para. 319.2.2(a).

<sup>2</sup>BPV Code references here and elsewhere in this Code are to the ASME Boiler and Pressure Vessel Code and its various Sections as follows:

- Section I, Power Boilers
- Section II, Materials, Part D
- Section V, Nondestructive Examination
- Section VIII, Pressure Vessels, Divisions 1 and 2
- Section IX, Welding and Brazing Qualifications

<sup>3</sup>AWS A3.0, Standard Welding Terms and Definitions, Including Terms for Adhesive Bonding, Brazing, Soldering, Thermal Coupling and Thermal Spraying

