

# STANDARD FOR ACCEPTANCE TESTING SPECIFICATIONS

for Electrical Power  
Equipment and Systems



InterNational Electrical  
Testing Association



*American National Standard*

# 2009

ANSI/NETA ATS-2009

AMERICAN NATIONAL STANDARD

**STANDARD FOR**  
**ACCEPTANCE TESTING SPECIFICATIONS** for  
Electrical Power Equipment  
and Systems

Secretariat  
**InterNational Electrical Testing Association**



Approved by  
**American National Standards Institute**



**– This page intentionally left blank –**



# American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**Caution Notice:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by  
**InterNational Electrical Testing Association**  
3050 Old Centre Avenue, Suite 102  
Portage, MI 49024  
888.300.6382 • FAX 269.488.6383  
[www.netaworld.org](http://www.netaworld.org)  
[neta@netaworld.org](mailto:neta@netaworld.org)  
Jayne Tanz - Executive Director

Copyright© 2009  
InterNational Electrical Testing Association  
All rights reserved  
Printed in the United States of America

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.





### **Copyright Information and Alteration of Content**

*2009 ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* (ANSI/NETA ATS-2009) is protected under the copyright laws of the United States, and all rights are reserved. Further, the ANSI/NETA ATS-2009 may not be copied, modified, sold, or used except in accordance with such laws and as follows:

Purchasers may reproduce and use all or a portion of the ANSI/NETA ATS-2009 provided *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* are clearly identified in writing as the source of all such uses or reproductions.

Section 7 of the *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* may be reproduced and used on a “cut and paste” basis for the particular type of equipment to be tested.

The following sections of the *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* must be incorporated by reference as part of any subsection:

3. Qualifications of Testing Organization and Personnel
  - 3.1 Testing Organization
  - 3.2 Testing Personnel
4. Division of Responsibility
  - 4.1 The Owner’s Representative
  - 4.2 The Testing Organization
5. General
  - 5.1 Safety and Precautions
  - 5.2 Suitability of Test Equipment
  - 5.3 Test Instrument Calibration
  - 5.4 Test Report

The purchaser is required to include the above sections with any section(s) of 7.

**© Copyright 2009**  
InterNational Electrical Testing Association  
3050 Old Centre Avenue, Suite 102  
Portage, MI 49024  
E-mail: [neta@netaworld.org](mailto:neta@netaworld.org) • Web: [www.netaworld.org](http://www.netaworld.org)



## Standards Review Council

These specifications were submitted for public comment and reviewed by the NETA Standards Review Council.

Charles K. Blizzard, Sr.  
Timothy J. Cotter  
Diane W. Hageman  
Roderic L. Hageman  
David Huffman  
Ralph Patterson  
Alan D. Peterson  
Jayne Tanz  
Ron Widup

### **Ballot Pool Members Of ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems, 2009**

Ken Bassett  
Tom Bishop  
Scott Blizzard  
Michel Castonguay  
Rick Eynon  
David Geary  
Don Genutis  
Paul Hartman

Gary Hartshorn  
David Huffman  
Stuart Jackson  
Jim Jordan  
Scott Kinney  
Andrew Kobler  
Benjamin Lanz  
Mark Lautenschlager

Joe Nims  
Jerry Parnell  
Jaime Ybarra  
Mose Ramieh  
Randall Sagan  
Peter Sammy  
Richard Sobhraj  
Larry Stovall

Tim Thomas  
Alan Turpen  
Wally Vahlstrom  
Chris Werstiuk  
John White  
JP Wolff



## NETA Accredited Companies

The following is a listing of all NETA Accredited Companies as of the date this document was approved by ANSI as an American National Standard, February 19, 2009.

A&F Electrical Testing, Inc.	Kevin Chilton
Advanced Testing Systems	D. Patrick MacCarthy
American Electrical Testing Co.	Scott A. Blizard
Apparatus Testing and Engineering	James Lawler
Applied Engineering Concepts	Michel Castonguay
Burlington Electrical Testing Company, Inc.	Walter Cleary
C.E. Testing, Inc.	Mark Chapman
DYMAX Holdings, Inc.	Gene Philipp
Eastern High Voltage	Joseph Wilson
Electric Power Systems, Inc.	Steve Reed
Electrical and Electronic Controls	Michael Hughes
Electrical Energy Experts, Inc.	William Styer
Electrical Engineering Consulting & Testing, P.C.	Barry W. Tyndall
Electrical Equipment Upgrading, Inc.	Kevin Miller
Electrical Reliability Services	Lee Bigham
Electrical Testing Services	Frank Plonka
Electrical Testing, Inc.	Steve Dodd
Elemco Testing Co. Inc.	Robert J. White
ESCO Energy Services	Lynn Hamrick
Hampton Tedder Technical Services	Matt Tedder
Harford Electrical Testing Co., Inc.	Vincent Biondino
High Energy Electrical Testing, Inc.	James P. Ratshin
High Voltage Maintenance Corp.	Tom Nation
HMT, Inc.	John Pertgen
Industrial Electric Testing, Inc.	Gary Benzenberg
Industrial Electronics Group	Butch E. Teal
Infra-Red Building and Power Service	Thomas McDonald
M&L Power Systems Maintenance, Inc.	Darshan Arora
Magna Electric Corporation	Kerry Heid
Magna IV Engineering – Edmonton	Wayne Sheridan



## NETA Accredited Companies

Magna IV Engineering, Ltd. – BC	Cameron Hite
MET Electrical Testing Co., Inc.	William McKenzie
Nationwide Electrical Testing, Inc.	Shashikant B. Bagle
North Central Electric, Inc.	Robert Messina
Northern Electrical Testing, Inc.	Lyle Detterman
Orbis Engineering Field Services, Ltd.	Lorne Gara
Phasor Engineering	Rafael Castro
Potomac Testing, Inc.	Ken Bassett
Power & Generation Testing, Inc.	Mose Ramieh
Power Engineering Services, Inc.	Miles R. Engelke
Power Plus Engineering, Inc.	Salvatore Mancuso
Power Products & Solutions, Inc.	Ralph Patterson
Power Services, Inc.	Gerald Bydash
Power Systems Testing Co.	David Huffman
Power Test, Inc.	Richard Walker
Power Testing and Energization, Inc.	Chris Zavadlov
Powertech Services, Inc.	Jean A. Brown
PRIT Service, Inc.	Roderic Hageman
Reuter & Hanney, Inc.	Michael Reuter
REV Engineering, Ltd.	Roland Davidson
Scott Testing, Inc.	Russ Sorbello
Shermco Industries, Inc.	Ron Widup
Sigma Six Solutions, Inc.	John White
Taurus Power and Controls, Inc.	Rob Bulfinch
Tony Demaria Electric, Inc.	Anthony Demaria
Trace Electrical Services & Testing, LLC	Joseph Vasta
Utilities Instrumentation Service, Inc.	Gary Walls
Utility Service Corporation	Alan Peterson



## NOTICE

In no event shall the InterNational Electrical Testing Association be liable to anyone for special, collateral, incidental, or consequential damages in connection with or arising out of the use of these materials.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. Comments and suggestions are invited from all users for consideration by the Association in connection with such review. Any such suggestions will be fully reviewed by the Association after giving the commenter, upon request, a reasonable opportunity to be heard.

This document should not be confused with federal, state, or municipal specifications or regulations, insurance requirements, or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, use of this document is purely voluntary and not binding.

InterNational Electrical Testing Association  
3050 Old Centre Avenue, Suite 102 • Portage, MI 49024  
Voice: 888.300.6382 Facsimile: 269.488.6383  
Email: [neta@netaworld.org](mailto:neta@netaworld.org) • Web: [www.netaworld.org](http://www.netaworld.org)  
Jayne Tanz, CMP - Executive Director



# FOREWORD

(This Foreword is not part of American National Standard ANSI/NETA ATS-2009)

The InterNational Electrical Testing Association (NETA) was formed in 1972 to establish uniform testing procedures for electrical equipment and apparatus. NETA developed specifications for the acceptance of new electrical apparatus prior to energization and for the maintenance of existing apparatus to determine its suitability to remain in service. The first NETA *Acceptance Testing Specifications for Electrical Power Equipment and Systems* was produced in 1972. Upon completion of this project, the NETA Technical Committee began work on a maintenance document, and *Maintenance Testing Specifications for Electrical Power Equipment and Systems* was published in 1975.

NETA has been an Accredited Standards Developer for the American National Standards Institute since 1996. NETA's scope of standards activity is different from that of the IEEE, NECA, NEMA, and UL. In matters of testing electrical equipment and systems NETA continues to reference other standards developers' documents where applicable. NETA's review and updating of presently published standards takes into account both national and international standards. NETA's standards may be used internationally as well as in the United States. NETA firmly endorses a global standardization. IEC standards as well as American consensus standards are taken into consideration by NETA's Section Panels and reviewing committees.

The *NETA Acceptance Testing Specifications* was developed for use by those responsible for assessing the suitability for initial energization of electrical power equipment and systems and to specify field tests and inspections that ensure these systems and apparatus perform satisfactorily, minimizing downtime and maximizing life expectancy.

Since 1972, several revisions of the *Acceptance Testing Specifications* have been published; in 1989 the NETA Technical Committee, with approval of the Board of Directors, set a four-year review and revision schedule. Unless it involves a significant safety or urgent technical issue, each comment and suggestion for change is held until the appropriate review period. Each edition includes new and completely revised sections. The document uses the standard numbering system of ANSI and IEEE. Since 1989, revised editions of the *Acceptance Testing Specifications* have been published in 1991, 1995, 1999, 2003, and 2007.

On February 19, 2009, the American National Standards Institute approved the NETA *Acceptance Testing Specifications for Electrical Power Equipment and Systems* as an American National Standard.

Suggestions for improvement of this standard are welcome. They should be sent to the InterNational Electrical Testing Association, 3050 Old Centre Avenue, Suite 102, Portage, MI 49024.



# PREFACE

It is recognized by the Association that the needs for acceptance testing of commercial, industrial, governmental, and other electrical power systems vary widely. Many criteria are used in determining what equipment is to be tested and to what extent.

To help the user better understand and navigate more efficiently through this document, we offer the following information:

## Notation of Changes

Material included in this edition of the document but not part of the 2007 edition is marked with a black vertical line in the margin to the left of the insertion of text, deletion of text, or alteration of text.

## The Document Structure

The document is divided into twelve separate and defined sections:

<b>Section</b>	<b>Description</b>
Section 1	General Scope
Section 2	Applicable References
Section 3	Qualifications of Testing Organization and Personnel
Section 4	Division of Responsibility
Section 5	General
Section 6	Power System Studies
Section 7	Inspection and Test Procedures
Section 8	System Function Test
Section 9	Thermographic Survey
Section 10	Electromagnetic Field Testing
Tables	Reference Tables
Appendices	Various Informational Documents

## Section 7 Structure

Section 7 is the main body of the document with specific information on what to do relative to the inspection and acceptance testing of electrical power distribution equipment and systems. It is not intended that this document list how to test specific pieces of equipment or systems.

## Expected Test Results

Section 7 consists of sections specific to each particular type of equipment. Within those sections there are, typically, three main bodies of information:


1. Visual and Mechanical Inspection
2. Electrical Tests
3. Test Values




## PREFACE (Continued)

### Results of Visual and Mechanical Inspections

Some, but not all, visual and mechanical inspections have an associated test value or result. Those items with an expected result are referenced under Section 3.1 Test Values – Visual and Mechanical. For example, Section 7.1 Switchgear and Switchboard Assemblies, item 7.1.1.7.2 calls for verifying tightness of connections using a calibrated torque wrench method. Under the Test Values – Visual and Mechanical Section 7.1.3.1.2, the expected results for that particular task are listed within Section 3.1, with reference back to the original task description on item 7.1.1.7.2.

<p>7. INSPECTION AND TEST PROCEDURES</p> <p>7.1 Switchgear and Switchboard Assemblies</p> <p>1. Visual and Mechanical Inspection</p> <ol style="list-style-type: none"><li>1. Compare equipment nameplate data with drawings and specifications.</li><li>2. Inspect physical and mechanical condition.</li><li>3. Inspect anchorage, alignment, grounding, and required area clearances.</li><li>4. Verify the unit is clean and all shipping bracing, loose parts, and documentation shipped inside cubicles have been removed.</li><li>5. Verify that fuse and circuit breaker sizes and types correspond to drawings and coordination study as well as to the circuit breaker's address for microprocessor-communication packages.</li><li>6. Verify that current and voltage transformer ratios correspond to drawings.</li><li>7. Inspect bolted electrical connections for high resistance using one or more of the following methods:<ol style="list-style-type: none"><li>1. Use of a low-resistance ohmmeter in accordance with Section 7.1.2.</li><li>2. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method in accordance with manufacturer's published data or Table 100.12.</li><li>3. Perform thermographic survey in accordance with Section 9.</li></ol></li><li>8. Confirm correct operation and sequencing of electrical and mechanical interlock systems.<ol style="list-style-type: none"><li>1. Attempt closure on locked-open devices. Attempt to open locked-closed devices.</li><li>2. Make key exchange with devices operated in off-normal positions.</li></ol></li><li>9. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.</li><li>10. Inspect insulators for evidence of physical damage or contaminated surfaces.</li><li>11. Verify correct barrier and shutter installation and operation.</li><li>12. Exercise all active components.</li><li>13. Inspect mechanical indicating devices for correct operation.</li><li>14. Verify that filters are in place and vents are clear.</li><li>15. Perform visual and mechanical inspection of instrument transformers in accordance with Section 7.10.</li></ol> <p>* Optional</p> <p> Page 23 ANSI/NETA ATS-2009</p>	
--	--

	<p>7. INSPECTION AND TEST PROCEDURES</p> <p>7.1 Switchgear and Switchboard Assemblies (continued)</p> <ol style="list-style-type: none"><li>4. Verify correct secondary voltage by energizing the primary winding with system voltage. Measure secondary voltage with the secondary wiring disconnected.</li><li>5. Verify correct function of control transfer relays located in the switchgear with multiple control power sources.</li></ol> <p>9. Voltage Transformers</p> <ol style="list-style-type: none"><li>1. Perform secondary wiring integrity test. Verify correct potential at all devices.</li><li>2. Verify secondary voltages by energizing the primary winding with system voltage.</li></ol> <p>10. Perform current-injection tests on the entire current circuit in each section of switchgear.</p> <ol style="list-style-type: none"><li>1. Perform current tests by secondary injection with magnitudes such that a minimum current of 1.0 ampere flows in the secondary circuit. Verify correct magnitude of current at each device in the circuit.</li><li>*2. Perform current tests by primary injection with magnitudes such that a minimum of 1.0 ampere flows in the secondary circuit. Verify correct magnitude of current at each device in the circuit.</li></ol> <ol style="list-style-type: none"><li>11. Perform system function tests in accordance with Section 8.</li><li>12. Verify operation of cubicle switchgear/switchboard space heaters.</li><li>13. Perform phasing checks on double-ended or dual-source switchgear to insure correct bus phasing from each source.</li></ol> <p>3. Test Values</p> <p>3.1 Test Values – Visual and Mechanical</p> <ol style="list-style-type: none"><li>1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value. (7.1.1.7.1)</li><li>2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.1.1.7.2)</li><li>3. Results of the thermographic survey shall be in accordance with Section 9. (7.1.1.7.3)</li></ol> <p>* Optional</p> <p> Page 25 ANSI/NETA ATS-2009</p>
--	--



## PREFACE (Continued)

### Results of Electrical Tests

Each electrical test has a corresponding expected result, and the test and the result have identical numbers. If the electrical test is item four, the expected result under the Test Values section is also item four. For example, under Section 7.15.1 Rotating Machinery, AC Induction Motors and Generators, item 7.15.1.2.2 (item 2 within the Electrical Tests section) calls for performing an insulation-resistance test in accordance with IEEE Standard 43. Under the Test Values – Electrical section, the expected results for that particular task are listed in the Test Values section under item 2.

<p>7. INSPECTION AND TEST PROCEDURES</p> <p>7.15.1 Rotating Machinery, AC Induction Motors and Generators</p> <p>1. Visual and Mechanical Inspection</p> <ol style="list-style-type: none"><li>1. Compare equipment nameplate data with drawings and specifications.</li><li>2. Inspect physical and mechanical condition.</li><li>3. Inspect anchorage, alignment, and grounding.</li><li>4. Inspect air baffles, filter media, cooling fans, slip rings, brushes, and brush rigging.</li><li>5. Inspect bolted electrical connections for high resistance using one of the following methods:<ol style="list-style-type: none"><li>1. Use of low-resistance ohmmeter in accordance with Section 7.15.1.2.</li><li>2. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12.</li><li>3. Perform thermographic survey in accordance with Section 9.</li></ol></li><li>6. Perform special tests such as air-gap spacing and machine alignment, if applicable.</li><li>7. Verify the application of appropriate lubrication and lubrication systems.</li><li>8. Verify that resistance temperature detector (RTD) circuits conform to drawings.</li></ol> <p>2. Electrical Tests – AC Induction</p> <ol style="list-style-type: none"><li>1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter, if applicable, in accordance with Section 7.15.1.1.</li><li>2. Perform insulation-resistance tests in accordance with ANSI/IEEE Standard 43.<ol style="list-style-type: none"><li>1. Machines larger than 200 horsepower (150 kilowatts): Test duration shall be ten minutes. Calculate polarization index.</li><li>2. Machines 200 horsepower (150 kilowatts) and less: Test duration shall be one minute. Calculate dielectric-absorption ratio.</li></ol></li><li>3. Perform dc dielectric withstand voltage tests on machines rated at 2300 volts and greater in accordance with ANSI/IEEE Standard 95.</li><li>4. Perform phase-to-phase stator resistance test on machines 2300 volts and greater.</li></ol> <p>*5. Perform insulation power-factor or dissipation-factor tests.</p>	
--	--

	<p>7. INSPECTION AND TEST PROCEDURES</p> <p>7.15.1 Rotating Machinery, AC Induction Motors and Generators (continued)</p> <p>5. Air-gap spacing and machine alignment shall be in accordance with manufacturer's published data. (7.15.1.1.6).</p> <p>3.2 Test Values – Electrical Tests</p> <ol style="list-style-type: none"><li>1. Compare bolted connection resistance values to values of similar connections. Investigate any values that deviate from similar bolted connections by more than 50 percent of the lowest value.</li><li>2. The dielectric absorption ratio or polarization index shall not be less than 1.0. The recommended minimum insulation resistance (<math>IR_{1min}</math>) test results in megohms shall be corrected to 40° C and read as follows:<ol style="list-style-type: none"><li>1. <math>IR_{1min} = kV + 1</math> for most windings made before 1970, all field windings, and others not described in 2.2 and 2.3.  (kV is the rated machine terminal-to-terminal voltage in rms kV)</li><li>2. <math>IR_{1min} = 100</math> megohms for most dc armature and ac windings built after 1970 (form-wound coils).</li><li>3. <math>IR_{1min} = 5</math> megohms for most machines and random-wound stator coils and form-wound coils rated below 1 kV.</li></ol><p>NOTE: Dielectric withstand voltage and surge comparison tests shall not be performed on machines having values lower than those indicated above.</p></li><li>3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.</li><li>4. Investigate phase-to-phase stator resistance values that deviate by more than 10 percent.</li><li>5. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's published data these values will be compared with previous values of similar machines.</li><li>6. Tip-up values shall indicate no significant increase in power factor.</li><li>7. If no evidence of distress, insulation failure, or lack of waveform nesting is observed by the end of the total time of voltage application during the surge comparison test, the test specimen is considered to have passed the test.</li><li>8. Bearing insulation-resistance measurements shall be within manufacturer's published tolerances. In the absence of manufacturer's published tolerances, the comparison shall be made to similar machines.</li></ol> <p>* Optional</p>
--	--



## **PREFACE (*Continued*)**

### **Optional Tests**

The purpose of these specifications is to assure that all tested electrical equipment and systems supplied by either contractor or owner are operational and within applicable standards and manufacturer's published tolerances and that equipment and systems are installed in accordance with design specifications.

Certain tests are assigned an optional classification. The following considerations are used in determining the use of the optional classification:

1. Does another listed test provide similar information?
2. How does the cost of the test compare to the cost of other tests providing similar information?
3. How commonplace is the test procedure? Is it new technology?

### **Manufacturer's Instruction Manuals**

It is important to follow the recommendations contained in the manufacturer's published data. Many of the details of a complete and effective testing procedure can be obtained from this source.

### **Summary**

The guidance of an experienced testing professional should be sought when making decisions concerning the extent of testing. It is necessary to make an informed judgment for each particular system regarding how extensive a procedure is justified. The approach taken in these specifications is to present a comprehensive series of tests applicable to most industrial and larger commercial systems. In smaller systems, some of the tests can be deleted. In other cases, a number of the tests indicated as optional should be performed.

Likewise, guidance of an experienced testing professional should also be sought when making decisions concerning the results of test data and their significance to the overall analysis of the device or system under test. Careful consideration of all aspects of test data, including manufacturer's published data and recommendations, must be included in the overall assessment of the device or system under test.

The Association encourages comment from users of this document. Please contact the NETA office or your local NETA Accredited Company.

### **Standards Review Council InterNational Electrical Testing Association**

Charles K. Blizzard, Sr.  
Timothy J. Cotter  
Diane W. Hageman  
Roderic L. Hageman  
David Huffman  
Ralph Patterson  
Alan D. Peterson  
Jayne Tanz  
Ron Widup



**– This page intentionally left blank –**



# CONTENTS

1.	GENERAL SCOPE .....	1
2.	APPLICABLE REFERENCES	
2.1	Codes, Standards and Specifications .....	2
2.2	Other Publications.....	8
2.3	Contact Information .....	8
3.	QUALIFICATIONS OF TESTING ORGANIZATION AND PERSONNEL	
3.1	Testing Organization.....	11
3.2	Testing Personnel.....	11
4.	DIVISION OF RESPONSIBILITY	
4.1	The Owner's Representative.....	12
4.2	The Testing Organization .....	12
5.	GENERAL	
5.1	Safety and Precautions.....	13
5.2	Suitability of Test Equipment .....	13
5.3	Test Instrument Calibration .....	14
5.4	Test Report.....	15
6.	POWER SYSTEM STUDIES	
6.1	Short-Circuit Studies.....	16
6.2	Coordination Studies.....	17
6.3	Arc-Flash Hazard Analysis.....	18
6.4	Load Flow Studies .....	20
6.5	Stability Studies .....	21
6.6	Harmonic-Analysis Studies .....	22
7.	INSPECTION AND TEST PROCEDURES	
7.1	Switchgear and Switchboard Assemblies .....	23
7.2.1.1	Transformers, Dry-Type, Air-Cooled, Low-Voltage, Small .....	28
7.2.1.2	Transformers, Dry-Type, Air-Cooled, Large.....	30
7.2.2	Transformers, Liquid-Filled.....	33
7.3.1	Cables, Low-Voltage, Low-Energy - Reserved.....	37
7.3.2	Cables, Low-Voltage, 600-Volt Maximum .....	38
7.3.3	Cables, Medium- and High-Voltage .....	40
7.4	Metal-Enclosed Busways.....	43
7.5.1.1	Switches, Air, Low-Voltage .....	45
7.5.1.2	Switches, Air, Medium-Voltage, Metal-Enclosed.....	47
7.5.1.3	Switches, Air, Medium- and High-Voltage, Open .....	50
7.5.2	Switches, Oil, Medium-Voltage .....	53
7.5.3	Switches, Vacuum, Medium-Voltage .....	56
7.5.4	Switches, SF <sub>6</sub> , Medium-Voltage.....	59
7.5.5	Switches, Cutouts.....	62
7.6.1.1	Circuit Breakers, Air, Insulated-Case/Molded-Case .....	64
7.6.1.2	Circuit Breakers, Air, Low-Voltage Power .....	67
7.6.1.3	Circuit Breakers, Air, Medium-Voltage .....	71
7.6.2	Circuit Breakers, Oil, Medium- and High-Voltage .....	75
7.6.3	Circuit Breakers, Vacuum, Medium-Voltage .....	80
7.6.4	Circuit Breakers, SF <sub>6</sub> .....	84
7.7	Circuit Switchers.....	88
7.8	Network Protectors, 600-Volt Class .....	91



## CONTENTS (continued)

7.9.1	Protective Relays, Electromechanical and Solid-State .....	94
7.9.2	Protective Relays, Microprocessor-Based .....	101
7.10	Instrument Transformers .....	103
7.11.1	Metering Devices .....	108
7.11.2	Metering Devices, Microprocessor-Based .....	110
7.12.1.1	Regulating Apparatus, Voltage, Step Voltage Regulators .....	112
7.12.1.2	Regulating Apparatus, Voltage, Induction Regulators .....	117
7.12.2	Regulating Apparatus, Current - Reserved .....	121
7.12.3	Regulating Apparatus, Load Tap-Changers .....	122
7.13	Grounding Systems .....	125
7.14	Ground-Fault Protection Systems, Low-Voltage .....	127
7.15.1	Rotating Machinery, AC Induction Motors and Generators .....	130
7.15.2	Rotating Machinery, Synchronous Motors and Generators .....	134
7.15.3	Rotating Machinery, DC Motors and Generators .....	140
7.16.1.1	Motor Control, Motor Starters, Low-Voltage .....	143
7.16.1.2	Motor Control, Motor Starters, Medium-Voltage .....	145
7.16.2.1	Motor Control, Motor Control Centers, Low-Voltage .....	149
7.16.2.2	Motor Control, Motor Control Centers, Medium-Voltage .....	150
7.17	Adjustable Speed Drive Systems .....	151
7.18.1.1	Direct-Current Systems, Batteries, Flooded Lead-Acid .....	154
7.18.1.2	Direct-Current Systems, Batteries, Vented Nickel-Cadmium .....	157
7.18.1.3	Direct-Current Systems, Batteries, Valve-Regulated Lead-Acid .....	160
7.18.2	Direct-Current Systems, Chargers .....	162
7.18.3	Direct-Current Systems, Rectifiers - Reserved .....	164
7.19.1	Surge Arresters, Low-Voltage .....	165
7.19.2	Surge Arresters, Medium- and High-Voltage .....	167
7.20.1	Capacitors and Reactors, Capacitors .....	169
7.20.2	Capacitors and Reactors, Capacitor Control Devices - Reserved .....	171
7.20.3.1	Capacitors and Reactors, Reactors, Shunt and Current-Limiting, Dry-Type .....	172
7.20.3.2	Capacitors and Reactors, Reactors, Shunt and Current-Limiting, Liquid-Filled .....	174
7.21	Outdoor Bus Structures .....	178
7.22.1	Emergency Systems, Engine Generator .....	180
7.22.2	Emergency Systems, Uninterruptible Power Systems .....	182
7.22.3	Emergency Systems, Automatic Transfer Switches .....	185
7.23	Communications - Reserved .....	188
7.24.1	Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum .....	189
7.24.2	Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil .....	193
7.25	Fiber-Optic Cables .....	196
8.	SYSTEM FUNCTION TESTS .....	197
9.	THERMOGRAPHIC SURVEY .....	198
10.	ELECTROMAGNETIC FIELD TESTING .....	199
11.	CORONA STUDIES - Reserved .....	201



## CONTENTS (continued)

### TABLES

100.1	Insulation Resistance Test Values, Electrical Apparatus and Systems.....	204
100.2	Switchgear Withstand Test Voltages .....	205
100.3	Recommended Dissipation Factor/Power Factor at 20° C; Liquid-Filled Transformers, Regulators, and Reactors, Acceptance Test Values.....	206
100.4	Insulating Fluid Limits	
100.4.1	Test Limits for New Insulating Oil Received in New Equipment .....	207
100.4.2	Test Limits for Silicone Insulating Liquid in New Transformers .....	207
100.4.3	Typical Values for Less-Flammable Hydrocarbon Insulating Liquid.....	208
100.5	Transformer Insulation Resistance, Acceptance Testing.....	209
100.6	Medium-Voltage Cables, Acceptance Test Values	
100.6.1	DC Test Voltages .....	210
100.6.2	AC Test Voltages .....	211
100.6.3	Partial Discharge Requirements .....	212
100.6.4	Very Low Frequency Testing Levels .....	212
100.7	Inverse Time Trip Test at 300% of Rated Continuous Current, Molded-Case Circuit Breakers.....	213
100.8	Instantaneous Trip Tolerances for Field Testing of Circuit Breakers.....	214
100.9	Instrument Transformer Dielectric Tests, Field Acceptance .....	215
100.10	Maximum Allowable Vibration Amplitude.....	216
100.11	Reserved .....	217
100.12	US Standard Fasteners, Bolt Torque Values for Electrical Connections	
100.12.1	Heat-Treated Steel - Cadmium or Zinc Plated .....	218
100.12.2	Silicon Bronze Fasteners .....	219
100.12.3	Aluminum Alloy Fasteners .....	219
100.12.4	Stainless Steel Fasteners.....	220
100.13	SF <sub>6</sub> Gas Tests .....	221
100.14	Insulation Resistance Conversion Factors	
100.14.1	Test Temperatures to 20° C.....	222
100.14.2	Test Temperatures to 40° C.....	223
100.15	High-Potential Test Voltage, Automatic Circuit Reclosers.....	224
100.16	High-Potential Test Voltage for Acceptance Test of Line Sectionalizers .....	225
100.17	Dielectric Withstand Test Voltages, Metal-Enclosed Bus.....	226
100.18	Thermographic Survey, Suggested Actions Based on Temperature Rise .....	227
100.19	Dielectric Withstand Test Voltages, Electrical Apparatus Other than Inductive Equipment .....	228
100.20	Rated Control Voltages and their Ranges for Circuit Breakers	
100.20.1	Circuit Breakers.....	229
100.20.2	Solenoid-Operated Devices .....	230
100.21	Accuracy of IEC Class TP Current Transformers Error Limit.....	231
100.22	Minimum Radii for Power Cable, Single & Multiple Conductor Cables with Interlocked Armor, Smooth or Corrugated Aluminum Sheath or Lead Sheath.....	232



## CONTENTS (*continued*)

### APPENDICES

Appendix A - Definitions.....	235
Appendix B - Reserved.....	237
Appendix C - About the InterNational Electrical Testing Association .....	238
Appendix D - Form for Comments.....	240
Appendix E - Form for Proposals .....	241



## 1. GENERAL SCOPE

1. These specifications cover the suggested field tests and inspections that are available to assess the suitability for initial energization of electrical power equipment and systems.
2. The purpose of these specifications is to assure that tested electrical equipment and systems are operational, are within applicable standards and manufacturer's tolerances, and are installed in accordance with design specifications.
3. The work specified in these specifications may involve hazardous voltages, materials, operations, and equipment. These specifications do not purport to address all of the safety issues associated with their use. It is the responsibility of the user to review all applicable regulatory limitations prior to the use of these specifications



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications

All inspections and field tests shall be in accordance with the latest edition of the following codes, standards, and specifications except as provided otherwise herein.

1. American National Standards Institute – ANSI

2. ASTM International - ASTM

ASTM D92	<i>Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester</i>
ASTM D445	<i>Standard Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (the Calculation of Dynamic Viscosity)</i>
ASTM D664	<i>Standard Test Method for Acid Number of Petroleum Products by Potentiometric Titration</i>
ASTM D877	<i>Standard Test Method for Dielectric Breakdown Voltage of Insulating Liquids using Disk Electrodes</i>
ASTM D923	<i>Standard Practices for Sampling Electrical Insulating Liquids</i>
ASTM D924	<i>Standard Test Method for Dissipation Factor (or Power Factor) and Relative Permittivity (Dielectric Constant) of Electrical Insulating Liquids</i>
ASTM D971	<i>Standard Test Method for Interfacial Tension of Oil against Water by the Ring Method</i>
ASTM D974	<i>Standard Test Method for Acid and Base Number by Color-Indicator Titration</i>
ASTM D1298	<i>Standard Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method</i>
ASTM D1500	<i>Standard Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)</i>
ASTM D1524	<i>Standard Test Method for Visual Examination of Used Electrical Insulating Oils of Petroleum Origin in the Field</i>
ASTM D1533	<i>Standard Test Methods for Water in Insulating Liquids by Coulometric Karl Fischer Titration</i>
ASTM D1816	<i>Standard Test Method for Dielectric Breakdown Voltage of Insulating Oils of Petroleum Origin Using VDE Electrodes</i>



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications (*continued*)

ASTM D2029	<i>Standard Test Methods for Water Vapor Content of Electrical Insulating Gases by Measurement of Dew Point</i>
ASTM D2129	<i>Standard Test Method for Color of Clear Electrical Insulating Liquids (Platinum-Cobalt Scale)</i>
ASTM D2284	<i>Standard Test Method of Acidity of Sulfur Hexafluoride</i>
ASTM D2285	<i>Standard Test Method for Interfacial Tension of Electrical Insulating Oils of Petroleum Origin against Water by the Drop-Weight Method</i>
ASTM D2477	<i>Standard Test Method for Dielectric Breakdown Voltage and Dielectric Strength of Insulating Gases at Commercial Power Frequencies</i>
ASTM D2685	<i>Standard Test Method for Air and Carbon Tetrafluoride in Sulfur Hexafluoride by Gas Chromatography</i>
ASTM D2759	<i>Standard Practice for Sampling Gas from a Transformer under Positive Pressure</i>
ASTM D3284	<i>Standard Test Method for Combustible Gases in the Gas Space of Electrical Apparatus Using Portable Meters</i>
ASTM D3612	<i>Standard Test Method for Analysis of Gases Dissolved in Electrical Insulating Oil by Gas Chromatography</i>
ASTM D3613	<i>Standard Practice for Sampling Electrical Insulating Oils for Gas Analysis and Determination of Water Content</i>

3. Association of Edison Illuminating Companies - AEIC

4. Canadian Standards Association - CSA

5. Electrical Apparatus Service Association - EASA

ANSI/EASA AR100 *Recommended Practice for the Repair of Rotating Electrical Apparatus*



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications (*continued*)

6. Institute of Electrical and Electronic Engineers - IEEE

ANSI/IEEE C2	<i>National Electrical Safety Code</i>
ANSI/IEEE C37 Compilation	<i>Guides and Standards for Circuit Breakers, Switchgear, Relays, Substations, and Fuses</i>
ANSI/IEEE C57 Compilation	<i>Distribution, Power, and Regulating Transformers</i>
ANSI/IEEE C62 Compilation	<i>Surge Protection</i>
ANSI/IEEE C93.1	<i>Requirements for Power-Line Carrier Coupling Capacitors and Coupling Capacitor Voltage Transformers (CCVT)</i>
ANSI/IEEE 43	<i>IEEE Recommended Practice for Testing Insulation Resistance of Rotating Machinery</i>
ANSI/IEEE 48	<i>IEEE Standard Test Procedures and Requirements for Alternating- Current Cable Terminations 2.5 kV through 765 kV</i>
IEEE 81	<i>IEEE Guide for Measuring Earth Resistivity, Ground Impedance, and Earth Surface Potentials of a Ground System Part I: Normal Measurements</i>
ANSI/IEEE 81.2	<i>IEEE Guide for Measurement of Impedance and Safety Characteristics of Large, Extended or Interconnected Grounding Systems</i>
ANSI/IEEE 95	<i>IEEE Recommended Practice for Insulation Testing of Large AC Rotating Machinery with High Direct Voltage</i>
IEEE 100	<i>The Authoritative Dictionary of IEEE Standards Terms</i>
IEEE 141	<i>IEEE Recommended Practice for Electrical Power Distribution for Industrial Plants (IEEE Red Book)</i>
ANSI/IEEE 142	<i>IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems (IEEE Green Book)</i>
ANSI/IEEE 241	<i>IEEE Recommended Practice for Electric Power Systems in Commercial Buildings (Gray Book)</i>
ANSI/IEEE 242	<i>IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems (Buff Book)</i>



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications (*continued*)

IEEE 386	<i>IEEE Standard for Separable Insulated Connectors System for Power Distribution Systems above 600 V</i>
ANSI/IEEE 399	<i>IEEE Recommended Practice for Power Systems Analysis (Brown Book)</i>
ANSI/IEEE 400	<i>IEEE Guide for Field Testing and Evaluation of the Insulation of Shielded Power Cable Systems</i>
ANSI/IEEE 400.2	<i>IEEE Guide for Field Testing of Shielded Power Cable Systems Using Very Low Frequency (VLF)</i>
ANSI/IEEE 421.3	<i>IEEE Standard for High-Potential-Test Requirements for Excitation Systems for Synchronous Machines</i>
ANSI/IEEE 446	<i>IEEE Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications (Orange Book)</i>
ANSI/IEEE 450	<i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications</i>
ANSI/IEEE 493	<i>IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems (Gold Book)</i>
ANSI/IEEE 519	<i>IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems</i>
ANSI/IEEE 602	<i>IEEE Recommended Practice for Electric Systems in Health Care Facilities (White Book)</i>
ANSI/IEEE 637	<i>IEEE Guide for the Reclamation of Insulating Oil and Criteria for Its Use</i>
IEEE 644	<i>Procedures for Measurement of Power Frequency Electric and Magnetic Fields from AC Power Lines</i>
ANSI/IEEE 739	<i>IEEE Recommended Practice for Energy Management in Commercial and Industrial Facilities (Bronze Book)</i>
ANSI/IEEE 902	<i>IEEE Guide for Maintenance, Operation and Safety of Industrial and Commercial Power Systems (Yellow Book)</i>
IEEE 1015	<i>IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems (Blue Book)</i>
IEEE 1100	<i>IEEE Recommended Practice for Powering and Grounding Sensitive Electronic Equipment (Emerald Book)</i>



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications (*continued*)

- |                |  |
|----------------|--|
| ANSI/IEEE 1106 | <i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Nickel-Cadmium Batteries for Stationary Applications</i>                   |
| ANSI/IEEE 1159 | <i>IEEE Recommended Practice on Monitoring Electrical Power Quality</i>  |
| ANSI/IEEE 1188 | <i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Valve-Regulated Lead-Acid (VRLA) Batteries for Stationary Applications</i> |
| IEEE 1584      | <i>IEEE Guide for Arc-Flash Hazard Calculations</i>  |
7. Insulated Cable Engineers Association – ICEA
- |                                     |   |
|-------------------------------------|---|
| ANSI/ICEA<br>S-93-639/NEMA<br>WC 74 | <i>5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy</i> |
| ANSI/ICEA<br>S-94-649               | <i>Standard for Concentric Neutral Cables Rated 5,000 - 46,000 Volts</i>                            |
| ANSI/ICEA<br>S-97-682               | <i>Standard for Utility Shielded Power Cables Rated 5,000 - 46,000 Volts</i>                        |
8. InterNational Electrical Testing Association - NETA
- |                          |   |
|--------------------------|---|
| ANSI/NETA ETT            | <i>Standard for Certification of Electrical Testing Technicians</i>                               |
| ANSI/NETA MTS<br>7.2.1.1 | <i>Standard for Electrical Maintenance Testing of Dry-Type Transformers</i>                       |
| ANSI/NETA MTS<br>7.2.1.2 | <i>Standard for Electrical Maintenance Testing of Liquid-Filled Transformers</i>                  |
| NETA MTS                 | <i>Maintenance Testing Specifications for Electrical Power Distribution Equipment and Systems</i> |
9. National Electrical Manufacturers Association - NEMA
- |                |  |
|----------------|--|
| NEMA AB4       | <i>Guidelines for Inspection and Preventive Maintenance of Molded-Case Circuit Breakers Used in Commercial and Industrial Applications</i> |
| ANSI/NEMA 84.1 | <i>Electrical Power Systems and Equipment Voltage Ratings (60 Hz)</i>  |
| NEMA MG1       | <i>Motors and Generators</i>   |
10. National Fire Protection Association - NFPA



## 2. APPLICABLE REFERENCES

### 2.1 Codes, Standards, and Specifications (*continued*)

ANSI/NFPA 70	<i>National Electrical Code</i>
ANSI/NFPA 70B	<i>Recommended Practice for Electric Equipment Maintenance</i>
ANSI/NFPA 70E	<i>Standard for Electrical Safety in the Workplace</i>
ANSI/NFPA 99	<i>Standard for Healthcare Facilities</i>
ANSI/NFPA 101	<i>Life Safety Code</i>
ANSI/NFPA 110	<i>Emergency and Standby Power Systems</i>
ANSI/NFPA 780	<i>Installation of Lightning Protection Systems</i>

11. Occupational Safety and Health Administration - OSHA
12. State and local codes and ordinances
13. Underwriters Laboratories, Inc. - UL



## **2. APPLICABLE REFERENCES**

### **2.2 Other Publications**

Manufacturer's instruction manuals for the equipment to be tested.

John C. Cadick, *Electrical Safety Handbook*, New York: McGraw Hill

Megger, *A Stitch in Time...The Complete Guide to Electrical Insulation Testing*

Paul Gill, *Electrical Power Equipment Maintenance and Testing*, New York: Marcel Dekker, Inc.

Kenneth G. Mastrullo, Ray A. Jones, Jane G. Jones, *The Electrical Safety Program Book*, NFPA

### **2.3 Contact Information**

American National Standards Institute – ANSI

25 West 43<sup>rd</sup> Street 4<sup>th</sup> Fl.

New York, NY 10036

(212) 642-4900

[www.ansi.org](http://www.ansi.org)

ASTM International – ASTM

100 Barr Harbor Drive

W. Conshohocken, PA 19428

(610) 832-9585

[www.astm.org](http://www.astm.org)

Association of Edison Illuminating Companies – AEIC

600 N. 18<sup>th</sup> Street; PO Box 2641

Birmingham, AL 35291

(205) 257-2530

[www.aeic.org](http://www.aeic.org)

Canadian Standards Association – CSA

178 Rexdale Boulevard

Toronto, ON M9W 1R3

(416) 747-4000

[www.csa.ca](http://www.csa.ca)

Electrical Apparatus Service Association – EASA

1331 Baur Boulevard

St. Louis, MO 63132

(314) 993-2220

[www.easa.com](http://www.easa.com)

Institute of Electrical and Electronic Engineers – IEEE

PO Box 1331

Piscataway, NJ 08855

(732) 981-0060

[www.ieee.org](http://www.ieee.org)



## 2. APPLICABLE REFERENCES

### 2.3 Contact Information (*continued*)

Insulated Cable Engineers Association – ICEA  
c/o Global Document Engineers  
15 Inverness Way East  
Englewood, CO 80112  
(303) 397-7956  
www.icea.net

International Electrotechnical Commission – IEC  
Contact through American National Standards Institute

InterNational Electrical Testing Association – NETA  
3050 Old Centre Avenue, Suite 102  
Portage, MI 49024  
(269) 488-6382 or (888) 300-NETA (6382)  
www.netaworld.org

Marcel Dekker, Inc.  
PO Box 5005  
Monticello, NY 12701  
(800) 228-160  
www.dekker.com

The McGraw-Hill Companies  
P.O. Box 182604  
Columbus, OH 43272  
Phone: (877) 833-5524  
www.mcgraw-hill.com

Megger  
4271 Bronze Way  
Dallas, TX 75237  
(214) 723-2861  
www.megger.com

National Electrical Manufacturers Association– NEMA  
1300 N. 17<sup>th</sup> St. Suite 1847  
Rosslyn, VA 22209  
(703) 841-3200  
www.nema.org

National Fire Protection Association – NFPA  
1 Battery March Park  
PO Box 901  
Quincy, MA 02269-9101  
(617) 984-7247  
www.nfpa.org



## **2. APPLICABLE REFERENCES**

### **2.3 Contact Information (*continued*)**

Occupational Safety and Health Administration – OSHA  
U.S. Department of Labor  
Occupational Safety and Health Administration  
Office of Public Affairs - Room N3647  
200 Constitution Avenue  
Washington, D.C. 20210  
(202) 693-1999  
[www.osha.gov](http://www.osha.gov)

The Okonite Company  
102 Hilltop Road  
Ramsey, New Jersey 07446  
(201) 825-0300 Fax 201-825-3524  
[www.okonite.com](http://www.okonite.com)

Underwriters Laboratories, Inc. – UL  
333 Pfingsten Road  
Northbrook, IL 60062  
(847) 272-8800  
[www.ul.com](http://www.ul.com)

