

ASME PTC 70-2009

Ramp Rates

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers



ASME PTC 70-2009

Ramp Rates

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



Date of Issuance: April 15, 2009

This Code will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to ASME PTC 70-2009.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Periodically certain actions of the ASME PTC Committee may be published as Code Cases. Code Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2009 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Notice	iv
Foreword	v
Committee Roster	vi
Correspondence With the PTC Committee	vii
Section 1 Object and Scope	1
1-1 Object	1
1-2 Scope	1
1-3 Expected Measurement Uncertainty	1
Section 2 Terms and Definitions	2
Section 3 Guiding Principles	4
3-1 Object of Test	4
3-2 Preparations for Testing	4
3-3 Tests	5
3-4 Instrumentation	5
3-5 Operating Conditions	6
3-6 Records	6
Section 4 Instrumentation and Methods of Measurement	7
4-1 Instrumentation Requirements	7
4-2 Test Methodology	7
Section 5 Computation of Results	9
5-1 Reported Ramp Rate	9
5-2 Determination of Ramp Rate	9
5-3 Data Reduction and Traceability	9
5-4 Graphical Presentation	9
Section 6 Test Uncertainty	10
6-1 Pretest Uncertainty Analysis	10
6-2 Post-Test Uncertainty Analysis	10
6-3 Calculating Ramp Rate Uncertainty	10
Section 7 Reporting of Results	11
7-1 Test Report Contents	11
Nonmandatory Appendices	
A Sample Uncertainty Calculation	13
B Sample Ramp Rate Data and Calculation	15

NOTICE

All Performance Test Codes must adhere to the requirements of ASME PTC 1, General Instructions. The following information is based on that document and is included here for emphasis and for the convenience of the user of the Code. It is expected that the Code user is fully cognizant of Sections 1 and 3 of ASME PTC 1 and has read them prior to applying this Code.

ASME Performance Test Codes provide test procedures that yield results of the highest level of accuracy consistent with the best engineering knowledge and practice currently available. They were developed by balanced committees representing all concerned interests and specify procedures, instrumentation, equipment-operating requirements, calculation methods, and uncertainty analysis.

When tests are run in accordance with a Code, the test results themselves, without adjustment for uncertainty, yield the best available indication of the actual performance of the tested equipment. ASME Performance Test Codes do not specify means to compare those results to contractual guarantees. Therefore, it is recommended that the parties to a commercial test agree before starting the test and preferably before signing the contract on the method to be used for comparing the test results to the contractual guarantees. It is beyond the scope of any Code to determine or interpret how such comparisons shall be made.

FOREWORD

The PTC Standards Committee approved the development of a test code on ramp rates. During their June 2007 meeting, a proposed Charter was approved, and the effort to constitute a committee was undertaken. An organizational meeting (via teleconferencing) was held in September 2007. After several teleconferences, a document was completed for industry review by the end of March 2008.

This Code was approved as a Standard practice of the Society by action of the Board on Standardization and Testing on December 8, 2008. It was also approved as an American National Standard by the ANSI Board of Standards Review on February 2, 2009.

ASME PTC COMMITTEE

Performance Test Codes

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

M. P. McHale, *Chair*
J. R. Friedman, *Vice Chair*
J. H. Karian, *Secretary*

STANDARDS COMMITTEE PERSONNEL

P. G. Albert , General Electric Co.	S. J. Korellis , EPRI
R. P. Allen , Consultant	M. P. McHale , McHale & Associates, Inc.
J. M. Burns , Burns Engineering	P. M. McHale , McHale & Associates, Inc.
W. C. Campbell , Southern Company Services	J. W. Milton , Reliant Energy
M. J. Dooley , Alstom Power	G. H. Mittendorf, Jr. , <i>Member Emeritus</i> , Virginia Military Institute
J. R. Friedman , Siemens Power Generation, Inc.	S. P. Nuspl , The Babcock & Wilcox Co.
G. J. Gerber , Consultant	R. R. Priestley , General Electric
P. M. Gerhart , University of Evansville	J. A. Rabensteine , Environmental Systems Corp.
T. C. Heil , The Babcock & Wilcox Co.	J. A. Silvaggio, Jr. , Siemens Demag Delaval
J. H. Karian , The American Society of Mechanical Engineers	W. G. Steele, Jr. , Mississippi State University
D. R. Keyser , Survice Engineering	J. C. Westcott , Mustan Corp.
	W. C. Wood , Duke Power Co.

PTC 70 COMMITTEE — RAMP RATES

S. Korellis , <i>Chair</i> , EPRI	P. M. McHale , McHale & Associates, Inc.
J. H. Karian , <i>Secretary</i> , The American Society of Mechanical Engineers	W. I. Rowen , The Turbine Engineering Consultancy
A. J. Bennett , The Babcock & Wilcox Co.	G. R. Smith , General Electric
B. M. Horton , Con Edison	T. L. Toburen , T2E3
S. A. Lefton , Aptech Engineering Services, Inc.	R. P. Wichert , U.S. Fuel Cell Council

CORRESPONDENCE WITH THE PTC COMMITTEE

General. ASME Codes are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Code may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to

Secretary, PTC Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

Proposing Revisions. Revisions are made periodically to the Code to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Code. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Code. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Code, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Code to which the proposed Case applies.

Interpretations. Upon request, the PTC Standards Committee will render an interpretation of any requirement of the Code. Interpretations can only be rendered in response to a written request sent to the Secretary of the PTC Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

Subject: Cite the applicable paragraph number(s) and the topic of the inquiry.
Edition: Cite the applicable edition of the Code for which the interpretation is being requested.
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The PTC Standards Committee regularly holds meetings, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the PTC Standards Committee.

RAMP RATES

Section 1 Object and Scope

1-1 OBJECT

This Code provides the procedures, direction, and guidance for the accurate determination, via testing, of the maximum repeatable load change ramp rate, startup load change rate, or shutdown load change rate of a power plant. The load change rate is distinguished by starting from one operating point at steady state condition and transitioning to another. Startup commences at a shutdown condition, or intermediary startup condition, and proceeds to a defined running condition. Shutdown begins at a running condition and proceeds to a shutdown condition or intermediary shutdown condition.

Measurements of actual net generation as a function of time are the primary test parameters. Additional data and information will be collected as part of this analysis to determine the long- and short-term effects of various ramp rates on the equipment and systems in the power plant of interest. This information includes and is not limited to design specifications and actual operating conditions.

1-2 SCOPE

This Code is applicable to all electrical generating facilities, independent of fuel source or prime movers.

This Code is directed at providing guidelines for measuring the machinery impact of controlled transients that are initiated by the operator. It is not the intent of this Code to address uncontrolled transients that may be initiated by system activity such as load rejection or governor response to grid frequency disturbances.

1-3 EXPECTED MEASUREMENT UNCERTAINTY

Uncertainties shall be determined utilizing techniques specified in ASME PTC 19.1. The expected uncertainties of tests completed following this Code are dependent upon the type of power plant, its size, and the test objective(s). For a simple ramp rate test from one operating load to another, resulting in an average MW/min value, uncertainties of better than 0.2% should be achievable when following this Code.