



ANSI/NEMA C80.6-2005

American National Standard for Intermediate Metal Conduit (EIMC)



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org





ANSI C80.6-2005

American National Standard

for Electrical Intermediate Metal
Conduit (EIMC)



ANSI C80.6-2005
Revision of
ANSI C80.6-1994

**American National Standard
For Electrical Intermediate Metal Conduit (EIMC)**

Secretariat:

National Electrical Manufacturers Association

Approved September 16, 2005

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209**

© Copyright 2005 by National Electrical Manufacturers Association.

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

This page intentionally left blank.

Contents

		Page
	Foreword	v
1	Scope	1
2	Normative References	1
3	Definitions	2
4	Units of Measurements	2
5	General Requirements	2
5.1	Circular cross section	2
5.2	Wall thickness	2
5.3	Interior surface	2
5.4	Welding	2
5.5	Cleaning	2
5.6	Protective coating for corrosion resistance	2
5.7	Surface treatment	2
6	Detailed Requirements	3
6.1	Exterior coating	3
6.1.1	Zinc coating	3
6.1.2	Alternative corrosion resistant coating (ACRC)	3
6.2	Interior coating	3
6.3	Threading and chamfering	3
6.4	Identification	3
6.5	Dimensions	3
6.6	Threads	3
6.7	Couplings	3
6.8	Elbows	4
7	Test Procedures	4
7.1	Bending properties	4
7.1.1	Ductility of steel	4
7.1.2	Ductility of coatings	5
7.2	Thickness of zinc coating	5
7.3	Alternate corrosion resistant coatings (ACRC)	5
7.4	Quality of organic coating for use on interior surface	5
8	Examination of Product	6
8.1	Place of inspection	6
8.2	Visual inspection of conduit	6

8.3	Retests	6
9	Markings	6
9.1	General	6
9.2	Alternate corrosion resistant coating marking.....	6
9.3	Supplementary coating marking	7

Tables

1	Dimensions of threads for intermediate metal conduit.....	7
2	Dimensions of intermediate metal conduit.....	8
3	Dimensions of couplings	9
4	Minimum acceptable dimensions of elbows and other bends	10

Figures

1	Test apparatus for bending conduit	5
2	Conduit bend.....	11

Foreword (This Foreword is not part of American National Standard C80.6-2005.)

This standard was developed by the Accredited Standards Committee on Raceways for Electrical Wiring Systems, C80. The objective of the committee is to produce a comprehensive specification that would establish uniform dimensions and standard construction requirements for Electrical Steel Metal Conduit, Electrical Metallic Tubing, Electrical Intermediate Metal Conduit and Electrical Rigid Aluminum Conduit raceway products and their associated components.

The standard was originally approved in 1986 and revised in 1994 and 2005.

Suggestions for improvement of this standard will be welcomed. They should be sent to:

National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847
Rossllyn, VA 22209.

This standard was processed and approved for submittal to ANSI by the Accredited Standards Committee on Raceways for Electrical Wiring Systems, C80. Committee approval of the standard does not necessarily imply that all committee members voted for its approval. At the time it approved this standard, the C80 Committee had the following members:

J. A. Gruber, Chairman
 J. P. Collins, Jr., Secretary

*Organization Represented:**Name of Representative:*

Aluminum Association	P. Pollak
American National Standards Institute	H. Benko
American Iron and Steel Institute	J. A. Gruber
American Iron and Steel Institute	M. J. Brett, Jr.
American Iron and Steel Institute	J. Robbins
American Pipe Fittings Association	D. Thompson
International Association of Electrical Inspectors	W. Lilly
International Brotherhood of Electrical Workers	H. Hickman
National Electrical Contractors Association	B. Stauffer
National Electrical Manufacturers Association	A. W. Ballard
National Electrical Manufacturers Association	S. Blais
National Electrical Manufacturers Association	T. McNeive
National Electrical Manufacturers Association	E. Thompson
National Electrical Manufacturers Association	J. Dodds
Steel Tube Institute	K. Carroll
Steel Tube Institute	G. Scartozzi
Underwriters Laboratories, Inc	G. Walbrecht
Unaffiliated	D. Gearing
Unaffiliated	R. Loyd
Unaffiliated	H. E. Harper, Jr.

This page intentionally left blank.

For Electrical Intermediate Metal Conduit (EIMC)—

1 Scope

This standard covers the requirements for steel electrical intermediate metal conduit for use as a raceway for wires or cables of an electrical system. Finished conduit is produced in nominal 10 ft (3.05 m) lengths, threaded on each end with one coupling attached. It is protected on the exterior surface with a metallic zinc coating or an alternate corrosion protection coating (See UL 1242 Third edition Clauses 1.3, 1.4, 16.2, 17, 18, 19, 22.6 and 22.7) and on the interior surface with a zinc or organic coating.

This standard also covers conduit couplings, elbows, and conduit lengths other than 10 ft (3.05 m).

Properly assembled systems of conduit, couplings, elbows and nipples manufactured in accordance with this standard, and other identified fittings, provide for the electrical continuity required of an equipment grounding conductor.

2 Normative References

The following standards contain provisions which, through reference in this text, constitute requirements of this American National Standard. At the time of this publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this American National Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below unless otherwise specified.

ANSI/ASME B1.20.1, *Pipe Threads, General Purpose (Inch)*

ASTM A 239 – 95(1999), *Standard Practice for Locating the thinnest Spot in a Zinc (Galvanized) Coating on Iron or Steel Articles*

ASTM B 499 – 96, *Standard Test Method for Measurement of Coating Thicknesses by the Magnetic Method: Nonmagnetic Coatings on Magnetic Basis Metals*

UL 1242, *Electrical Intermediate Metal Conduit – Steel*

3 Definitions

3.1 electrical intermediate metal conduit (EIMC): A threadable steel raceway of circular cross-section designed for the physical protection and routing of conductors and cables and for use as an equipment grounding conductor.

3.2 threaded coupling: An internally threaded steel cylinder for joining together the components of an EIMC system.

3.3 elbow: A manufactured curved section of EIMC threaded on each end.

3.4 straight conduit: A straight length of EIMC without a coupling.

3.5 finished conduit: A straight length of EIMC with one coupling attached.