

# IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications

**IEEE Power & Energy Society**

Sponsored by the  
**Stationary Batteries Committee**

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA

**IEEE Std 485™-2010**  
**(Revision of**  
**IEEE Std 485-1997)**

15 April 2011

# **IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications**

Sponsor

**Stationary Batteries Committee**

of the

**IEEE Power & Energy Society**

Approved 8 November 2010

**IEEE-SA Standards Board**

**Abstract:** Methods for defining the dc load and for sizing a lead-acid battery to supply that load for stationary battery applications in full-float operations are described in this recommended practice. Some factors relating to cell selection are provided for consideration. Installation, maintenance, qualification, testing procedures, and consideration of battery types other than lead-acid are beyond the scope of this recommended practice. Design of the dc system and sizing of the battery charger(s) are also beyond the scope of this recommended practice.

**Keywords:** battery duty cycle, cell selection, dc load, full-float operation, IEEE 485, lead-acid batteries, rated capacity, sizing, stationary applications, valve-regulated lead-acid (VRLA) cell, vented battery

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 15 April 2011. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

**PDF: ISBN 978-0-7381-6507-3 STD97052**  
**Print: ISBN 978-0-7381-6508-0 STDPD97052**

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std 485-2010, IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications.

The storage battery is of primary importance for the satisfactory operation of generating stations, substations, and other stationary applications. This recommended practice is based on commonly accepted methods used to define the load and to ensure adequate battery capacity. The method described is applicable to all installations and battery sizes.

The installations considered herein are designed for operation with a battery charger serving to maintain the battery in a charged condition as well as to supply the normal dc load. This recommended practice does not apply to “cycling” applications. (See IEEE P1660™/D9, June 2008 [B2]<sup>a</sup> subject to approval before this revision is approved.)

This recommended practice was prepared by the Lead Acid Battery Sizing Working Group of the Stationary Battery Committee. It may be used separately, but when combined with IEEE Std 450™-2002<sup>b</sup> and IEEE Std 484™-2002 (for vented lead acid batteries) or IEEE Std 1187™-2002 and IEEE Std 1188™-2005 (for valve-regulated lead-acid [VRLA] batteries), it will provide the user with a general guide to designing, placing in service, and maintaining the applicable lead-acid battery installation.

## Notice to users

### Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

### Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of

---

<sup>a</sup> The numbers in brackets correspond to those of the bibliography in Annex J.

<sup>b</sup> Information on references can be found in Clause 2.

amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

## **Errata**

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## **Interpretations**

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

## **Patents**

Attention is called to the possibility that implementation of this recommended practice may require use of subject matter covered by patent rights. By publication of this recommended practice, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this recommended practice are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this recommended practice was completed, the Lead Acid Battery Sizing Working Group had the following membership:

**Robert Fletcher, *Chair***  
**Jeff LaMarca, *Vice Chair***

Phyllis Archer	Garth Corey	Matthew McConnell
Curtis Ashton	John Coyle	James McDowall
Gary Balash	Tom Croda	Jerry Meyers
Robert Beavers	Peter Demar	Rudy Ortega
Richard Bolgeo	John Gagge, Jr.	Bansi Patel
John Byrne	Alan Jensen	Jan Reber
William Cantor	Michael Jump	Christopher Searles
Thomas Carpenter	John J. Kopera	Edward C. Stallings
Leonard Casella	Jose Marrero	Joseph Stevens
Jay Chamberlin	Tania Martinez Navedo	Lesley Varga
Mark Clark	Stephen McCluer	Allan Williamson

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman	Gary Engmann	Arthur Neubauer
Satish Aggarwal	Wells Fargo	Michael S. Newman
Samuel Aguirre	Robert Fletcher	Howard Nudi
Steven Alexanderson	James Graham	Chris Osterloh
James Anderson	Randall Groves	Bansi Patel
Phyllis Archer	Hamidreza Heidarisaifa	John Polenz
Stan Arnot	Scott Hietpas	Percy Pool
Gary Arntson	Gary Hoffman	Edward Rafter
Curtis Ashton	David Horvath	Michael Roberts
Gary Balash	James Houston	Charles Rogers
Farouk Baxter	Randy Jamison	Gregg Sauer
Robert Beavers	Wayne Johnson	Bartien Sayogo
Steven Bezner	James Jones	Robert Schuerger
Thomas Blair	John J. Kopera	David Smith
William Bloethe	David Krause	James Smith
Richard Bolgeo	Jim Kulchisky	Allan St. Peter
Mark Bowman	Saumen Kundu	Joseph Stevens
Steven Brockschink	Chung-Yiu Lam	William W. Terry
William Cantor	Daniel Lambert	Malcolm Thaden
Leonard Casella	Thomas LaRose	S. Thamilarasan
Jay Chamberlin	Daniel Levin	Wayne Timm
Keith Chow	Debra Longtin	Lesley Varga
Mark Clark	Keith Malmedal	Stephen Vechy
Randy Clelland	William McBride	John Vergis
Garth Corey	Stephen McCluer	Kenneth White
Charles Cotton	James McDowall	Allan Williamson
John Coyle	John Merando	Larry Yonce
Jesus De Leon Diaz	Kimberly Mosley	Luis Zambrano
Donald Dunn	Haissam Nasrat	Ahmed Zobaa

When the IEEE-SA Standards Board approved this recommended practice on 8 November 2010, it had the following membership:

**Robert M. Grow**, *Chair*  
**Richard H. Hulett**, *Vice Chair*  
**Steve M. Mills**, *Past Chair*  
**Judith Gorman**, *Secretary*

Karen Bartleson  
Victor Berman  
Ted Burse  
Clint Chaplin  
Andy Drozd  
Alexander Gelman  
Jim Hughes

Young Kyun Kim  
Joseph L. Koepfinger\*  
John Kulick  
David J. Law  
Hung Ling  
Oleg Logvinov  
Ted Olsen

Ronald C. Petersen  
Thomas Prevost  
Jon Walter Rosdahl  
Sam Sciacca  
Mike Seavey  
Curtis Siller  
Don Wright

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Michael Janezic, *NIST Representative*

Don Messina  
*IEEE Standards Program Manager, Document Development*

Soo H. Kim  
*IEEE Standards Program Manager, Technical Program Development*

## Contents

1. Overview .....	1
1.1 Scope .....	1
2. Normative references.....	1
3. Definitions .....	2
4. Defining loads .....	2
4.1 General considerations.....	2
4.2 Load classification.....	3
4.3 Duty cycle diagram.....	4
5. Cell selection .....	5
6. Determining battery size.....	6
6.1 Number of cells .....	6
6.2 Additional considerations .....	7
6.3 Cell size .....	10
6.4 Cell sizing worksheet.....	12
7. Cell voltage/time profile calculation .....	13
Annex A (informative) Battery and cell sizing examples.....	15
Annex B (informative) Converting constant power and resistance loads to constant current .....	21
Annex C (informative) Calculating cell voltage during discharge .....	23
Annex D (informative) Consideration of cell types.....	31
Annex E (informative) Constant power sizing .....	32
Annex F (informative) Development and use of battery discharge curves.....	39
Annex G (informative) Random loads .....	50
Annex H (informative) Capacity variation during life .....	56
Annex I (informative) Full-size worksheet.....	57
Annex J (informative) Bibliography.....	59

# IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications

**IMPORTANT NOTICE:** *This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

### 1.1 Scope

Methods for defining the dc load and for sizing a lead-acid battery to supply that load for stationary battery applications in full float operations are described. Some factors relating to cell selection are provided for consideration. Installation, maintenance, qualification, testing procedures, and consideration of battery types other than lead acid are beyond the scope of this recommended practice. The design of the dc system and sizing of the battery charger(s) are also beyond the scope of this recommended practice.

## 2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated referenced, the latest edition of the referenced document (including any amendments or corrigenda) applies.

IEEE Std 450™-2002, IEEE Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications.<sup>1,2</sup>

---

<sup>1</sup> This publication is available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854, USA (<http://standards.ieee.org/>).

<sup>2</sup> The IEEE standards or products referred to in this clause are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.

IEEE Std 484™-2002, IEEE Recommended Practice for Installation Design and Installation of Vented Lead-Acid Batteries for Stationary Applications.

IEEE Std 1184™-2006, IEEE Guide for Batteries for Uninterruptible Power Supply Systems.

IEEE Std 1187™-2002 IEEE Recommended Practice for Installation Design and Installation of Valve-Regulated Lead-Acid Storage Batteries for Stationary Applications.

IEEE Std 1188™-2005, IEEE Recommended Practice for Maintenance, Testing, and Replacement of Valve-Regulated Lead-Acid (VRLA) Batteries for Stationary Applications.

### 3. Definitions

For the purposes of this document, the following terms and definitions apply. *The IEEE Standards Dictionary: Glossary of Terms & Definitions* should be consulted for terms not defined in this clause.<sup>3</sup>

**battery duty cycle:** The sequence of loads a battery is expected to supply for specified time periods.

**cell size:** The rated capacity of a cell or the number of positive plates in a cell.

**equalizing charge:** A charge, at a level higher than the normal float voltage, applied for a limited period of time, to correct inequalities of voltage, specific gravity, or state of charge that may have developed between the cells during service.

**full-float operation (float service):** Operation of a direct current (dc) system in which the battery spends the majority of the time on float charge with infrequent discharge. (The primary source of power is normally the battery charger or rectifier.)

**period:** An interval of time in the battery duty cycle during which the current (or power) is assumed to be constant for purposes of cell sizing calculations.

**rated capacity (lead-acid):** The capacity assigned to a cell by its manufacturer for a given discharge rate, at a specified electrolyte temperature and specific gravity, to a given end-of-discharge voltage.

**valve-regulated lead-acid (VRLA) cell:** A lead-acid cell that is sealed with the exception of a valve that opens to the atmosphere when the internal pressure in the cell exceeds atmospheric pressure by a preselected amount. VRLA cells provide a means for recombination of internally generated oxygen and the suppression of hydrogen gas evolution to limit water consumption.

**vented battery:** A battery in which the products of electrolysis and evaporation are allowed to escape to the atmosphere as they are generated. These batteries are also commonly referred to as “flooded.”

## 4. Defining loads

### 4.1 General considerations

The duty cycle imposed on the battery by any of the conditions described herein will depend on the dc system design and the requirements of the installation. The battery must supply the dc power requirements when the following conditions occur:

---

<sup>3</sup> *The IEEE Standards Dictionary: Glossary of Terms & Definitions* is available at <http://shop.ieee.org/>.