

ASME MFC-26–2011

Measurement of Gas Flow by Bellmouth Inlet Flowmeters

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

INTENTIONALLY LEFT BLANK

ASME MFC-26-2011

Measurement of Gas Flow by Bellmouth Inlet Flowmeters

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Three Park Avenue • New York, NY • 10016 USA

Date of Issuance: August 10, 2011

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME MFC Committee may be published as Cases. Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not approve, rate, or endorse any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2011 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword		iv
Committee Roster		v
Correspondence With the MFC Committee		vi
1	General	1
2	References	1
3	Definitions and Symbols	2
4	Principle of Measurement and Method of Computation	3
5	Flow Conditioning	11
6	General Requirements	12
7	Discharge Coefficient Development	14
8	Uncertainties in the Measurement of Flow Rate	16
Figures		
4.1-1	Bellmouth Inlet Flow Nozzle — General Description (Side View)	6
4.1-2	Bellmouth Inlet Flow Nozzle — General Description (Front View)	6
4.3-1	Clean Inlet Method	8
4.3-2	Combo Probe: P_t and P_s Method	9
4.3-3	Combo Probe: P_t and T_t Method	10
5.2-1	Typical Boundary Layer Growth, Flat Plate Model	12
7.3-1	Inlet Instrumentation (Technique From Para. 4.3.1)	15
Table		
3.3-1	Symbols	4
Nonmandatory Appendices		
A	Sample Calculation Equation Set	19
B	Example of Empirically Derived Sensitivity	20
C	Derivation of Sample Equation	21
D	References for Additional Reading	25

FOREWORD

The bellmouth is a common device for flow conditioning and flow measurement in the aerospace industry. Specifically, the bellmouth is attached to the front end of a turbofan gas turbine engine. Turboshift engine applications also use the bellmouth but typically for flow conditioning and less frequently for flow measurement. The automotive industry also uses the bellmouth in some test applications. This Standard was prepared by Subcommittee 26, Bellmouth Inlet Flowmeters, of the ASME Standards Committee on Measurement of Fluids in Closed Conduits (MFC).

This is the initial release of this Standard.

This Standard provides information in both SI (metric) units and U.S. Customary units.

Suggestions for improvement of this Standard are welcome. They should be sent to The American Society of Mechanical Engineers; Secretary, MFC Standards Committee; Three Park Avenue; New York, NY 10016-5990.

This Standard was approved by the American National Standards Institute on March 30, 2011.

ASME MFC COMMITTEE MEASUREMENT OF FLUID FLOW IN CLOSED CONDUITS

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

R. J. DeBoom, *Chair*
Z. D. Husain, *Vice Chair*
D. C. Wyatt, *Vice Chair*
C. J. Gomez, *Secretary*

STANDARDS COMMITTEE PERSONNEL

C. J. Blechinger, <i>Honorary Member</i> , Consultant	G. E. Mattingly, The Catholic University of America
R. M. Bough, Rolls-Royce Corp.	R. W. Miller, <i>Honorary Member</i> , R. W. Miller & Associates, Inc.
M. S. Carter, Flow Systems, Inc.	A. Quraishi, American Gas Association
G. P. Corpron, <i>Honorary Member</i> , Consultant	W. Seidl, Colorado Engineering Experiment Station, Inc.
R. J. DeBoom, Consultant	D. W. Spitzer, <i>Contributing Member</i> , Spitzer and Boyes, LLC
D. Faber, <i>Contributing Member</i> , Badger Meter, Inc.	R. N. Steven, Colorado Engineering Experiment Station, Inc.
C. J. Gomez, The American Society of Mechanical Engineers	T. M. Kegel, <i>Alternate</i> , Colorado Engineering Experiment Station, Inc.
F. D. Goodson, Emerson Process Management, Daniel Division	J. H. Vignos, <i>Honorary Member</i> , Consultant
Z. D. Husain, Chevron Corp.	D. E. Wiklund, Emerson Process Management, Rosemount Division
C. G. Langford, <i>Honorary Member</i> , Consultant	J. D. Wright, <i>Contributing Member</i> , NIST
T. O. Maginnis, Consultant	D. C. Wyatt, Wyatt Engineering
W. M. Mattar, Invensys/Foxboro Co.	

SUBCOMMITTEE 26 — BELLMOUTH INLET FLOWMETERS

R. M. Bough, <i>Chair</i> , Rolls-Royce Corp.	W. Seidl, Colorado Engineering Experiment Station, Inc.
R. J. DeBoom, Consultant	D. C. Wyatt, Wyatt Engineering
Z. D. Husain, Chevron Corp.	

CORRESPONDENCE WITH THE MFC COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending committee meetings. Correspondence should be addressed to:

Secretary, MFC Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the standard, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the standard to which the proposed Case applies.

Interpretations. Upon request, the MFC Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the MFC Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

- Subject:** Cite the applicable paragraph number(s) and the topic of the inquiry.
- Edition:** Cite the applicable edition of the Standard for which the interpretation is being requested.
- Question:** Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The MFC Committee regularly holds meetings, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the MFC Standards Committee.

MEASUREMENT OF GAS FLOW BY BELLMOUTH INLET FLOWMETERS

1 GENERAL

1.1 Scope

This Standard applies only to the steady flow of single-phase gases and gas mixtures and applies only to bellmouth inlet flowmeters in which the flow remains subsonic throughout the measuring section and the flow is steady or varies only slowly with time. It also addresses procedures by which calibration of the device can be made to allow for application with consistent conclusions and within known limits of uncertainty.

Bellmouth inlet flowmeters should be used only within the limits for which a given unit is tested, or if additional uncertainty can be tolerated, over a range within which extrapolation is reliable.

This Standard outlines the general geometry and method of use of bellmouth inlet flowmeters to determine the mass or volumetric flow rate of the gas or gas mixture flowing through the device. It also gives necessary information for calculating the flow rate and its associated uncertainty.

A bellmouth inlet flowmeter is a device that provides flow conditioning and flow measurement whose inlet is located or positioned in a large reservoir or supply source. The reservoir can be outside ambient, room, or plenum conditions depending on the application. The bellmouth inlet flowmeter is also referred to as an airbell, nozzle with zero beta ratio, borda tube, etc. Typical geometry consists of a convergent inlet followed by a constant throat area. This flowmeter is a differential pressure type device that allows determination of the flow rate from the differential pressure between the total pressure and static pressure at a single specified axial location in the constant area throat of the bellmouth.

1.2 Purpose

The purpose of this Standard is to provide guidance and recommendations for fluid flow measurement of gaseous applications using the bellmouth inlet flowmeter.

This Standard addresses the following:

- (a) principle of operation
- (b) design parameters and considerations
- (c) calibration methods and procedures
- (d) instrumentation and calculation methods
- (e) installation requirements and considerations
- (f) measurement uncertainty

1.3 Field of Application

The bellmouth inlet flowmeter is a common device that both conditions the flow and measures its rate and is widely used in the aerospace industry. Specifically, the discharge of the bellmouth flowmeter is often attached to the front end of a test article such as a turbofan gas turbine engine. Turbohaft engine applications also use the bellmouth but typically for flow conditioning and less frequently for flow measurement. The automotive industry also uses the bellmouth in some test applications.

2 REFERENCES

The following documents form a part of this Standard to the extent specified herein. Unless otherwise specified, the latest edition shall apply.

ASME Fluid Meters, 6th Edition, 1971

ASME MFC-1M, Glossary of Terms Used in the Measurement of Fluid Flow in Pipes

ASME MFC-3M, Measurement of Fluid Flow in Pipes Using Orifice, Nozzle, and Venturi

ASME PTC 19.5, Flow Measurement

Publisher: The American Society of Mechanical Engineers (ASME), Three Park Avenue, New York, NY 10016-5990; Order Department: 22 Law Drive, P.O. Box 2900, Fairfield, NJ 07007-2900 (www.asme.org)

ISO 5167, Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full

Publisher: International Organization for Standardization (ISO), Central Secretariat, 1, ch. de la Voie-Creuse, Case postale 56, CH-1211 Geneva 20, Switzerland (www.iso.org)