



BSI Standards Publication

PUBLISHED DOCUMENT

Application of fire safety engineering principles to the design of buildings

Part 3: Structural response and fire spread beyond the enclosure of origin

This publication is not to be regarded as a British Standard.

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© BSI 2011

ISBN 978 0 580 60070 8

ICS 13.220.20; 91.040.01

The following BSI reference relates to the work on this

Published Document:

Committee reference FSH/24

Publication history

First published January 2003

Second (present) edition, November 2011

Amendments issued since publication date

Text affected

Contents

Foreword	<i>vii</i>
Introduction	1
1	Scope 2
2	Normative references 4
3	Terms and definitions 6
4	Symbols and abbreviated terms 9
5	Interaction of BS 7974 sub-systems 11
6	Design approach to PD 7974-3 16
7	Analysis of mechanisms of fire spread 32
8	Characterization of the fire enclosure and openings 45
9	Characterization of the fire conditions 52
10	Analysis of thermal response 65
11	Behaviour of separating elements in fire 92
12	Analysis of mechanical response of loadbearing structural elements and frames 136

Annexes

Annex A (informative)	Temperature-dependent properties of construction materials 175
Annex B (informative)	Temperature-dependent properties of non-loadbearing construction systems – Thermal properties of materials used in composite sandwich panels 238
Annex C (informative)	Fire resistant load bearing structural solutions 244
Annex D	Methodology for establishing the extended application of fire resistance test results 246
Bibliography	254

List of figures

Figure 1 – Overview of the PD 7974 series of Published Documents	3
Figure 2 – Inter-relationship between PD 7974-3 and the other sub-systems	12
Figure 3 – Methodology for interaction of all sub-systems in the PD 7974 series	17
Figure 4 – Interaction between the various professionals as part of the process in delivering a successful fire strategy	19
Figure 5 – Interaction between the various professions and the design team in addressing PD 7974-3 factors	20
Figure 6 – Routes for fire transmission	24
Figure 7 – Procedure for quantitative analysis within PD 7974-3	29
Figure 8 – Potential outputs that can be obtained from various analysis methods	34
Figure 9 – Configuration factors for typical scenarios	43
Figure 10 – Nomogram for modification factor for ventilation	51
Figure 11 – Nominal standard fire curves	56
Figure 12a) – Time-temperature curves, at depths shown from surface for 1:2:4 Portland cement concrete with ham river sand and gravel aggregate – heated 2 hours	69
Figure 12b) – Time-isotherms and colour changes for 1:2:4 Portland cement concrete with ham river sand and gravel aggregate – heated 2 hours	70
Figure 13 – Temperature distribution in slabs exposed to the standard fire on one side	72
Figure 14 – Temperature profiles at distances from the surface (mm) for a 300 mm × 300 mm concrete column for various fire resistance periods	72

- Figure 15 – Calculation of section factors 75
- Figure 16 – Calculation of element factors 77
- Figure 17 – Typical set of board thicknesses for a box encasement fire protection system 79
- Figure 18 – Compartment parameters 82
- Figure 19 – Spandrel beam with shielded flanges 83
- Figure 20 – Calculation methods for determining the temperature profiles through masonry elements 87
- Figure 21 – Temperature gradient through autoclaved concrete masonry with a density of 400 kg/m^3 to 800 kg/m^3 88
- Figure 22 – Typical detail showing protection to a floor beam with a service penetration 129
- Figure 23 – General approach to structural fire safety design 141
- Figure 24 – Design methods for fire limit state (FLS) design adopted in BS EN 1992-1-2 146
- Figure 25 – Principle design methodologies adopted in BS EN 1993-1-2 148
- Figure 26A – Definition of residual cross-section and effective cross-section 155
- Figure 26B – Relationship between k_0 and time of fire exposure for unprotected surfaces, and for protected surfaces where $t_{ch} \leq 20 \text{ min}$ 156
- Figure 26C – Relationship between k_0 and time of fire exposure for protected surfaces where $t_{ch} > 20 \text{ min}$ 156
- Figure 27 – Equations 85 to 87 illustrated 157
- Figure 28 – Vertical section on masonry (adapted from BS EN 1996-1-2:2005, Figure C.2) 162
- Figure 29 – Typical examples of concrete floor slabs with profiled steel sheets with or without reinforcing bars (BS EN 1994-1-2) 166
- Figure 30 – Examples of composite floor beams (BS EN 1994-1-2) 167
- Figure 31 – Examples of composite columns (BS EN 1994-1-2) 168
- Figure 32 – Schematic representation of the compressive and tensile forces of a floor zone during fire 170
- Figure 33 – Illustration of the deflection of a multi-zone composite floor system with protected and unprotected members 171
- Figure 34 – Illustration of catenary action developed in a multi-zone composite floor system 172
- Figure A.1 – Variation in thermal strain with temperature for siliceous and calcareous concrete 176
- Figure A.2 – Variation of specific heat with temperature for normal weight concrete (NC) and lightweight concrete (LC) as a function of temperature 177
- Figure A.3 – Variation of thermal conductivity of concrete with temperature 178
- Figure A.4 – Mathematical model for stress-strain relationships under compression at elevated temperatures (see BS EN 1992-1-2:2004, Figure 3.1) 181
- Figure A.5 – Variation in coefficient $k_c(\theta)$ for describing the characteristic strength, $f_{c,k}$, for siliceous and calcareous aggregates at elevated temperatures (see BS EN 1992-1-2:2004, Figure 4.1) 182
- Figure A.6 – Stress-strain relationships for normal weight siliceous concrete at elevated temperatures (see BS EN 1994-1-2:2005, Figure B.1) 183
- Figure A.7 – Stress-strain curves allowing for cooling of a grade 40/50 concrete (see BS EN 1994-1-2:2005, Figure C.2) 184

- Figure A.8 – Coefficient $k_{c,t}(\theta)$ allowing for decrease of tensile strength ($f_{ck,t}$) of concrete at elevated temperatures (see BS EN 1992-1-2:2004, Figure 3.2) 185
- Figure A.9 – Reduction of strength at elevated temperature 187
- Figure A.10 – Thermal elongation of carbon steel as a function of the temperature 189
- Figure A.11 – Thermal elongation of austenitic stainless steel as a function of temperature 190
- Figure A.12 – Specific heat of carbon steels as a function of temperature 191
- Figure A.13 – Specific heat of stainless steels as a function of temperature 192
- Figure A.14 – Thermal conductivity of carbon steel as a function of temperature 193
- Figure A.15 – Thermal conductivity of stainless steel as a function of temperature 193
- Figure A.16 – Determination of heated perimeter (H_p) for various configurations of unprotected steel 195
- Figure A.17 – Determination of H_p for various configurations of protected steel members 196
- Figure A.18 – Stress-strain relationships for hot finished, structural steel at elevated temperatures (see BS EN 1993-1-2:2005, Figure 3.1) 197
- Figure A.19 – Graphical presentation of the stress-strain relationships of hot rolled structural steel at elevated temperatures, with strain-hardening included (see BS EN 1994-1-2:2005, Figure A.2) 199
- Figure A.20 – Alternative stress-strain relationship for steel allowing for strain-hardening (see BS EN 1993-1-2:2005, Figure A.1) 200
- Figure A.21 – Reference curves for critical temperature of reinforcing and pre-stressing steels 206
- Figure A.22 – Reduction factors for the stress-strain relationship of cold formed and hot rolled thin walled steel at elevated temperatures 207
- Figure A.23 – Strength reduction factors (SRF) for grade 8.8 bolts in shear and tension at elevated temperatures 208
- Figure A.24 – Strength reduction factors for fillet welds at elevated temperatures 210
- Figure A.25 – Stress-strain model for stainless steel at elevated temperatures 211
- Figure A.26 – Relationship between charring rate and time 222
- Figure A.27 – Variation in specific heat of softwood and charcoal 224
- Figure A.28 – Temperature-density ratio relationship for softwood with an initial moisture content of 12% 224
- Figure A.29 – Variation in thermal conductivity with temperature for wood and charcoal 225
- Figure A.30 – Reduction factor for strength parallel to the grain for softwood 226
- Figure A.31 – Effect of temperature on the elastic modulus of softwood parallel to the grain 226
- Figure A.32 – Calculation values of thermal strain ε_T of clay units with unit strength 12 N/mm² to 20 N/mm² and units with a density range of 900 kg/m³ to 1 200 kg/m³ 227
- Figure A.33 – Calculation values of thermal strain ε_T of calcium silicate units with unit strength 12 N/mm² to 20 N/mm² and a density range of 1 600 kg/m³ to 2 000 kg/m³ 228

- Figure A.34 – Calculation values of thermal strain ε_T of lightweight aggregate concrete units (pumice) with unit strength 4 N/mm² to 6 N/mm² and a density range of 600 kg/m³ to 1 000 kg/m³ 228
- Figure A.35 – Calculation values of temperature-dependant material properties of autoclaved aerated concrete units with a density range of 400 kg/m³ to 600 kg/m³ 229
- Figure A.36 – Calculation values of temperature-dependant material properties of clay units with a density range of 900 kg/m³ to 1 200 kg/m³ 229
- Figure A.37 – Calculation values of temperature-dependant material properties of lightweight aggregate concrete units (pumice) with a density range of 600 kg/m³ to 1 000 kg/m³ 230
- Figure A.38 – Calculation values of temperature-dependant material properties of calcium silicate units with a density range of 1 600 kg/m³ to 2 000 kg/m³ 230
- Figure A.39 – Calculation values of temperature-dependant stress-strain diagrams of clay units with unit strength of 12 N/mm² to 20 N/mm² and a density range of 900 kg/m³ to 1 200 kg/m³ 231
- Figure A.40 – Calculation values of temperature dependent stress-strain curves of calcium silicate units with strength of 12 N/mm² to 20 N/mm² and a density range of 1 600 kg/m³ to 2 000 kg/m³ 232
- Figure A.41 – Calculation values of temperature-dependent stress-strain curves of lightweight aggregate concrete units (pumice) with strength of 4 N/mm² to 6 N/mm² and a density range of 600 kg/m³ to 1 000 kg/m³ 232
- Figure A.42 – Flexural strength of glass polyester at elevated temperatures 237
- Figure B.1 – Thermal conductivity for various densities of mineral (rock) wool at elevated temperatures 240

List of tables

- Table 1 – Overview of means of analysis for each fire spread mechanism 33
- Table 2 – Flash-ignition temperatures 41
- Table 3 – Maximum permitted radiation dose to building occupants 44
- Table 4 – Values of k_b 58
- Table 5 – Notional radiation levels from openings in enclosures 63
- Table 6 – Effect of automatic sprinklers on expected fire conditions 64
- Table 7 – Guidance on the material surface emissivity of construction materials 67
- Table 8 – Calculation of element factors (EF) 76
- Table 9 – Typical set of coating thicknesses for a profile spray-applied protection system 78
- Table 10 – Location of columns between windows to avoid direct flame impingement 82
- Table 11 – Spandrel beams 83
- Table 12 – Recommended fire protection thickness to compensate for deficiencies in concrete thickness/reinforcement cover 96
- Table 13 – Notional period of fire endurance for which imperforate condition can be assumed for unproven elements subject to fire exposure 135
- Table 14 – Partial safety factors for loads (illustrative) 137
- Table 15 – Notional char depths for various species after 30 min and 60 min in the standard furnace test (BS 476-20) 153
- Table 16 – Values of k_{fi} for different components/elements 154
- Table 16A – Determination of k_0 156

- Table 17 – Minimum thickness requirements for dense and lightweight aggregate masonry, single-leaf, loadbearing walls (extracted from NA to BS EN 1996-1-2:2005, Table NA.3.2) 159
- Table 18 – Values of constant, c , and temperatures θ_1 and θ_2 by masonry material – (extracted from BS EN 1996-1-2:2005, Figure C.2) 162
- Table A.1 – Values for the main parameters of the stress-strain relationships of normal weight concrete with siliceous or calcareous aggregates (see BS EN 1992-1-2:2004, Table 3.1) 182
- Table A.2 – Values for the two main parameters of the stress-strain relationship – lightweight concrete at elevated temperatures 185
- Table A.3 – Reduction of strength at elevated temperature 186
- Table A.4 – Density of stainless steel at elevated temperatures 194
- Table A.5 – Mathematical formulations of stress-strain relationships for hot finished structural steel at elevated temperatures (see BS EN 1993-1-2:2005, Figure 3.1) 198
- Table A.6 – Reduction factors k_θ for stress-strain relationships of structural steel at elevated temperatures (see BS EN 1994-1-2:2005, Table 3.2) 199
- Table A.7 – Strength reduction factor for structural steel grades 275 and 355 to BS EN 10025-1 and BS EN 10025-2 201
- Table A.8 – Elevated temperature stress-strain data for grade 275 structural steel 202
- Table A.9 – Elevated temperature stress-strain data for grade 355 structural steel 203
- Table A.10 – Values for the three main parameters ($E_{a,\theta}; f_{ap,\theta}; f_{a,\theta}$) of the stress-strain relationships for cold worked reinforcing steel 204
- Table A.11 – Values for the parameters of the stress-strain relationship of cold worked (cw) (wires and strands) and quenched and tempered (q & t) (bars) pre-stressing steel at elevated temperatures (see BS EN 1992-1-2:2004, Table 3.3) 205
- Table A.12 – Strength reduction factor for cold formed galvanized steel to BS EN 10147 206
- Table A.13 – Reduction factors for carbon steel for the design of class 4 sections at elevated temperatures 207
- Table A.14 – Strength reduction factors for grade 8.8 bolts in shear and tension 208
- Table A.15 – Strength reduction factors for butt welds 209
- Table A.16 – Strength reduction factors for fillet welds at elevated temperatures (see BS EN 1993-1-2:2005, Table D.1) 210
- Table A.17 – Stress-strain parameters for stainless steel 211
- Table A.18 – Factors for determination of strain and stiffness of stainless steel at elevated temperatures 213
- Table A.19 – Reduction factor and ultimate strain for the use of advanced calculation methods 215
- Table A.20 – Elastic modulus of aluminium alloys at elevated temperatures 218
- Table A.21 – 0.2% proof stress ratios, $k_{0.2,\theta}$ for aluminium alloys at elevated temperatures for up to 2 hours thermal exposure period 219
- Table A.22 – Design charring rates for timber, LVL, wood based panels and panelling 220
- Table A.23 – Variation of specific heat capacity and density ratio of softwood at elevated temperatures 223
- Table A.24 – Variation of thermal conductivity with temperature 225
- Table A.25 – Thermal properties of common types of glass 233
- Table A.26 – Mechanical properties of some common glasses 233

Table A.27 – Thermal properties of some common plastics	235
Table A.28 – Mechanical properties of some plastics	236
Table A.29 – Mechanical properties of some typical resins	237
Table A.30 – Mechanical properties of several types of fibre reinforcement	238
Table A.31 – Strength properties of polyester laminates at elevated temperatures	238
Table B.1 – Comparison of expansion of materials used in composite sandwich panels	239
Table B.2 – Comparison of specific heat capacity of materials used in composite sandwich panels	239
Table B.3 – Thermal conductivity for various densities of mineral (rock) wool at elevated temperatures	240
Table B.4 – Constants for calculating the thermal conductivity of mineral wool at elevated temperatures	241
Table B.5 – Thermal conductivity of cellular glass	241
Table B.6 – Thermal conductivity of expanded polystyrene	241
Table B.7 – Thermal conductivity of extruded polystyrene	242
Table B.8 – Thermal conductivity of phenolic foam	242
Table B.9 – Thermal conductivity of polyisocyanate foam	242
Table B.10 – Thermal conductivity of rigid polyurethane foam	242
Table B.11 – Thermal conductivity through the cell gas for various blowing gases	243
Table B.12 – Typical densities of core materials used in sandwich panels	243

Summary of pages

This document comprises a front cover, an inside front cover, pages i to viii, pages 1 to 258, an inside back cover and a back cover.

Foreword

Publishing information

This Published Document is published by BSI and came into effect on 30 November 2011. It was prepared by Technical Committee FSH/24, *Fire Safety Engineering*. A list of organizations represented on this committee can be obtained on request to its secretary.

Supersession

This Published Document supersedes PD 7474-3:2003, which is withdrawn.

Information about this document

This Published Document (PD) is one of a series of documents published under the Fire Standards Policy Committee, and is a supporting document to BS 7974, *Code of Practice on the Application of Fire Safety Engineering Principles to the Design of Buildings*. Other documents in the series are:

PD 7974-0: *Guide to design framework and fire safety engineering procedures;*

PD 7974-1: *Initiation and development of fire within the enclosure of origin;*

PD 7974-2: *Spread of smoke and toxic gases within and beyond the enclosure of origin;*

PD 7974-4: *Detection of fire and activation of fire suppression systems;*

PD 7974-5: *Fire service intervention;*

PD 7974-6: *Evacuation;*

PD 7974-7: *Probabilistic risk assessment.*

Presentational conventions

The provisions of this Published Document are presented in roman (i.e. upright) type. Its recommendations are expressed in sentences in which the principal auxiliary verb is "should".

Commentary, explanation and general informative material is presented in smaller, italic type, and does not constitute a normative element.

Contractual and legal considerations

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a Published Document cannot confer immunity from legal obligations.

Introduction

This Published Document is one of a series of documents intended to support BS 7974, *Code of Practice on the Application of Fire Safety Engineering Principles to the Design of Buildings*.

This and the other Published Documents (PDs) contain “state of the art” guidance and information on how to undertake quantitative and detailed analysis of specific aspects of design. It is intended that they be updated as new theories, calculation methods and/or data become available.

However, it is important to recognize that the information contained within PD 7974-3 does not preclude data, information or methods of analyses from other sources, such as published peer reviewed research, manufacturers’ data or codes of practice prepared on behalf of the construction materials industry, professional engineering and technical institutions and other professional bodies.

BS 7974 was first published in 2001. Since then there have been substantial changes in understanding in the behaviour of fire in the built environment and how materials and construction systems respond at elevated temperatures. Not least, the structural Eurocodes on Fire Actions have been published as full European Standards. These have resulted in revised formulations on the behaviour of structural components in fire, as well as new data on the thermal and mechanical properties of the various materials used in building construction. One of the most significant and recent advances in the understanding of buildings in fire has come about as a result of studies of experimental major fires in full size structures and the ensuing guidance this has generated on analysing the structural behaviour of the framework and compartmentation.

However, where understanding the behaviour of construction systems and building products cannot be quantified, or there are no specific analyses of some aspects of fire spread beyond the enclosure of origin other than the performance of products based upon a fire resistance furnace test, a commentary is given on the particular issues that need to be considered and how these could be treated.

A fire-safety engineering approach that takes into account the total fire safety package can provide a more economical solution than prescriptive approaches to fire safety. In some cases, it is the only viable means of achieving a satisfactory standard of fire safety in some large and complex buildings.

A major issue in the determination of the structural response is the application of time equivalent methods in specifying an equivalent period of heating in the standard fire resistance test furnace. Any outputs should consider the consequences of failure in relation to the particular occupancy and building dimensions (height and compartment size) and its location in the building, for example, BS 9999 specifies a risk-based approach for occupant life safety in building structures.

Fire safety engineering has many benefits. The use of BS 7974 facilitates the practice of fire safety engineering and, in particular:

- a) provides the designer with an organized approach to fire safety design;
- b) allows the safety levels for alternative fire safety designs to be compared;

- c) provides a basis for selection of appropriate fire protection systems;
- d) provides opportunities for innovative design; and
- e) provides information on the management of fire safety for a building.

Fire is an extremely complex phenomenon and there are still gaps in the available knowledge. When used by suitably qualified persons experienced in fire safety engineering, BS 7974 and its associated PDs provide a means of establishing acceptable levels of fire safety economically, without impeding building design.

For the purpose of this Published Document, spread of fire beyond the enclosure of origin is deemed to have taken place when any material outside of the fire enclosure ignites or suffers thermal degradation. Structural response is the interaction of loadbearing and non-loadbearing elements or frames as a result of thermal and/or mechanical actions due directly or indirectly to a fire. The level of sophistication employed to evaluate fire spread can vary. For example, a simple decision can be taken that the creation of any openings or gaps in the enclosure boundaries precipitates fire spread. Alternatively, more complex analyses can be employed to consider whether flames project from openings in the enclosure's boundaries and whether such flames ignite or degrade materials outside the enclosure.

Throughout PD 7974-3 reference is made to relevant codes of practice. Where appropriate, relevant extracts are provided in order to assist the reader in understanding the design methodologies presented and to compare and contrast between different approaches or sources of data. It is therefore important that PD 7974-3 is not used in isolation and reference is made to the relevant codes of practice, particularly in relation to additional notes and sub-clauses describing its application (see Figure 1).

1 Scope

This Published Document provides a framework for developing a rational methodology for design using a fire safety engineering approach through the application of scientific and engineering principles to the protection of people, property and the environment from fire. The Published Document considers the following issues:

- a) the conditions within a fire enclosure and their potential to cause fire spread;
- b) the thermal and mechanical response of the enclosure boundaries and its structure to the fire conditions;
- c) the impact of the anticipated thermal and mechanical responses on adjacent enclosures and spaces;
- d) the structural responses of loadbearing elements and their effect on structural stability, load transfer and acceptable damage according to the design and purpose of the building;
- e) fire following structural impact to the building.