



ASA/ANSI S12.58-2012

Reaffirmed by ANSI January 17, 2019

AMERICAN NATIONAL STANDARD

Sound Power Level Determination for Sources Using a Single-source Position

Secretariat:

Acoustical Society of America

Approved on August 23, 2012:

American National Standards Institute, Inc.

Abstract

This American National Standard describes a method for the determination of sound power levels of noise sources that emit broadband sound and/or discrete frequency sounds/tones using reverberation rooms. The standard applies when it is either undesirable or unfeasible to move the source to decrease the uncertainty of the measurement. The method described requires reverberation room pre-qualification through test and requires the use of the comparison method to determine sound power levels. This standard specifies the physical environment, procedures, and equipment used to qualify the reverberation room by test. Pre-qualifying the room ensures adequate modal density for the use of one source location to obtain acceptable accuracy and repeatability of results. The reference sound source (RSS) used for the comparison method relies on AHRI Standard 250 to accurately describe the requirements for and characterize sound power of the RSS at all frequencies of interest.

Reaffirmed by ANSI
January 17, 2019

ANSI/ASA S12.58-2012

AMERICAN NATIONAL STANDARD

**Sound Power Level Determination for
Sources Using a Single-source Position**

ANSI/ASA S12.58-2012

Accredited Standards Committee S12, Noise

Standards Secretariat
Acoustical Society of America
35 Pinelawn Road, Suite 114E
Melville, NY 11747-3177

The American National Standards Institute, Inc. (ANSI) is the national coordinator of voluntary standards development and the clearinghouse in the U.S.A. for information on national and international standards.

The Acoustical Society of America (ASA) is an organization of scientists and engineers formed in 1929 to increase and diffuse the knowledge of acoustics and to promote its practical applications.



AMERICAN NATIONAL STANDARD

Sound Power Level Determination for Sources Using a Single-source Position

Secretariat:

Acoustical Society of America

Approved by ANSI on:

August 23, 2012

Abstract

This American National Standard describes a method for the determination of sound power levels of noise sources that emit broadband sound and/or discrete frequency sounds/tones using reverberation rooms. The standard applies when it is either undesirable or unfeasible to move the source to decrease the uncertainty of the measurement. The method described requires reverberation room pre-qualification through test and requires the use of the comparison method to determine sound power levels. This standard specifies the physical environment, procedures, and equipment used to qualify the reverberation room by test. Pre-qualifying the room ensures adequate modal density for the use of one source location to obtain acceptable accuracy and repeatability of results. The reference sound source (RSS) used for the comparison method relies on AHRI Standard 250 to accurately describe the requirements for and characterize sound power of the RSS at all frequencies of interest.

AMERICAN NATIONAL STANDARDS ON NOISE

The Acoustical Society of America (ASA) provides the Secretariat for Accredited Standards Committees S1 on Acoustics, S2 on Mechanical Vibration and Shock, S3 on Bioacoustics, S3/SC 1 on Animal Bioacoustics, and S12 on Noise. These committees have wide representation from the technical community (manufacturers, consumers, trade associations, organizations with a general interest, and government representatives). The standards are published by the Acoustical Society of America as American National Standards after approval by their respective Standards Committees and the American National Standards Institute (ANSI).


These standards are developed and published as a public service to provide standards useful to the public, industry, and consumers, and to Federal, State, and local governments.

Each of the Accredited Standards Committees (operating in accordance with procedures approved by ANSI) is responsible for developing, voting upon, and maintaining or revising its own Standards. The ASA Standards Secretariat administers Committee organization and activity and provides liaison between the Accredited Standards Committees and ANSI. After the Standards have been produced and adopted by the Accredited Standards Committees, and approved as American National Standards by ANSI, the ASA Standards Secretariat arranges for their publication and distribution.

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered and that a concerted effort be made towards their resolution.

The use of an American National Standard is completely voluntary. Their existence does not in any respect preclude anyone, whether he or she has approved the Standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the Standards.

NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this Standard.



Acoustical Society of America
ASA Secretariat
35 Pinelawn Road, Suite 114E
Melville, New York 11747-3177
Telephone: 1 (631) 390-0215
Fax: 1 (631) 390-0217
E-mail: asastds@aip.org

© 2012 by Acoustical Society of America. This standard may not be reproduced in whole or in part in any form for sale, promotion, or any commercial purpose, or any purpose not falling within the provisions of the U.S. Copyright Act of 1976, without prior written permission of the publisher. For permission, address a request to the Standards Secretariat of the Acoustical Society of America.

Contents

1	Scope	1
2	Normative references	2
3	Terms and definitions	2
4	Requirements for qualification of reverberation rooms	3
4.1	Reverberation room requirements	3
4.2	Instrumentation requirements	4
4.3	Standard deviation requirements for broadband room qualification	4
4.4	Standard deviation requirements for discrete-frequency room qualification	4
4.5	Microphone position	5
4.6	Microphone traverse	5
4.7	Fixed microphones	6
5	Reverberation room qualification procedures	6
5.1	Introduction	6
5.2	Broadband room qualification	6
5.3	Discrete frequency room qualification	8
6	Sound power testing requirements and calculations	11
6.1	Instrumentation	11
6.2	Volume of unit under test	11
6.3	Location of unit under test	11
6.4	Reference sound source considerations	11
6.5	Measurements	11
6.6	One-third octave band sound power level calculation	11
6.7	Octave band sound power level calculations	13
6.8	A-weighted sound power level	14
6.9	Linear sound power level	14
7	Information to be recorded	15
7.1	General	15
7.2	Noise source under test	15
7.3	Test environment	15
7.4	Instrumentation	16
7.5	Acoustical data	16
8	Test report	16
9	Conformance conditions	16
	Annex A (informative) Sample calculation	17

Tables

Table 1 — Maximum standard deviations of sound power level reproducibility determined in accordance with this standard	1
Table 2—Broadband standard deviation limits	4

Table 3—Discrete frequency standard deviation limits.....	4
Table 4 — Test frequencies for discrete frequency qualification	9
Table 5 — One-third octave band frequency range [ANSI/ASA S1.6-1984 (R 2011)]	10
Table 6 — Background correction limits by one-third octave band	13
Table 7 — One-third octave band numbers and A-weighting factors.....	14

Foreword

[*This Foreword is for information only and is not a part of the American National Standard ANSI/ASA S12.58-2012 American National Standard Sound Power Level Determination for Sources Using a Single-source Position. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.*]

This standard comprises a part of a group of definitions, standards, and specifications for use in noise. It was developed and approved by Accredited Standards Committee S12 Noise, under its approved operating procedures. Those procedures have been accredited by the American National Standards Institute (ANSI). The Scope of Accredited Standards Committee S12 is as follows:

Standards, specifications, and terminology in the field of acoustical noise pertaining to methods of measurement, evaluation, and control, including biological safety, tolerance and comfort, and physical acoustics as related to environmental and occupational noise.

The information in this paragraph of the Foreword was updated during the 2019 reaffirmation process, but the technical content in the body of the document, as well as all other front matter (membership, remains identical to the 2012 publication. This standard was developed from the Air-Conditioning, Heating and Refrigeration Institute's (AHRI) standard AHRI 220. It is published here with permission from AHRI after being approved by ballot in Accredited Standards Committee S12. The intent for AHRI and S12 is to move to undated references when appropriate, and the technical portion of this document will be updated in the next revision cycle. It is appropriate to use undated references for ANSI/ASA S1.6, ANSI/ASA S1.11/IEC 61260 Parts 1 through 3, ANSI/ASA S12.51/ISO 3741, and AHRI 250. Also, ASHRAE Terminology of Heating, Ventilation, Air-Conditioning and Refrigeration was replaced with a web application <https://www.ashrae.org/resources--publications/free-resources/ashrae-terminology>.

This standard is not comparable to any existing ISO Standard.

At the time this Standard was submitted to Accredited Standards Committee S12, Noise for approval, the membership was as follows:

W.J. Murphy, *Chair*
R.D. Hellweg, *Vice-Chair*

S.B. Blaeser, *Secretary*

3M Occupational Health & Environmental Safety Division	E.H. Berger
Acoustical Society of America	R.D. Hellweg D. Lubman (Alt.)
Air-Conditioning, Heating and Refrigeration Institute	S.J. Lind D. Abbate (Alt.)
Air Movement & Control Association, Inc.	J.A. Brooks M. Stevens (Alt.)
Alcoa Inc.	W.D. Gallagher
American Academy of Audiology	D. Ostergren S. Gordon-Salant (Alt.)
American Academy of Otolaryngology - Head and Neck Surgery	R.A. Dobie L.A. Michael (Alt.)

American Industrial Hygiene Association	D. Driscoll S.N. Hacker (Alt.)
American Speech-Language-Hearing Association	L.A. Wilber V. Gladstone (Alt.)
Caterpillar, Inc.	K.G. Meitl
Compressed Air and Gas Institute	R.C. Johnson D.R. Bookshar (Alt.)
Council for Accreditation in Occupational Hearing Conservation	VACANT L.D. Hager (Alt.)
Emerson Electric – Copeland Corporation	A.T. Herfat G. Williamson (Alt.)
ETS – Lindgren Acoustic Systems	D. Winker M. Black (Alt.)
ExxonMobil	B. Moulton
G.R.A.S. Sound & Vibration	B. Schustrich
General Motors	D.B. Moore
Harley-Davidson Motor Company	D. Jaeger
Information Technology Industry Council	W.M. Beltman J. Rosenberg (Alt.)
Institute of Noise Control Engineering	B. Tinianov
International Safety Equipment Association	J. Birkner C.Z. Fargo (Alt.)
John Deere	K.B. Washburn K. Cone (Alt.)
National Council of Acoustical Consultants	J. Erdreich G.E. Winzer (Alt.)
National Hearing Conservation Association	J. Cissna
National Institute for Occupational Safety and Health	W.J. Murphy E. Zechmann (Alt.)
National Institute of Standards and Technology – National Voluntary Laboratory Accreditation Program	B.A. Sandoval
National Park Service	G.R. Stanley K. Frstrup (Alt.)
Noise Control Engineering, Inc.	M.A. Bahtiarian R. Fischer (Alt.)
Noise Pollution Clearinghouse	L. Blomberg
North American Insulation Manufacturers Association	H. Alter

PCB Group	K. Cox L. Harbaugh (Alt.)
Power Tool Institute, Inc.	W.D. Spencer M. Hickok (Alt.)
Quest Technologies, Inc.	M. Wurm P.J. Battenberg (Alt.)
Schomer and Associates, Inc.	P.D. Schomer
Sierra Club – National Parks and Monuments Committee	D.J. Hingson
Sperian Hearing Protection, LLC	B. Witt T. Schulz (Alt.)
U.S. Access Board	M.K. Mazz
U.S. Air Force	R.L. McKinley H. Gallagher (Alt.)
U.S. Army Aeromedical Research Lab	W.A. Ahroon
U.S. Army Construction Engineering Research Laboratory	M.J. White M. Swearingen (Alt.)
U.S. Army Public Health Command	C. Stewart M. Grantham (Alt.)
U.S. Army Research Laboratory, Human Research and Engineering Directorate	J. Gaston M.S. Binseel (Alt.)
U.S. Department of Transportation	A. Konheim
U.S. Naval Surface Warfare Center- Carderock	M. Craun
Université du Québec ETS	J. Voix F. Laville (Alt.)

Individual Experts of Accredited Standards Committee S12, Noise, were:

P.K. Baade	W.W. Lang	R.J. Peppin
E.H. Berger	D. Lubman	J. Schmitt
B.M. Brooks	D. Michaud	P.D. Schomer
A.J. Campanella	N.P. Miller	L.C. Sutherland
L.S. Finegold	W.J. Murphy	W.R. Thornton
R.D. Godfrey	M.A. Nobile	L.A. Wilber
R.D. Hellweg		G.E. Winzer

Working Group S12/WG 23, Determination of Sound Power, which assisted Accredited Standards Committee S12, Noise, in the development of this standard, had the following membership.

B.M. Brooks and J. Schmitt, Co-Chairs
S.J. Lind, Project Leader

M.C. Black	K. Cunefare	M.A. Nobile
S. Bly	R.D. Hellweg	M. O'Connell
A.J. Campanella	A.T. Herfat	P.D. Schomer

D. Collings

S. Keith
G.C. Maling

J. Weinstein

Suggestions for improvements to this standard will be welcomed. They should be sent to Accredited Standards Committee S12, Noise, in care of the Standards Secretariat of the Acoustical Society of America, 35 Pinelawn Road, Suite 114E, Melville, New York 11747-3177. Telephone: 631-390-0215; Fax: 631-390-0217; E-mail: asastds@aip.org.

Introduction

This standard describes a method for determination of sound power levels of broadband and/or discrete-frequency noise, and narrowband noise sources in reverberation rooms. It is based on but more restrictive than ANSI/ASA S12.51/ISO 3741, which allows the user to test using either the direct method or the comparison method and also allows the user to employ a space with general characteristics. The intent of ANSI/ASA S12.51/ISO 3741 is to have a room that provides a “good” environment for testing, with the understanding that if the end result has a variation that is too high, the user can increase the number of measurement locations to improve the spatial averaging and thus lower the variation. This is not practical for sources that are difficult to move.

The method described herein requires reverberation room pre-qualification through test and requires the use of the comparison method to determine sound power levels. This Standard specifies the physical environment, procedures, and equipment to qualify the reverberation room by test. Pre-qualifying the room ensures adequate modal density for the use of one source location to obtain acceptable accuracy and repeatability of results. The reference sound source (RSS) used for the comparison method relies on AHRI Standard 250 to accurately determine the sound power for the RSS at all frequencies of interest. The use of the comparison method reduces a number of potential sources of data collection and calculation errors. The standard contains information on instrumentation, installation, and operation of the source, procedures for determining the number of microphone positions or length of traverse, and procedures for the calculation of sound power levels.

American National Standard

Sound Power Level Determination for Sources Using a Single-source Position

1 Scope

This American National Standard describes a method for the determination of sound power levels of noise sources that emit broadband sound and/or discrete frequency sounds/tones in reverberation rooms. The method described herein requires reverberation room pre-qualification through test and requires the use of the comparison method to determine sound power levels. This standard specifies the physical environment, procedures, and equipment used to qualify the reverberation room by test. Pre-qualifying the room ensures adequate modal density for the use of one source location to obtain acceptable accuracy and repeatability of results. The reference sound source (RSS) used for the comparison method relies on AHRI Standard 250 to accurately describe the performance and characterize the sound power of the RSS at all frequencies of interest. Sound rating values are often useful for applications and design; therefore, it is important to acquire data and qualify measurement rooms in one-third octave bands. The use of the comparison method reduces a number of potential sources of error. This standard contains information on instrumentation, installation, and operation of the source; procedures for determining the number of microphone positions or length of traverse; and procedures for the calculation of sound power level. Measurements made in conformity with this standard will, with very few exceptions, result in standard deviations equal to or less than specified in Table 1.

The frequencies covered in this standard range from the 50 Hz to the 10,000 Hz one-third octave bands (63 Hz to 8000 Hz octave bands). The 50 to 80 Hz one-third octave band sound frequently affects product applications and often cannot be ignored. The product-specific standards referring to this method should specify the frequency range of interest for qualification, calculation, and reporting. This standard is based on ANSI/ASA S12.51/ISO 3741 but provides additions, exceptions, and extensions.

Table 1 — Maximum standard deviations of sound power level reproducibility determined in accordance with this standard

One-third octave band center frequency, Hz	One-third octave band maximum standard deviation of reproducibility, σ_{R0} , dB
50 - 80	4.0
100 - 160	3.0
200 - 315	2.0
400 - 5000	1.5
6000 - 10000	3.0
A-weighted	1.0

This standard is intended to serve as a basic reference to be used in product-specific standards and for the guidance of the industry, including manufacturers, engineers, installers, contractors, and users.

The standard is appropriate for all noise sources but is especially appropriate when it is either undesirable or unfeasible to move the source to decrease the uncertainty of the measurement.

This standard applies to products where sound power is determined by measurement using the comparison method in a reverberation room that meets the qualification requirements of this standard.