

PD IEC/TR 61439-0:2013



BSI Standards Publication

Low-voltage switchgear and controlgear assemblies

Part 0: Guidance to specifying assemblies

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide™



National foreword

This Published Document is the UK implementation of IEC/TR 61439-0:2013.

The UK participation in its preparation was entrusted by Technical Committee PEL/17, Switchgear, controlgear, and HV-LV co-ordination, to Subcommittee PEL/17/3, Low voltage switchgear and controlgear assemblies.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013

Published by BSI Standards Limited 2013

ISBN 978 0 580 79300 4

ICS 29.130.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 May 2013.

Amendments issued since publication

Amd. No.	Date	Text affected
-----------------	-------------	----------------------



TECHNICAL REPORT

Low-voltage switchgear and controlgear assemblies – Part 0: Guidance to specifying assemblies

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XB**

ICS 29.130.20

ISBN 978-2-83220-787-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

INTRODUCTION.....	7
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	10
4 Application of ASSEMBLIES within the IEC 61439 series	10
4.1 General.....	10
4.2 ASSEMBLY design and verification.....	10
4.3 Service conditions and interface characteristics	10
4.4 Design.....	11
5 Electrical system	11
5.1 General.....	11
5.2 Earthing system	11
5.3 Nominal voltage	11
5.4 Transient overvoltages	12
5.5 Unusual voltage transients, temporary overvoltages	13
5.6 Rated frequency f_n (Hz)	13
5.7 Additional on-site testing requirements: wiring, operational performance and function	14
6 Short-circuit withstand capability	14
6.1 General.....	14
6.2 Prospective short-circuit current at supply terminals I_{CP} (kA).....	14
6.3 Prospective short-circuit current in the neutral.....	15
6.4 Prospective short-circuit current in the protective circuit.....	15
6.5 Short-circuit protective device (SCPD).....	15
6.6 Co-ordination of short-circuit protective devices including external short-circuit protective device details.....	16
6.7 Data associated with loads likely to contribute to the short-circuit current.....	16
7 Protection of persons against electric shock	17
7.1 General.....	17
7.2 Basic protection (protection against direct contact).....	17
7.2.1 General	17
7.2.2 Basic insulation provided by insulating material	17
7.2.3 Barriers or enclosures	17
7.3 Fault protection (protection against indirect contact).....	18
7.3.1 General	18
7.3.2 Requirements for the protective conductor to facilitate automatic disconnection of the supply	18
7.3.3 Electrical separation	19
7.3.4 Protection by total insulation.....	19
8 Installation environment.....	20
8.1 General.....	20
8.2 Location type.....	20
8.3 Protection against ingress of solid foreign bodies and ingress of water.....	20
8.4 External mechanical impact.....	21
8.5 Resistance to UV radiation	21
8.6 Resistance to corrosion	21

8.7	Ambient air temperature	21
8.8	Maximum relative humidity	21
8.9	Pollution degree	22
8.10	Altitude.....	22
8.11	EMC environment.....	22
8.12	Special service conditions	23
8.12.1	General	23
8.12.2	Climatic conditions	24
8.12.3	Protection against ingress of solid foreign bodies and ingress of water	24
8.12.4	Shock, vibration, seismic occurrence and external mechanical impact (IK).....	24
8.12.5	Fire and explosion hazards.....	24
8.12.6	Exceptional overvoltages	25
8.12.7	EMC environment	25
9	Installation method	25
9.1	General	25
9.2	Assembly type.....	25
9.3	Portability.....	26
9.4	Maximum overall dimensions and weight.....	26
9.5	External conductor type(s).....	26
9.6	Direction(s) of external conductors	26
9.7	External conductor material.....	26
9.8	External phase conductor, cross-sections, and terminations.....	27
9.9	External PE, N, PEN conductors cross-sections, and terminations	27
9.10	Special terminal identification requirements.....	27
10	Storage and handling	28
10.1	General	28
10.2	Maximum dimensions and weight of transport units	28
10.3	Methods of transport (e.g. forklift, crane).....	28
10.4	Environmental conditions different from the service conditions	28
10.5	Packing details	28
11	Operating arrangements.....	28
11.1	General	28
11.2	Access to manually operated devices	29
11.3	Isolation of load installation equipment items.....	29
12	Maintenance and upgrade capabilities	30
12.1	General	30
12.2	Requirements related to accessibility for inspection and similar operations	30
12.3	Requirements related to accessibility for maintenance in service by authorized persons.....	30
12.4	Requirements related to extension under voltage	31
12.5	Protection against direct contact with hazardous live internal parts during maintenance or upgrade.....	31
12.6	Method of functional units connection.....	31
12.7	Operating and maintenance gangways within an ASSEMBLY	32
12.8	Internal separation	32
13	Current carrying capability.....	32
13.1	General	32

13.2	Rated current I_{nA} (A) (maximum current allowable).....	32
13.3	Rated current of circuits I_{nC} (A).....	33
13.4	Rated diversity factor (RDF)	33
13.5	Ratio of cross-section of the neutral conductor to phase conductors.....	33
13.5.1	General	33
13.5.2	Phase conductors up to and including 16 mm ²	33
13.5.3	Phase conductors above 16 mm ²	33
14	ASSEMBLY design and routine verification processes	34
14.1	Design verification.....	34
14.1.1	Object.....	34
14.1.2	Methods	34
14.1.3	Records.....	34
14.2	Routine verification.....	34
14.2.1	General	34
14.2.2	Records.....	35
Annex A	(informative) Cross-section of copper conductors suitable for connection to terminals for external conductors	36
Annex B	(informative) Forms of internal separation (see 12.8)	37
Annex C	(informative) Specification guidance for IEC 61439-2.....	41
Annex D	(informative) Specification guidance for IEC 61439-3.....	47
Annex E	(informative) Specification guidance for IEC 61439-4.....	51
Annex F	(informative) Specification guidance for future IEC 61439-5	55
Annex G	(informative) Specification guidance for IEC 61439-6	56
Annex H	(informative) Specification guidance for IEC 61439-7.....	60
Annex I	(informative) List of notes concerning certain countries	61
Bibliography	62
Figure 1	– Required rated impulse withstand voltage	13
Figure B.1	– Symbols used in Figures B.2 and B.3.....	38
Figure B.2	– Forms 1 and 2	39
Figure B.3	– Forms 3 and 4	40
Table A.1	– Cross-section of copper conductors suitable for connection to terminals for external conductors	36
Table B.1	– Forms of internal separation.....	37
Table C.1	– Items subject to agreement between the ASSEMBLY manufacturer and the user	41
Table C.2	– Examples of optional items subject to agreement between the ASSEMBLY manufacturer and the user	45
Table D.1	– Items subject to agreement between the ASSEMBLY manufacturer and the user	47
Table E.1	– Items subject to agreement between the ASSEMBLY manufacturer and the user	51
Table G.1	– Items subject to agreement between the ASSEMBLY manufacturer and the user	56

INTRODUCTION

For the purposes of this technical report, the user is the party who specifies or selects the ASSEMBLY characteristics. The user may be the same party as the one who will use and operate the ASSEMBLY, or someone acting on their behalf. The aim of this technical report is to provide the user with guidance on the specification that should be provided in order to achieve the desired design of an assembly. Throughout this technical report, the term ASSEMBLY is used for a low-voltage switchgear and controlgear assembly. The term “manufacturer” refers to the ASSEMBLY manufacturer unless specifically noted otherwise.

The purpose of the IEC 61439 series of standards is to harmonize as far as practicable, all the general rules and requirements that apply to ASSEMBLIES. The series further seeks, in order to obtain uniformity of requirements for ASSEMBLIES, consistency in the verification of ASSEMBLIES and to avoid the need for verification to other standards.

All those requirements for the various ASSEMBLIES that can be considered as general, together with specific subjects of wide interest and application, e.g. temperature rise, dielectric properties, have therefore been gathered in IEC 61439-1 as general rules. For each type of ASSEMBLY only two main standards are necessary to determine all requirements and the corresponding methods of verification:

- 1) the standard giving the general rules and designated “Part 1”, and
- 2) the specific ASSEMBLY standard, hereinafter referred to as the relevant ASSEMBLY standard.

The IEC 61439 series of standards encompasses ASSEMBLIES for a wide variety of uses, some of which have specific needs as dictated by their particular application. In order to define clearly these specific needs, relevant ASSEMBLY standards focussed on a particular type of application have been (or are being) developed. These are identified as IEC 61439-2 to IEC 61439-7, inclusive (see list below). Each relevant ASSEMBLY standard with reference to IEC 61439-1, the general rules, as appropriate, specifies the characteristics and performance required by an ASSEMBLY within its defined scope of application. Each relevant ASSEMBLY standard includes, as an annex, a template for “items subject to agreement between the ASSEMBLY manufacturer and the user” to facilitate the specifying of an ASSEMBLY. These are reproduced and explained in this technical report.

General characteristics of all types of assemblies are considered in this Technical Report. Details of which are applicable to each type of assembly can be determined by reference to the Specification Template in Annex ‘C’ onwards.

Within this technical report, reference to IEC 61439 means the series of ASSEMBLY standards, including:

- IEC 61439-1:2011, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*
- IEC 61439-2:2011, *Low-voltage switchgear and controlgear assemblies – Part 2: Power switchgear and controlgear assemblies*
- IEC 61439-3:2012, *Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)*
- IEC 61439-4:2012, *Low-voltage switchgear and controlgear assemblies – Part 4: Particular requirements for assemblies for construction sites (ACS)*
- IEC 61439-5:2010, *Low-voltage switchgear and controlgear assemblies – Part 5: Assemblies for power distribution in public networks*
- IEC 61439-6:2012, *Low-voltage switchgear and controlgear assemblies – Part 6: Busbar trunking systems (busways)*

- IEC 61439-7:2013, *Low-voltage switchgear and controlgear assemblies – Part 7: Assemblies for specific applications such as marinas, camping sites, market squares, electrical vehicles charging stations*¹

A reference to “general rules” means a reference to IEC 61439-1:2011.

A reference to “ASSEMBLY standard” means the relevant part of the IEC 61439 series (e.g. Part 2, 3, etc.).

A reference to “product standard” means the relevant part or parts of the IEC standard for the components used in the ASSEMBLY (e.g. IEC 60947-2 for circuit breakers).

¹ To be published.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 0: Guidance to specifying assemblies

1 Scope

Within the IEC 61439 series of standards for low-voltage switchgear and controlgear assemblies (ASSEMBLIES), there are system and application details that are specified by the user to enable the manufacturer to produce an ASSEMBLY that meets the needs and expectations of the user.

This Part of IEC 61439, which is a technical report identifies, from the user's perspective, those functions and characteristics that should be defined when specifying ASSEMBLIES. It provides:

- an explanation of the ASSEMBLY characteristics and options within the IEC 61439 series;
- a guidance on how to select the appropriate option and to define characteristics so as to meet specific application needs, using a functional approach; and
- an assistance in the specification of ASSEMBLIES.

References within this technical report to the interface characteristics of an ASSEMBLY and the requirements with which they will comply assume that the ASSEMBLY is designed, manufactured, and verified in accordance with the relevant IEC 61439 part.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

IEC 60364-4-41, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-6, *Low-voltage electrical installations – Part 6: Verification*

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61439-1:2011, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 62262, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*