

BS 6867:2013



BSI Standards Publication

Maintenance of electrical switchgear and controlgear for voltages above 36 kV – Code of practice

bsi.

...making excellence a habit.™

Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2013

Published by BSI Standards Limited 2013

ISBN 978 0 580 61300 5

ICS 29.130.10

The following BSI references relate to the work on this document:

Committee reference PEL/17/1

Draft for comment 13/30174947 DC

Publication history

First published October 1987

Second (present) edition, September 2013

Amendments issued since publication

Date	Text affected
------	---------------

Contents

Foreword *iii*

Section 1: General 1

- 1 Scope 1
- 2 Normative references 1
- 3 Terms and definitions 1
- 4 Maintenance policy 3
- 5 Operational policy 4
- 6 Competence 4

Section 2: Safety 5

- 7 Personal protective equipment and treatment of persons suffering from electric shock 5
- 8 Operational experience 5
- 9 Safety rules and procedures for safe systems of work 5
- 10 Equipment location 6
- 11 Isolation and access for maintenance 6
- 12 Preparing for maintenance work 8
- 13 Fire extinguishing equipment 8
- 14 Testing 9
- 15 Disposal of scrap 9

Section 3: Common recommendations relating to maintenance 10

- 16 Manufacturer's instructions 10
- 17 Newly commissioned equipment 10
- 18 Frequency of maintenance 10
- 19 Records and drawings 13
- 20 Replacement parts 14
- 21 Cleanliness 15
- 22 Marking of covers and connections 15
- 23 Quality of connections 15
- 24 Maintenance and testing of insulation 16
- 25 Maintenance of safety earthing continuity 20
- 26 Shutters, locking devices, etc. 20
- 27 Interlocks 20
- 28 Ventilation 21
- 29 Equipment heating and lighting 21
- 30 Lifting devices 21
- 31 Mechanisms 22
- 32 Tripping and closing supplies 24
- 33 Equipment tools, spares and test instruments 24
- 34 Conclusion of maintenance 24

Section 4: Additional recommendations relating to the maintenance of specific items 25

- 35 Circuit breakers 25
- 36 Switches and switch disconnectors 40
- 37 Disconnectors and earthing switches 40
- 38 Busbars and busbar chambers 40
- 39 Relays 41
- 40 Protective, measuring and control transformers 42
- 41 Cable boxes and terminations 44
- 42 Compressed air plant 44
- 43 Ancillary and auxiliary circuits 44
- 44 Capacitive charged motor drive mechanisms 44

Annexes

Annex A (informative) Statutory requirements and related documents 45

Annex B (informative) Example of items to be covered in safety rules 46

Bibliography 52

List of tables

Table 1 – Recommended test voltages 16

Table 2 – Maintenance of ancillary and auxillary circuits 44

Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 54, an inside back cover and a back cover.

Foreword

Publishing information

This British Standard is published by BSI Standards Limited, under license from the British Standards Institution and came into effect on 30 September 2013. It was prepared by Subcommittee PEL/17/1, *High-voltage switchgear and controlgear*, under the authority of Technical Committee PEL/17, *High-voltage switchgear and controlgear and HV-LV co-ordination*. A list of organizations represented on these committees can be obtained on request to their secretary.

Supersession

This British Standard supersedes BS 6867:1987, which is withdrawn.

Information about this document

This is a full revision of the standard, and introduces the following principal changes.

- The various types of maintenance approach are discussed, including preventative and condition based maintenance.
- Maintenance policies using PAS 55 philosophy have been introduced.
- Maintenance considerations for modern plant and equipment, like gas insulated switchgear (GIS) and capacitive charged motor drive mechanisms, have been added.
- The standard has been restructured to create a dedicated clause on mechanisms (Clause 31).
- Text on use and handling of sulphur hexafluoride has been brought up to date.
- Recommendations for hard-gas interrupters are not given.

The purpose of this British Standard is to provide, in a convenient form, recommendations and guidance on those matters which technical knowledge and experience have shown to be important in keeping electrical switchgear and controlgear in an acceptable condition. It is intended for the guidance of those actually carrying out the maintenance work, as well as for administrative personnel.

The normally quiescent state of electrical switchgear and some controlgear does not automatically draw attention to incipient faults, deterioration or danger resulting from neglect and the consequent need for maintenance. It follows, therefore, that an organized system of maintenance is important to facilitate continued safe and acceptable operation of an electrical system with the minimum risk of failure and consequent interruption of supply.

Use of this document

As a code of practice, this British Standard takes the form of guidance and recommendations. It should not be quoted as if it were a specification and particular care should be taken to ensure that claims of compliance are not misleading.

Any user claiming compliance with this British Standard is expected to be able to justify any course of action that deviates from its recommendations.

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Hazard warnings

WARNING. Older switchgear might contain asbestos. Attention is drawn to the Control of Asbestos Regulations 2012.

Presentational conventions

The provisions in this standard are presented in roman (i.e. upright) type. Its recommendations are expressed in sentences in which the principal auxiliary verb is "should".

Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.

Contractual and legal considerations

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

In particular attention is drawn to the statutory regulations listed in Annex A.

Section 1: General

1 Scope

This British Standard gives recommendations and guidance for the maintenance of electrical switchgear and controlgear having a rated a.c. or d.c. voltage above 36 kV.

NOTE This standard is not applicable to explosion protected switchgear and controlgear. Inspection and maintenance of electrical apparatus in explosive gas atmospheres is covered in BS EN 60079-17.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 6423:1983+A1:1992, *Code of practice for maintenance of electrical switchgear and controlgear for voltages up to and including 1 kV*

BS EN 13306:2010, *Maintenance – Maintenance terminology*

BS EN 50110-1:2013, *Operation of electrical installations – Part 1: General requirements*

BS EN 60422, *Mineral insulating oils in electrical equipment – Supervision and maintenance guidance*

BS EN 60480, *Guidelines for the checking and treatment of sulphur hexafluoride (SF₆) taken from electrical equipment and specification for its re-use*

PD CLC/TR 62271-303, *High voltage switchgear and controlgear – Part 303: Use and handling of sulphur hexafluoride (SF₆)*

3 Terms and definitions

For the purposes of this British Standard the terms and definitions given in BS EN 13306:2010, BS EN 50110-1:2013 and the following apply.

3.1 acceptable condition

condition in which an item is able to meet the requirements of the relevant specification and perform its required functions

3.2 controlgear

a general term covering switching devices and their combination with associated control, measuring, protective and regulating equipment, also assemblies of such devices and equipment with associated interconnections, accessories, enclosures and supporting structures, intended in principle for the control of electric energy consuming equipment [IEC 60050-441:1984+A1, **441-11-03**]

3.3 dead working

work activity on electrical installations, which are neither live nor charged, carried out after having taken all measures to prevent electrical danger [BS EN 50110-1:2013, **3.4.8**]

3.4 diagnostic test

comparative measurement carried out to monitor the condition of an item