

BS HD 60269-2:2013

BS 88-2:2013

Incorporating corrigendum February 2014



BSI Standards Publication

Low-voltage fuses

Part 2: Supplementary requirements
for fuses for use by authorized persons
(fuses mainly for industrial application)
— Examples of standardized systems of
fuses A to K

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of HD 60269-2:2013. It is derived from IEC 60269-2:2013. It supersedes BS HD 60269-2:2010 (dual numbered as BS 88-2:2010) which will be withdrawn on 15 August 2016.

The CENELEC common modifications have been implemented at the appropriate places in the text. The start and finish of each common modification is indicated in the text by tags **C** **C1**.

This standard covers the following British Fuse systems that are included in BS HD 60269-2:2013 (BS 88-2:2013):

Fuse system E — Fuses with fuse-links for bolted connections (BS bolted fuse system)

Fuse system G — Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)

Fuse system I — gU fuse-links with wedge tightening contacts

This standard is part of a series of British Standards for Low Voltage Fuses. These cover the related parts and examples of systems of fuses in the associated IEC 60269 series of standards.

These British Standards together with their IEC counterparts are:

BS EN 60269-1:2007+A1:2009 (BS 88-1:2007) — General requirements (IEC 60269-1)

BS HD 60269-2:2013 (BS 88-2:2013) — Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) (IEC 60269-2, Fuse systems E, G and I)

BS HD 60269-3:2010 (BS 88-3:2010) — Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) (IEC 60269-3, Fuse system C)

BS EN 60269-4:2009+A1:2012 (BS 88-4:2009+A1:2012) — Supplementary requirements for fuse-links for the protection of semiconductor devices (IEC 60269-4)

PD IEC/TR 60269-5:2010 (PD 88-5:2010) — Guidance for the application of low voltage fuses (IEC/TR 60269-5:2010)

BS EN 60269-6:2011 — Supplementary requirements for fuse-links for the protection of solar photovoltaic energy system (IEC 60269-6:2010).

The text for BS HD 60269-2:2013/BS 88-2:2013 has been extracted from IEC 60269-2:2013 and is identical to the text for sections E, G, and I. However, wherever a reference is made to IEC 60269-1 in the text this should be taken as a reference to BS EN 60269-1 (BS 88-1).

The UK participation in its preparation was entrusted to Technical Committee PEL/32, Fuses.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.

Published by BSI Standards Limited 2014

ISBN 978 0 580 85308 1

ICS 29.120.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2013.

Amendments/corrigenda issued since publication

| Date | Text affected |
|---------------|---|
| 31 March 2014 | Standard amended to only include fuses E, G and I |

English version

**Low-voltage fuses -
Part 2: Supplementary requirements for fuses for use by authorized
persons (fuses mainly for industrial application) -
Examples of standardized systems of fuses A to K
(IEC 60269-2:2013, modified)**

Fusibles basse tension -
Partie 2: Exigences supplémentaires pour
les fusibles destinés à être utilisés par des
personnes habilitées (fusibles pour
usages essentiellement industriels) -
Exemples de systèmes de fusibles
normalisés A à K
(CEI 60269-2:2013, modifiée)

Niederspannungssicherungen -
Teil 2: Zusätzliche Anforderungen an
Sicherungen zum Gebrauch durch
Elektrofachkräfte bzw. elektrotechnisch
unterwiesene Personen (Sicherungen
überwiegend für den industriellen
Gebrauch) -
Beispiele für genormte
Sicherungssysteme A bis K
(IEC 60269-2:2013, modifiziert)

This Harmonization Document was approved by CENELEC on 2013-08-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 32B/611/FDIS, future edition 5 of IEC 60269-2:2013, prepared by SC 32B, "Low-voltage fuses", of IEC/TC 32, "Fuses" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as HD 60269-2:2013.

A draft amendment, which covers common modifications to IEC 60269-2:2013, was prepared by CLC/SR 32B "Low-voltage fuses" and approved by CENELEC.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-08-15
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2016-08-15

This document supersedes HD 60269-2:2010.

HD 60269-2:2013 includes the following significant technical changes with respect to HD 60269-2:2010:

- a) fuse systems A and B: modified values for the power dissipation of NH aM fuse-links;
- b) fuse systems A and B: introduction of dimension r for NH fuse-links;
- c) addition of new fuse system K: gK fuse-links with contacts for bolted connections.

This part is to be used in conjunction with EN 60269-1:2007 + A1:2009, *Low-voltage fuses – Part 1: General requirements*.

This Part 2 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 2 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101 in fuse system A, from 201 in fuse system B, etc. Additional annexes are numbered AA, BB, etc.

Clauses, subclauses, notes, tables, figures and annexes which are additional to those in IEC 60269-2:2013 are prefixed "Z".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Endorsement notice

The text of the International Standard IEC 60269-2:2013 was approved by CENELEC as a Harmonisation Document with agreed common modifications.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

| | |
|-------------|-----------------------------------|
| IEC 60060-1 | NOTE Harmonised as EN 60060-1. |
| IEC 60060-2 | NOTE Harmonised as EN 60060-2. |
| IEC 60060-3 | NOTE Harmonised as EN 60060-3. |
| IEC 60529 | NOTE Harmonised as EN 60529. |
| IEC 60672-1 | NOTE Harmonised as EN 60672-1. |
| IEC 60672-2 | NOTE Harmonised as EN 60672-2. |
| IEC 60672-3 | NOTE Harmonised as EN 60672-3. |
| IEC 62262 | NOTE Harmonised as EN 62262. |
| ISO 898-1 | NOTE Harmonised as EN ISO 898-1. |
| ISO 1207 | NOTE Harmonised as EN ISO 1207. |
| ISO 4589-1 | NOTE Harmonised as EN ISO 4589-1. |

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | <u>EN/HD</u> | <u>Year</u> |
|--------------------|-------------|---|--------------|-------------|
| IEC 60112 | - | Method for the determination of the proof and the comparative tracking indices of solid insulating materials | EN 60112 | - |
| IEC 60269-1 | - | Low-voltage fuses Part 1: General requirements | EN 60269-1 | - |
| IEC 60664-1 | - | Insulation coordination for equipment within low-voltage systems Part 1: Principles, requirements and tests | EN 60664-1 | - |
| IEC 60999 | Series | Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units | EN 60999 | Series |
| IEC 60999-1 | - | Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm ² up to 35 mm ² (included) | EN 60999-1 | - |
| IEC 60999-2 | - | Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units Part 2: Particular requirements for clamping units for conductors above 35 mm ² up to 300 mm ² (included) | EN 60999-2 | - |
| ISO 6988 | - | Metallic and other non-organic coatings - Sulfur dioxide test with general condensation of moisture | EN ISO 6988 | - |

CONTENTS

| | |
|--|-----------|
| INTRODUCTION..... | 9 |
| 1 General scope..... | 10 |
| 1.1 Scope..... | 10 |
| 1.2 Normative references | 11 |
| Fuse system E – Fuses with fuse-links for bolted connections (BS bolted fuse system) | 12 |
| 1 General..... | 12 |
| 1.1 Scope..... | 12 |
| 2 Terms and definitions | 12 |
| 3 Conditions for operation in service..... | 12 |
| 4 Classification..... | 12 |
| 5 Characteristics of fuses | 12 |
| 5.3.1 Rated current of the fuse-link..... | 12 |
| 5.3.2 Rated current of the fuse-holder | 12 |
| 5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder | 13 |
| 5.6 Limits of time-current characteristics | 13 |
| 5.6.1 Time-current characteristics, time-current zones and overload curves | 13 |
| 5.6.2 Conventional times and currents..... | 13 |
| 5.6.3 Gates | 13 |
| 5.7.2 Rated breaking capacity | 13 |
| 6 Markings | 13 |
| 6.1 Markings of fuse-holders | 14 |
| 6.2 Markings of fuse-links..... | 14 |
| 7 Standard conditions for construction..... | 14 |
| 7.1 Mechanical design..... | 14 |
| 7.1.2 Connections including terminals | 14 |
| 7.2 Insulating properties and suitability for insulation | 14 |
| 7.9 Protection against electric shock | 14 |
| 8 Tests..... | 14 |
| 8.3 Verification of temperature rise and power dissipation | 14 |
| 8.3.1 Arrangement of the fuse | 14 |
| 8.3.3 Measurement of the power dissipation of the fuse-link..... | 14 |
| 8.4 Verification of operation | 15 |
| 8.4.1 Arrangement of the fuse | 15 |
| 8.5 Verification of breaking capacity..... | 15 |
| 8.5.1 Arrangement of the fuse | 15 |
| 8.5.8 Acceptability of test results..... | 15 |
| 8.9 Verification of resistance to heat | 15 |
| 8.10 Verification of non-deterioration of contacts..... | 15 |
| 8.10.1 Arrangement of the fuse | 15 |
| 8.10.2 Test method | 15 |
| 8.10.3 Acceptability of the results..... | 16 |
| 8.11 Mechanical and miscellaneous tests..... | 16 |
| FIGURES..... | 17 |

| | |
|--|----|
| Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system) | 26 |
| 1 General | 26 |
| 1.1 Scope | 26 |
| 2 Terms and definitions | 26 |
| 3 Conditions for operation in service | 26 |
| 4 Classification | 26 |
| 5 Characteristics of fuses | 26 |
| 5.2 Rated voltage | 27 |
| 5.3.1 Rated current of the fuse-link | 27 |
| 5.3.2 Rated current of the fuse-holder | 27 |
| 5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder | 27 |
| 5.6.1 Time-current characteristics, time-current zones | 27 |
| 5.6.2 Conventional times and currents | 27 |
| 5.6.3 Gates | 27 |
| 5.7.2 Rated breaking capacity | 28 |
| 6 Markings | 28 |
| 6.1 Markings of fuse-holders | 28 |
| 6.2 Markings of fuse-links | 28 |
| 7 Standard conditions for construction | 28 |
| 7.1 Mechanical design | 28 |
| 7.1.2 Connections including terminals | 28 |
| 7.2 Insulating properties and suitability for insulation | 29 |
| 7.7 I^2t characteristics | 29 |
| 7.9 Protection against electric shock | 29 |
| 8 Tests | 29 |
| 8.3.3 Measurement of the power dissipation of the fuse-link | 29 |
| 8.4.1 Arrangement of the fuse | 30 |
| 8.5.1 Arrangement of the fuse | 30 |
| 8.7.4 Verification of overcurrent discrimination | 30 |
| 8.9 Verification of resistance to heat | 30 |
| 8.10 Verification of non-deterioration of contacts | 30 |
| 8.10.1 Arrangement of the fuse | 30 |
| 8.10.2 Test method | 31 |
| 8.10.3 Acceptability of test results | 31 |
| 8.11 Mechanical and miscellaneous tests | 31 |
| FIGURES | 32 |
| Fuse system I – gU fuse-links with wedge tightening contacts | 37 |
| 1 General | 37 |
| 1.1 Scope | 37 |
| 2 Terms and definitions | 37 |
| 3 Conditions for operation in service | 38 |
| 3.9 Discrimination of fuse-links | 38 |
| 4 Classification | 38 |

| | | |
|-------|---|----|
| 5 | Characteristics of fuses | 38 |
| 5.2 | Rated voltage | 38 |
| 5.3.1 | Rated current of the fuse-link..... | 38 |
| 5.5 | Rated power dissipation of a fuse-link | 38 |
| 5.6.1 | Time-current characteristics, time-current zones | 38 |
| 5.6.2 | Conventional times and currents..... | 39 |
| 5.6.3 | Gates | 39 |
| 5.7.2 | Rated breaking capacity | 39 |
| 5.8 | Cut-off current and I^2t characteristics..... | 39 |
| 6 | Markings | 39 |
| 6.1 | Markings of fuse-holders | 39 |
| 6.2 | Markings of fuse-links..... | 39 |
| 7 | Standard conditions for construction..... | 39 |
| 7.1 | Mechanical design..... | 39 |
| 7.2 | Insulating properties and suitability for insulation | 39 |
| 7.5 | Breaking capacity..... | 39 |
| 7.7 | I^2t characteristics..... | 40 |
| 7.8 | Overcurrent discrimination of the fuse-links..... | 40 |
| 8 | Tests | 40 |
| 8.1.1 | Kind of tests | 40 |
| 8.3.1 | Arrangement of the fuse | 40 |
| 8.3.3 | Measurement of the power dissipation of the fuse-link..... | 41 |
| 8.4.1 | Arrangement of the fuse | 41 |
| 8.5.1 | Arrangement of the fuse | 41 |
| 8.5.2 | Characteristics of the test circuit..... | 41 |
| 8.5.5 | Test method | 41 |
| 8.5.8 | Acceptability of test results..... | 41 |
| 8.7.3 | Verification of compliance for fuse-links at 0,01 s | 42 |
| 8.9 | Verification of resistance to heat | 42 |
| 8.11 | Mechanical and miscellaneous tests..... | 42 |
| | FIGURES | 43 |
| | Bibliography..... | 51 |
| | Figure 501 – Fuse-links for bolted connection – Sizes A, B, C and D (1 of 2) | 17 |
| | Figure 502 – Typical fuse-holder (1 of 2)..... | 19 |
| | Figure 503 – Time-current zones for "gG" fuse-link | 21 |
| | Figure 504 – Time-current zones for "gG" fuse-link | 22 |
| | Figure 505 – Power dissipation test rig | 23 |
| | Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2) | 24 |
| | Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3 | 32 |
| | Figure 702 – Typical fuse-holder..... | 33 |
| | Figure 703 – Time-current zones for "gG" fuse-links | 34 |
| | Figure 704 – Time-current zones for "gG" fuse-links | 35 |
| | Figure 705 – Power dissipation test rig | 36 |

| | |
|--|----|
| Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A..... | 43 |
| Figure 902 – Time-current zones for current ratings 160 A and 315 A..... | 44 |
| Figure 903 – Time-current zones for current ratings 250 A and 500 A..... | 45 |
| Figure 904 – Time-current zones for current ratings 200 A and 400 A..... | 46 |
| Figure 905 – Dimensions for fuse-links with L type and U type tags..... | 47 |
| Figure 906 – Power dissipation test rig..... | 48 |
| Figure 907 – Breaking capacity test rig (1 of 2)..... | 49 |
| | |
| Table 501 – Conventional time and current for "gG" fuse-links..... | 13 |
| Table 502 – Gates for specified pre-arcing times of "gG" fuse-links..... | 13 |
| Table 701 – Conventional time and current for "gG" fuse-links..... | 27 |
| Table 702 – Gates for specified pre-arcing times of "gG" fuse-links..... | 28 |
| Table 703 – Sizes of copper conductors..... | 29 |
| Table 704 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links..... | 29 |
| Table 901 – Maximum power dissipation values..... | 38 |
| Table 902 – Pre-arcing I^2t values for gU fuse-links at 0,01 s..... | 40 |
| Table 903 – Cross-sectional area of conductors for power dissipation and temperature-rise tests..... | 41 |

INTRODUCTION

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

- Part 1: General requirements
- Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K
- Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F
- Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- Part 5: Guidance for the application of low-voltage fuses
- Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

1 General scope

1.1 Scope

Fuses for use by authorized persons are generally designed to be used in installations where the fuse-links are accessible to, and may be replaced by, authorized persons only.

Fuses for use by authorized persons according to the following fuse systems also comply with the requirements of the corresponding subclauses of IEC 60269-1, unless otherwise defined in this standard.

This standard is divided into fuse systems, each dealing with a specific example of standardized fuses for use by authorized persons:

- Fuse system A: Fuses with fuse-links with blade contacts (NH fuse system)
- Fuse system B: Fuses with striker fuse-links with blade contacts (NH fuse system)
- Fuse system C: Fuse-rails (NH fuse system)
- Fuse system D: Fuse-bases for busbar mounting (NH fuse system)
- Fuse system E: Fuses with fuse-links for bolted connections (BS bolted fuse system)
- Fuse system F: Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)
- Fuse system G: Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)
- Fuse system H: Fuses with fuse-links having "gD" and "gN" characteristic (class J and class L time delay and non time delay fuse types)
- Fuse system I: gU fuse-links with wedge tightening contacts
- Fuse system J: Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)
- Fuse system K: gK fuse-links with blade for bolted connections – High fuse-link ratings from 1 250 A up to 4 800 A (master fuse-links)

☐ The following fuse systems are standardized systems in respect to their safety aspects. The National Committees shall select at least one complete fuse system of this European Standard for their national standards. The time current characteristics "gD" and "gN" are only relevant for the fuse system H. ☐