

BS 5499-10:2014



BSI Standards Publication

Guidance for the selection and use of safety signs and fire safety notices

bsi.

...making excellence a habit.™

Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2014

Published by BSI Standards Limited 2014

ISBN 978 0 580 78349 4

ICS 01.080.10, 13.220.01

The following BSI references relate to the work on this document:

Committee reference PH/8/1

Draft for comment 14/30260340 DC

Publication history

First published July 2006

Second (present) edition August 2014

Amendments issued since publication

Date	Text affected
-------------	----------------------

Contents

Introduction 1

- 1 Scope 2
- 2 Normative references 2
- 3 Terms and definitions 3
- 4 System design 5
- 5 Documentation 22
- 6 Training and education 22
- 7 Audit 22
- 8 Servicing and maintenance 22
- 9 Monitoring and review 23

Annexes

- Annex A (normative) Fire safety notices 25
 - Annex B (informative) Examples of application of distance factor for safety signs 31
 - Annex C (informative) Examples of the use of safety signs to indicate the location and identification of safety equipment, fire equipment and safe drinking water, and of the hierarchy of safety signs 41
- Bibliography 49

List of figures

- Figure 1 – Decision process 7
- Figure 2 – Examples of safety signs without supplementary text 12
- Figure 3 – Examples of combination safety signs with supplementary text 13
- Figure 4 – Examples of multiple signs with supplementary text 14
- Figure 5 – Zone of influence 16
- Figure 6 – Measurement of sign height 17
- Figure A.1 – Geometrical formats for fire safety notices and exclusion zones 25
- Figure B.1 – Circular boundaries of observation distances in horizontal plane 32
- Figure B.2 – Circular boundaries of observation distances in horizontal plane 33
- Figure B.3 – Variation of radius “r” against difference in observation height ΔH for an externally illuminated safety sign under 100 lux 34
- Figure B.4 – Circular boundaries of observation distances in horizontal plane: at eye level of sign and eye levels of ± 1 m above and below the height of sign 35
- Figure B.5 – Circular boundaries of observation distances for safety sign and lower case supplementary text in horizontal plane under a vertical illumination condition of 100 lux 36
- Figure B.6 – Circular boundaries of observation distances for safety sign and lower case supplementary text in horizontal plane when within 3 m distance from the sign under a vertical illumination condition of 100 lux 37
- Figure B.7 – Circular boundaries of observation distances for safety sign and lower case supplementary text in horizontal plane under a vertical illumination condition of 5 lux 38
- Figure B.8 – Circular boundaries of observation distances for safety sign and lower case supplementary text in horizontal plane when within 3 m distance from the sign under a vertical illumination condition of 5 lux 39
- Figure B.9 – Approaching a safety sign side-on: Circular boundaries of observation distances in horizontal plane: at eye level of sign and eye levels of ± 1 m above and below the height of sign 40
- Figure C.1 – Illustration of the use of a safety sign to identify a particular switch as being a first aid call point 41
- Figure C.2 – Illustration of the use of a safety sign to identify a particular telephone as being one for emergency use 42
- Figure C.3 – Illustration of the use of a safety sign to indicate the position of an emergency shower so that it can be located 43
- Figure C.4 – Illustration of the use of a safety sign to indicate that water from a particular tap is safe for drinking 44

- Figure C.5 – Illustration of the use of a safety sign to indicate the location of a first aid station 44
- Figure C.6 – Illustration of the use of a safety sign to indicate that a particular locker houses a stretcher 45
- Figure C.7 – Illustration of the use of a safety sign to identify the unit as being a fire alarm call point 45
- Figure C.8 – Illustration of the use of a multiple safety sign to identify the risk(s) and prohibited action(s) upon entering an oil/gas tank enclosure 46
- Figure C.9 – Illustration of the use of a safety sign to indicate the position of a fire extinguisher so that it can be located from a distance in a situation where other objects (in this case chairs) might distract the viewer 47
- Figure C.10 – Illustration of the use of a hierarchy of safety signs 48

List of tables

- Table 1 – Distance factor, z_0 , for externally illuminated safety signs based on ordinary materials or phosphorescent materials 18
- Table 2 – Distance factor, z_0 , for supplementary text of externally illuminated safety signs based on ordinary materials or phosphorescent materials 18
- Table 3 – Examples of maximum viewing distances/diameter of zones for identification of safety signs and legibility of supplementary text for externally illuminated safety signs of different sign height subject to a vertical illuminance of 100 lux 19
- Table 4 – Examples of maximum viewing distances/diameter of zones for identification of safety signs and legibility of supplementary text for externally illuminated safety signs of different sign height subject to a vertical illuminance of 5 lux 19
- Table A.1 – Examples of mandatory notices 26
- Table A.2 – Examples of fire equipment notices 28
- Table A.3 – Examples of maximum viewing distances/diameter of zones for legibility of text for externally illuminated fire safety notices of different height of lower case letters subject to a vertical illuminance of 100 lux or 5 lux 30

Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 50, an inside back cover and a back cover.

Foreword

Publishing information

This part of BS 5499 is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 31 August 2014. It was prepared by Subcommittee PH/8/1, *Safety signs*, under the authority of Technical Committee PH/8, *Graphical symbols*. A list of organizations represented on this committee can be obtained on request to its secretary.

Supersession

This part of BS 5499 supersedes BS 5499-10:2006, which is withdrawn.

Relationship with other publications

This part of BS 5499 is part of a series that contains the following current part:

- Part 4: *Code of practice for escape route signing*.

The original suite of standards on safety signs in BS 5499 included BS 5499-1, BS 5499-5, BS 5499-6 and BS 5499-11. They were all crosslinked. All have been superseded as follows:

- BS ISO 3864-1 supersedes BS 5499-1.
- BS ISO 3864-4 is new and covers material replacing that in the previous edition of ISO 3864-1, specifically the colour of safety signs.
- BS ISO 3864-3 supersedes BS 5499-6.
- BS EN ISO 7010 supersedes BS 5499-5.
- BS ISO 20712-1 supersedes BS 5499-11.

Information about this document

The purpose of this part of BS 5499 is to improve public safety by providing guidance on the use of safety signs and fire safety notices, excluding escape route signing, fire action notices and water safety signs.

The provisions of this standard are intended to be applied in situations in which a formal risk assessment has established the need for safety signs and fire safety notices.

This is a full revision of the standard and the principal changes are a consequence of the adoption of ISO 3864-1, ISO 3864-3 and ISO 3864-4 as British Standards and the graphical images of the registered safety signs in BS EN ISO 7010 with regard to colour specification and presentation. Fire safety notices are now included. Additional guidance is provided on viewing distances and viewing zones for safety signs and associated supplementary text, including the effects of viewing angle.

Use of this document

The colours represented in the electronic file of this British Standard can be neither viewed on screen nor printed as true representations. Although the copies of this British Standard have been produced to correspond (with an acceptable tolerance as judged by the naked eye) to the colour requirements, it is not intended that these printed copies be used for colour matching. Instead, colorimetric and photometric properties together with, as a guideline, references from colour order systems are provided in BS ISO 3864-4.

This part of BS 5499 takes the form of guidance and recommendations. It should not be quoted as if it were a specification and particular care should be taken to ensure that claims of compliance are not misleading.

Any user claiming compliance with this part of BS 5499 is expected to be able to justify any course of action that deviates from its recommendations.

It has been assumed in the preparation of this part of BS 5499 that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Presentational conventions

The provisions of this standard are presented in roman (i.e. upright) type. Its recommendations are expressed in sentences in which the principal auxiliary verb is "should".

Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.

The word "should" is used to express recommendations of this standard. The word "may" is used in the text to express permissibility, e.g. as an alternative to the primary recommendation of the clause. The word "can" is used to express possibility, e.g. a consequence of an action or an event.

Notes and commentaries are provided throughout the text of this standard. Notes give references and additional information that are important but do not form part of the recommendations. Commentaries give background information.

Contractual and legal considerations

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

Introduction

Safety signs and fire safety notices can make a major contribution to good communication and the development of good safety culture.

This code of practice is intended to assist the facilities manager of the premises and others responsible for selecting and installing safety signs and fire safety notices. This code of practice reflects best practice and shows how to use safety signs and fire safety notices in a standardized manner to ensure consistent application throughout a particular environment or an entire organization.

Safety signs using graphical symbols provide important benefits in the field of communication. Properly used they can:

- a) provide information in a compact form;
- b) provide information in a form that is independent of language;
- c) have visual impact; and
- d) guide the viewer to a desired outcome or appropriate decision.

However, these benefits are not always achieved in practice. If safety signs are used in a consistent manner they will become familiar to the viewers and thus be widely understood and effective. There might, however, be instances when optimum results can only be achieved by the provision of supplementary text. The use of the appropriate combination of safety signs with suitable supplementary text assists the process of education on the meaning of safety signs and the action(s) to be taken to control risk.

It is important that safety signs clearly convey the intended message to the viewers. In particular, safety signs need to clearly differentiate between information that relates to safety requirements (including those associated with unsafe use or misuse of products and equipment) and those that relate to public information.

A fire safety notice is a notice that consists of a specific geometrical format and colour with text to convey a specific action or identify specific types of fire equipment.

1 Scope

This part of BS 5499 provides guidance on how to select, install, position and maintain safety signs conforming to BS ISO 3864-1 and BS EN ISO 7010, excluding escape route signs, to present specific safety information. Fire safety notices are also covered in Annex A.

This part of BS 5499 satisfies the requirements of the Health and Safety (Safety Signs and Signals) Regulations 1996 [1] and the Regulatory Reform (Fire Safety) Order 2005 [2].

This part of BS 5499 is applicable to all premises, with the exception of private domestic premises. However, it is applicable to the common access areas within multi-occupied dwellings.

This part of BS 5499 is intended for use by building owners, facility managers of premises, safety managers and others responsible for selecting, installing and/or inspecting safety signs.

This part of BS 5499 is not applicable to:

- a) road traffic signs;
- b) public information symbols;
- c) actions to be taken in the event of a fire;
- d) International Maritime Organization symbols;
- e) labels provided under the Carriage of Dangerous Goods by Road Regulations 1996;
- f) labels provided under the International Maritime Dangerous Goods Code.

This part of BS 5499 does not give guidance on the use of escape route signs or water safety signs.

NOTE 1 A code of practice for the use of escape route signing is given in BS 5499-4.

NOTE 2 Specification of water safety signs and guidance for use are covered by BS ISO 20712-1 and BS ISO 20712-3 respectively.

NOTE 3 The illustrations in this standard are as accurate as possible within the limitations of the printing process.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 5266-1, *Emergency lighting – Part 1: Code of practice for the emergency escape lighting of premises*

BS EN ISO 7010, *Graphical symbols – Safety colours and safety signs – Registered safety signs (ISO 7010)*¹⁾

BS EN 60598-1, *Luminaires – Part 1: General requirements and tests*

BS ISO 3864-1:2011, *Graphical symbols – Safety colours and safety signs – Part 1: Design principles for safety signs and safety markings*

BS ISO 3864-3, *Graphical symbols – Safety colours and safety signs – Part 3: Design principles for graphical symbols for use in safety signs*

¹⁾ All current safety signs included in ISO 7010 and ISO amendments are available for viewing in the ISO OnLine Browsing Platform (OBP) [3], <https://www.iso.org/obp/ui/>.