



BSI Standards Publication

Energy losses by industrial door

National foreword

This Published Document is the UK implementation of CEN/TR 16676:2014.

The UK participation in its preparation was entrusted to Technical Committee B/538/5, Industrial and commercial garage doors and gates.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014. Published by BSI Standards Limited 2014

ISBN 978 0 580 83958 0

ICS 91.060.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 November 2014.

Amendments issued since publication

Date	Text affected
------	---------------

TECHNICAL REPORT
RAPPORT TECHNIQUE
TECHNISCHER BERICHT

CEN/TR 16676

October 2014

ICS 91.060.50

English Version

Energy losses by industrial door

Perte d'énergie par les portes industrielles

Energieverluste durch Industrietore

This Technical Report was approved by CEN on 28 July 2014. It has been drawn up by the Technical Committee CEN/TC 33.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Simplified calculation basis.....	5
3.1 Heat transmission with closed door by temperature difference	5
3.2 Air leakage with closed door by wind	6
3.3 Air leakage with closed door by chimney	7
3.4 Infiltration with door open (by wind).....	8
4 Results	10
4.1 General.....	10
4.2 Local/metrological data.....	10
4.3 Building/doors data (dimensions).....	11
4.4 Building data (intended use)	11
5 Results for heat transmission	13
6 Results for air leakage by wind.....	13
7 Results for air leakage by chimney effect.....	14
8 Infiltration (open door)	15
9 Summary.....	17

Foreword

This document (CEN/TR 16676:2014) has been prepared by Technical Committee CEN/TC 33 “Doors, windows, shutters, building hardware and curtain walling”, the secretariat of which is held by AFNOR.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

Introduction

The calculation method in EN 12428 gives a U -value in $W/m^2 \cdot K$ for thermal resistance of an industrial door used for access of vehicles accompanied by pedestrians.

With a view to energy efficiency (energy saving) it should be remembered, however, that this performance is only achieved when the door is closed.

In practice the evidence shows that doors are left open for longer periods than is perhaps necessary or acceptable. Therefore, it is difficult to see how reducing U -values can improve energy efficiency without radical changes in work place practices or operation mode of the door.

In keeping with the whole building approach mandated by the EPBD¹⁾ building designers should be working on a whole building principle rather than an elemental basis which results in a beneficial evaluation of those factors in the construction of the building envelope that contribute significantly to energy conservation in the buildings use.

Therefore, it is important that building designers and specification writers should seek to:

- set achievable values for products calculated in accordance with EN 13241-1;
- consider awareness of the classification possibilities and the availability and need to implement appropriate technologies;
- consider specifying improved power operated doors specification including appropriate control systems;
- consider changes to supporting constructions (e.g. lobbies, screens);
- consider the use of double doors (e.g. insulated external doors, rapid acting internal doors for operational use).

There is a common misconception that energy conservation is best achieved (only) through U -value improvements.

Due to the nonlinear shape of the U -value/thickness graph there is a danger of achieving diminishing returns from additional thickness of doors. Up to the present time, for the U -values commonly specified for construction in the EU, there has been an approximately linear relationship but as the move to seek lower U -values continues this is no longer the case.

Concern has been expressed that much of this good work is wasted as long as the practice of leaving doors open for unnecessarily long periods prevails.

Therefore, a study with a simplified calculation basis has been undertaken by CEN/TC 33/WG 5 relating to the energy losses through doors. This Technical Report does not replace the requirements of EN 13241-1 regarding EN 12428.

For the purpose of this Technical Report the term “door” and/or “doorset” is used as a general term for “industrial door”.

¹⁾ Energy Performance of Buildings Directive (Directive 2002/91/EC).

1 Scope

This Technical Report gives simplified calculation relating to the energy losses through doors taking into account:

- heat transmission with closed door by temperature difference,
- air leakage through a closed door due to wind,
- air leakage through a closed door due to a chimney effect, and
- air infiltration with a door open (due to wind).

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12428, *Industrial, commercial and garage doors - Thermal transmittance - Requirements for the calculation*

EN 13241-1, *Industrial, commercial and garage doors and gates - Product standard - Part 1: Products without fire resistance or smoke control characteristics*

3 Simplified calculation basis

3.1 Heat transmission with closed door by temperature difference

- Heat transmission coefficient U in $W/m^2 \cdot K$ is measured by notified bodies and calculated per door configuration (according to EN 13241-1).
- Outside temperature is taken out of Table 1.
- Heat transmission is then calculated with:

$$H_t = A \cdot U \cdot (T_i - T_o)$$

where

H_t is the power losses by heat transmission, in watts (W);

A is the area of exposed surface, in square metres (m^2);

T_i is the inside air temperature, in Celsius ($^{\circ}C$);

T_o is the outside air temperature, in Celsius ($^{\circ}C$).

- Energy losses per year will be calculated with:

$$E_t = \frac{h \cdot C_h \cdot H_t}{1000}$$