



BSI Standards Publication

**Electric cables –  
Thermosetting insulated,  
armoured, fire-resistant  
cables of rated  
voltage 600/1 000 V for  
fixed installations, having  
low emission of smoke and  
corrosive gases when  
affected by fire –  
Specification**

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2015

Published by BSI Standards Limited 2015

ISBN 978 0 580 86731 6

ICS 13.220.99; 29.060.20

The following BSI references relate to the work on this document:

Committee reference GEL/20

Draft for comment 15/30301742 DC

**Publication history**

First published September 1996

Second edition, October 2000

Third edition, September 2009

Fourth (current) edition, November 2015

**Amendments issued since publication**

<b>Date</b>	<b>Text affected</b>
-------------	----------------------

---

## Contents

1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Voltage designation and fire resistance categories	3
5	Conductors	5
6	Insulation	5
7	Identification of cores	5
8	Laying-up	7
9	Bedding	7
10	Armour	8
11	Oversheath	9
12	Cable marking and additional information	9
13	End sealing	12
14	Schedule of tests	13
15	Test conditions	14
16	Routine tests	14
17	Sample tests	15
18	Type tests	17

### Annexes

Annex A (informative)	Guide to use and installation of cables	22
Annex B (normative)	Armour wire tests	28
Annex C (normative)	Compatibility test	30
Annex D (normative)	Abrasion resistance test	31
Annex E (normative)	Insulation resistance constant test on oversheath	31
Annex F (normative)	Resistance of armour	32
Annex G (informative)	Gross cross-sectional area of armour	33
Annex H (normative)	Test for shrinkage of oversheath	34
Annex I (normative)	Fire resistance test for category F2 – Additional provisions for cables with a diameter over 20 mm	35
Annex J (informative)	Guidance on type tests	37

Bibliography	41
--------------	----

### List of figures

Figure 1	– An example of the marking on the oversheath of the cable	11
Figure I.1	– Method of mounting a sample for test for resistance to fire with mechanical shock	36

### List of tables

Table 1	– Maximum permitted voltages against rated voltage of cable	4
Table 2	– Diameter of armour wire and mass of zinc coating	8
Table 3	– Schedule of tests	13
Table 4	– Two core 600/1 000 V cables with copper conductors	18
Table 5	– Three core 600/1 000 V cables with copper conductors	19
Table 6	– Four core 600/1 000 V cables with copper conductors	20
Table 7	– Five core 600/1 000 V cables with copper conductors	21
Table 8	– Multicore auxiliary 600/1 000 V cables with copper conductors	21
Table A.1	– Selection of cables for a.c. systems	23
Table A.2	– Test voltages after installation	28
Table B.1	– Temperature correction multiplication factors	29
Table C.1	– Compatibility requirements	30
Table D.1	– Vertical load requirements	31
Table F.1	– Maximum resistance of armour for two-, three-, four- and five-core cable	32

Table F.2 – Maximum resistance of armour for 600/1 000 V multicore auxiliary cables 32

Table G.1 – Gross cross-sectional area of armour wires for the two-, three-, four- and five-core 600/1 000 V cable 33

Table G.2 – Gross cross-sectional area of armour wires for 600/1 000 V multicore auxiliary cable 33

Table J.1 – Test schedule for the smoke emission test 38

**Summary of pages**

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 42, an inside back cover and a back cover.

## Foreword

### Publishing information

This British Standard is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 30 November 2015. It was prepared by Technical Committee GEL/20, *Electric cables*. A list of organizations represented on this committee can be obtained on request to its secretary.

### Supersession

This British Standard supersedes BS 7846:2009, which will be withdrawn on 1 December 2016.

### Information about this document

This is a full revision of the standard, and introduces the following principal changes.

- a) Interlocked tape armour has been removed as it no longer has market relevance.
- b) 48 core auxiliary cables have been removed as they are no longer market relevant.
- c) The marking requirements have been updated and clarified.
- d) The guide to use given in Annex A has been updated to reflect modern installation practice and the recommendations in BS 8519:2010.
- e) Test methods have been updated in accordance with the latest BS EN standards.

The new edition takes account of:

- BS EN 50363 (replacing certain parts of BS 7655) on materials;
- BS EN 50395 (replacing Annex K of BS 7846:2009) on electrical tests;
- BS EN 50396 (replacing Annex D of BS 7846:2009) on thickness measurement;
- BS EN 60332-1-2 (replacing BS EN 50265-2-1);
- BS EN 60332-3-24 (replacing BS EN 50266-2-4);
- BS EN 62230 (replacing BS EN 50356 and BS 5099) on spark testing.

### Product certification/inspection/testing

Users of this British Standard are advised to consider the desirability of third-party certification/inspection/testing of product conformity to this British Standard. Users seeking assistance in identifying appropriate conformity assessment bodies or schemes may ask BSI to forward their enquiries to the relevant association.

### Hazard warnings

**WARNING.** This British Standard calls for the use of substances and/or procedures that can be injurious to health if adequate precautions are not taken. It refers only to technical suitability and does not absolve the user from legal obligations relating to health and safety at any stage.

### **Use of this document**

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

### **Presentational conventions**

The provisions of this standard are presented in roman (i.e. upright) type. Its requirements are expressed in sentences in which the principal auxiliary verb is "shall".

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

### **Contractual and legal considerations**

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**

## 1 Scope

This British Standard specifies requirements for construction and performance of thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V having low emission of smoke and corrosive gases when affected by fire.

This British Standard is applicable to cables for use in fixed installations in industrial areas, buildings or similar applications, where maintenance of power supply during a fire is required for a defined period of time.

This British Standard specifies requirements for the following types of cables:

- a) wire armoured and oversheathed cables with two-, three-, four- or five-cores, and with stranded copper conductor;
- b) multicore auxiliary cables, wire armoured and oversheathed, with stranded copper conductor.

This British Standard specifies four categories of cables based on their performance in tests which assess separately resistance to fire, resistance to fire with water spray and resistance to fire with mechanical shock (Category F2) and which assess resistance to fire with direct mechanical impact and water jet in combination (Categories F30, F60 and F120).

This British Standard is applicable to cables that are designed for a maximum sustained conductor temperature of 90 °C and for a maximum short-circuit conductor temperature of 250 °C (for a maximum of 5 s).

*NOTE 1 Limitation on the temperature of the cables might be imposed in situations where they may be touched or where they could touch other materials.*

*NOTE 2 Annex A gives the guide to use, Annex B gives armour wire tests, Annex C gives compatibility test, Annex D gives abrasion test, Annex E gives insulation resistance constant test on oversheath, Annex F gives resistance of conductor and armour, Annex G gives gross cross-sectional area of armour, Annex H gives a test for shrinkage of oversheath, Annex I gives the fire resistance test for category F2 – additional provisions for cables with a diameter over 20 mm, and Annex J gives notes on type tests.*

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 6387, *Test method for resistance to fire of cables required to maintain circuit integrity under fire conditions*

BS 7655-1.2, *Specification for insulating and sheathing materials for cables – Part 1: Cross-linked elastomeric insulating compounds – Section 2: General 90°C application*

BS 7655-1.3, *Specification for insulating and sheathing materials for cables – Part 1: Elastomeric insulating compounds – Section 3: XLPE*

BS 7655-6.1, *Specification for insulating and sheathing materials for cables – Part 6: Thermoplastic sheathing compounds having low emission of corrosive gases, and suitable for use in cables having low emission of smoke when affected by fire – Section 1: General application thermoplastic types*

BS 7671, *Requirements for electrical installations – IET Wiring Regulations – Seventeenth edition*