



CGA P-15—2016
STANDARD FOR THE FILLING
OF INDUSTRIAL AND MEDICAL
NONFLAMMABLE
COMPRESSED GAS CYLINDERS

FIFTH EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 09-013
Medical Gases Committee

NOTE—Due to the extensive changes in this document, technical changes from the previous edition are not identified.

NOTE—Appendix A (Informative) is for information only.

NOTE—Appendices B and C (Normative) are a requirement.

FIFTH EDITION: 2016
FOURTH EDITION: 2005
THIRD EDITION: 1999

SECOND EDITION: 1993 (SECOND PRINTING: 1997)

© 2016 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	1
4 Cylinder specifications.....	4
5 Prefill inspection of compressed gas cylinders.....	5
5.1 Visual inspection.....	5
5.2 Cylinder markings.....	6
5.3 Valve inspection	11
5.4 Hammer (dead ring) test.....	12
5.5 Testing for internal contaminants	13
6 Cylinder labeling	14
7 Cylinder filling	14
7.1 Preparation for cylinder filling	14
7.2 Venting of residual gas.....	15
7.3 Cylinder filling of nonflammable, nonliquefied compressed gases.....	15
7.4 Cylinder filling of nonflammable, liquefied compressed gases	18
8 Quality control	20
8.1 Analytical testing.....	20
8.2 General considerations.....	20
8.3 Analytical program for medical gas products.....	21
8.4 Analytical program for food gas products	21
8.5 Analytical program for breathing air.....	21
9 References	21
 Figures	
Figure 1—Example of UN steel cylinder regulatory markings.....	7
Figure 2—Example of UN aluminum alloy cylinder regulatory markings	7
Figure 3—Example of DOT/TC steel cylinder regulatory markings	8
Figure 4—Example of DOT/TC aluminum alloy cylinder regulatory markings	8
 Table	
Table 1—Requalification schedule.....	10
 Appendices	
Appendix A—Example of high pressure and liquefied cylinder fill checklist for use by gas suppliers	24
Appendix B—Temperature-pressure filling charts (U.S. customary units).....	25
Appendix C—Temperature-pressure filling chart (Metric).....	30
 Appendices Tables	
Table B-1—Compressed air temperature-pressure filling chart.....	25
Table B-2—Argon temperature-pressure filling chart.....	26
Table B-3—Helium temperature-pressure filling chart	27
Table B-4—Nitrogen temperature-pressure filling chart.....	28
Table B-5—Oxygen temperature-pressure filling chart.....	29
Table C-1—Compressed air temperature-pressure filling chart.....	30
Table C-2—Argon temperature-pressure filling chart	31
Table C-3—Helium temperature-pressure filling chart.....	32
Table C-4—Nitrogen temperature-pressure filling chart	33
Table C-5—Oxygen temperature-pressure filling chart.....	34

This page is intentionally blank.

1 Introduction

Compressed gas cylinders are filled and used each day without incidents and have been for many years. There is no reason why cylinders cannot be filled safely and be safe for consumers to use if procedures are followed that recognize and control the possible hazards associated with the filling and use of compressed gas cylinders.

The filling of compressed gas cylinders requires complying with all applicable federal, state, provincial, and local regulations. Personnel shall be familiar with these regulatory requirements. In addition to the requirements for industrial gases, medical and food gases require compliance with additional regulations. These requirements are addressed in other CGA publications.

2 Scope

This publication describes the recommended industry practices and precautionary measures for filling certain liquefied and nonliquefied, nonflammable industrial, medical and food gas cylinders not exceeding 125 lb (57 kg) water capacity. It should not be assumed that every safety precaution is included here. This publication does not cover equipment design specifications to perform these filling operations.

This publication only covers the filling of DOT 3A, DOT 3AA, DOT 3AL, TC 3AM, TC 3AAM, TC 3ALM, authorized United Nations (UN) equivalents for these cylinders, and aluminum composite cylinders with the following gases: air, argon, carbon dioxide, helium, nitrogen, nitrous oxide, and oxygen.

This publication does not address automated or palletized cylinder filling operations or the filling of cylinders that are clustered or bundled.

This publication does not cover the filling of the following cylinders:

- Insulated refrigerated liquid cylinders such as DOT 4L and home cryogenic oxygen base units, with cryogenic liquids or refrigerated liquids. The filling of these cylinders are addressed in other CGA publications;
- Portable high pressure cylinders from other high pressure cylinders, either gas to gas (e.g., oxygen) or liquefied compressed gas to liquefied compressed gas (e.g., carbon dioxide), commonly known as transfilling; and
- Portable high pressure cylinders from home oxygen concentrators.

This publication does not cover the filling of:

- gas mixtures of any type, including reconstituted or blended air used for breathing or other purposes; and
- flammable, specialty, or liquefied petroleum gases that require additional procedures and special precautions to be taken.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.