



BSI Standards Publication

# **LV and MV polymeric insulated cables for use by distribution and generation utilities**

Part 4: Specification for distribution  
cables with extruded insulation of  
rated voltages of 11 kV to 33 kV

Section 4.10: Single-core 11 kV to  
33 kV cables

(Implementation of HD 620)

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2016

Published by BSI Standards Limited 2016

ISBN 978 0 580 93805 4

ICS 29.060.20

The following BSI references relate to the work on this standard:

Committee reference GEL/20/16

Drafts for comment 11/30214073 DC, 16/30339580 DC

**Publication history**

First published August 1999

Second (present) edition, December 2011

**Amendments/corrigenda issued since publication**

Date	Text affected
August 2012	C.1
June 2016	A.1 See foreword

## Contents

Foreword *ii*

<b>1</b>	Scope	1
<b>2</b>	Normative references	1
<b>3</b>	Voltage designation	2
<b>4</b>	Construction and dimensions	2
<b>5</b>	Tests	9
<b>6</b>	Routine tests	11
<b>7</b>	Sample tests	12
<b>8</b>	Type tests	14

### Annexes

Annex A (informative)	Guide to selection and use of cables	19
Annex B (normative)	Information to be supplied and items to be agreed	20
Annex C (informative)	Guidance on type tests	20
Annex D (normative)	Measurement of moisture content of water blocking tape	22
Bibliography		23

### List of tables

Table 1	– Thickness of insulation	3
Table 2	– 6.35/11 kV single-core copper wire screened cables	7
Table 3	– 12.7/22 kV single-core copper wire screened cables	7
Table 4	– 19/33 kV single-core copper wire screened cables	8
Table 5	– Schedule of tests	9
Table 6	– D.C resistance of metallic screen	11
Table 7	– Compatibility requirements	16
Table 8	– Tan $\delta$ in relation to voltage	17
Table 9	– Tan $\delta$ in relation to temperature	17
Table 10	– Impulse test voltage	18
Table 11	– Long duration wet ageing requirements	18
Table A.1	– Guide to use	19

### Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 24, an inside back cover and a back cover.

## Foreword

### Publishing information

This section of BS 7870 is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 31 December 2011. It was prepared by Subcommittee GEL/20/16, *Medium/High voltage cables*, under the authority of Technical Committee GEL/20, *Electric cables*. A list of organizations represented on these committees can be obtained on request to their secretary.

### Supersession

BS 7870-4.10:2011+A1:2016 supersedes BS 7870-4.10:2011, which is withdrawn.

### Relationship with other publications

BS 7870 implements the nationally applicable parts of Harmonization Documents HD 603, 605, 620, 626 and 627 published by the European Committee for Electrotechnical Standardization (CENELEC) in accordance with the decision of the CENELEC Technical Board.

BS 7870 applies to cables for fixed installations having a rated voltage  $U_0/U$  up to and including 19/33 kV, and is published as a series of separate parts and sections, as listed in the table in the foreword of BS 7870-1.

This section of BS 7870 implements Part 10O and Part 11O of HD 620 S2, and is to be read in conjunction with BS 7870-1 and BS 7870-2.

### Information about this document

BS 7870-4.10:2011 was a full revision of the standard, and brought the standard up to date in accordance with current practice in the industry.

The start and finish of text introduced or altered by Amendment No. 1 is indicated in the text by tags **A1** **A1**. Minor editorial changes are not tagged.

A general guide to use for the types of cables specified in BS 7870 is given in BS 7870-1 and specific details for the types of cables specified in this section of BS 7870 are given in Annex A.

### Hazard warnings

**WARNING.** This British Standard calls for the use of substances and/or procedures that can be injurious to health if adequate precautions are not taken. It refers only to technical suitability and does not absolve the user from legal obligations relating to health and safety at any stage.

### Use of this document

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

### Presentational conventions

The provisions of this standard are presented in roman (i.e. upright) type. Its requirements are expressed in sentences in which the principal auxiliary verb is "shall".

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

**Contractual and legal considerations**

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**



## 1 Scope

This section of BS 7870 specifies requirements for the construction, dimensions and mechanical and electrical properties of 6.35/11(12) kV to 19/33(36) kV single-core cables having either aluminium or copper conductors, cross-linked polyethylene (XLPE) or ethylene propylene rubber (EPR) extruded insulation, a copper wire metallic screen and an oversheath of one of the following compounds:

- a) medium density polyethylene (MDPE) compound type DMP 5 (Type A cables);
- b) thermoplastic compound type DMZ 4 for cables with having a low emission of smoke and corrosive gases when affected by fire (Type B cables).

The standard also specifies requirements for 11 kV cables laid up in a triplex formation.

This section of BS 7870 is applicable to cables that are designed for a maximum continuous conductor operating temperature of 90 °C and for a maximum short-circuit conductor temperature of 250 °C.

*NOTE Information to be supplied by the purchaser, and items to be agreed between the purchaser and the manufacturer at the time of enquiry and/or order are given in Annex B. Guidance on type testing is given in Annex C.*

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 3988:1970+A3:1989, *Specification for wrought aluminium for electrical purposes – Solid conductors for insulated cables*

BS 7870-1, *LV and MV polymeric insulated cables for use by distribution and generation utilities – Part 1: General*

BS 7870-2, *LV and MV polymeric insulated cables for use by distribution and generation utilities – Part 2: Methods of test*

BS EN 50267-2-1, *Common test methods for cables under fire conditions – Tests on gases evolved during combustion of materials from cables – Part 2-1: Procedures – Determination of the amount of halogen acid gas*

BS EN 60228:2005, *Specification for conductors in insulated cables and cords*

BS EN 60332-1-2:2004, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

BS EN 60332-3-24:2009, *Tests on electric and optical fibre cables under fire conditions – Part 3-24: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category C*

BS EN 60811-1-2, *Insulating and sheathing materials of electric and optical cables – Common test methods – Part 1-2: General application – Thermal ageing methods*

BS EN 60811-1-3, *Insulating and sheathing materials of electric and optical cables – Common test methods – Part 1-3: General application – Methods for determining the density – Water absorption tests – Shrinkage test*