



**ANSI B109.4**  
Approved  
Revised December 2016

## **Self-Operated Diaphragm-Type Natural Gas Service Regulators**

For Nominal Pipe Size 1¼ inches (32 mm) and smaller  
with outlet pressures of 2 psig (13.8 kPa) and less

### **Secretariat**



400 North Capitol Street, NW 4<sup>th</sup> Floor  
Washington, DC 20001  
U.S.A.

**Catalog No. XM1602**

First Edition–1998  
Second Edition–2016

Copyright © 2016, American Gas Association  
All rights reserved

## Table of Contents

<b>TABLE OF CONTENTS</b> .....	<b>i</b>
<b>DISCLAIMERS AND COPYRIGHT</b> .....	<b>ii</b>
<b>PREFACE</b> .....	<b>iv</b>
<b>HISTORY OF DEVELOPMENT OF THE STANDARD</b> .....	<b>v</b>
<b>ACCREDITED STANDARDS COMMITTEE B109</b> .....	<b>vi</b>
<b>1.0 Scope</b> .....	<b>1</b>
<b>2.0 Definitions</b> .....	<b>2</b>
<b>3.0 General</b> .....	<b>5</b>
<b>4.0 Design Requirements</b> .....	<b>6</b>
4.1 Regulator Valve Body .....	6
4.2 Diaphragm Casing Assembly .....	7
4.3 Diaphragm .....	8
4.4 Loading Spring .....	8
4.5 Valve Linkage and Disk .....	8
4.6 Orifice .....	9
4.7 Exterior Surface .....	9
4.8 Vent .....	10
4.9 Markings .....	11
<b>5.0 Qualification Test for Service Regulator Performance</b> .....	<b>12</b>
5.1 General .....	12
5.2 Test Equipment .....	13
5.3 Test Procedures .....	13
<b>APPENDIX A: GUIDELINES FOR PRESENTATION OF REGULATOR PERFORMANCE DATA</b> .....	<b>24</b>
<b>APPENDIX B: SI/METRIC SYMBOLS</b> .....	<b>28</b>
<b>APPENDIX C: U.S. (INCH-POUND) SYMBOLS</b> .....	<b>29</b>
<b>APPENDIX D: REFERENCED STANDARDS</b> .....	<b>30</b>
<b>FORM FOR PROPOSALS ON ANSI B109.4</b> .....	<b>31</b>

## **AMERICAN GAS ASSOCIATION (AGA) NOTICE AND DISCLAIMER**

*This document was developed through a voluntary consensus standards development process via the American National Standards Institute (ANSI) essential requirements for due process for American National Standards (Edition January 2014). While the American Gas Association (AGA) administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document, and it does not independently test, evaluate or verify the accuracy or completeness of any information or the soundness of any judgments contained in this publication.*

*The AGA disclaims liability for any personal injury, property damages or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from this publication, the use of or reliance on this publication. The AGA also makes no guarantee or warranty as to the accuracy or completeness of any information published herein.*

*In issuing and making this document available, the AGA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the AGA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.*

*The AGA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the AGA list, certify, test or inspect products, designs or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the AGA and is solely the responsibility of the certifier or maker of the statement.*

*The AGA does not take any position with respect to the validity of any patent rights asserted in connection with any items that are mentioned in or are the subject of this publication, and the AGA disclaims liability for the infringement of any patent resulting from the use of or reliance on it. Users of this publication are expressly advised that determination of the validity of any such patent rights and the risk of infringement of such rights is entirely their own responsibility.*

*Users of this publication should consult applicable federal, state, and local laws and regulations. The AGA does not, through this publication, provide legal advice for any purpose or intend to urge action that is not in compliance with applicable laws and this publication may not be construed as doing so.*

*Changes to this document may become necessary from time to time. If changes are believed appropriate by any person or entity, such suggested changes should be communicated to AGA in writing using the form found at the end of the document titled, Form For Proposals on ANSI B109.4 and sent to: American Gas Association, ATTN: Secretariat B109, 400 North Capitol Street, NW, Suite 450, Washington, DC 20001, U.S.A. Suggested changes must include: contact information, including name, address and any corporate affiliation; full name of the document; suggested revisions to the text of the document; the rationale for the suggested revisions; and permission to use the suggested revisions in an amended publication of the document.*

**Copyright © 2016 American Gas Association, All Rights Reserved.**

*Permission is granted to republish material herein in laws or ordinances as well as regulations, administrative orders or similar documents issued by public authorities. Those desiring permission for other publication should consult the American Gas Association, ATTN: ANSI B109.4 Secretariat, 400 N. Capitol St., NW, Washington, DC, U.S.A.*

## PREFACE

This publication presents a basic standard for the safe and reliable operation and the substantial and durable construction of self-operated diaphragm-type natural gas service regulators for nominal pipe size of 1¼ inches (32 mm) and smaller with outlet pressure of 2 psig (3.48 kPa) and less. This work is the result of years of experience that has been supplemented by extensive research. The standard is intended to meet the minimum design, material, performance and testing requirements for efficient use of service regulators.

It is recognized that during any transition period to the metric system, sizes and dimensions need to be expressed in either the metric system or the inch-pound system or both. In this document, both systems are used with the inch-pound units given preference. In most cases, a soft conversion from existing inch-pound values is shown. Soft conversion implies a change in nomenclature only. In this document, the alternative nomenclatures (metric and inch-pound) are shown by using parentheses and can be used interchangeably.

Nothing in this standard is to be considered as in any way indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow the construction and performance of service regulators that may exceed the various provisions specified in any respect. In this standard's preparation, recognition was intended to be given to the possibility of improvement, through the ingenuity of design or otherwise. As progress takes place, revisions may become necessary. Whenever such revisions are believed desirable, recommendations should be forwarded to the Chairman of ANSI B109 Committee, American Gas Association, 400 N. Capitol St., NW, Washington, DC 20001

Users of this document should consult applicable federal, state and local regulations. The AGA does not, by the publication of this document, intend to present specifications that are not in compliance with applicable rules, and this document may not be construed as doing so.

NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute Inc. (ANSI) require that action is taken to reaffirm, revise or withdraw this standard no later than five years from the date of publication. Whenever any revisions are deemed advisable, recommendations should be forwarded to the **American Gas Association**. A form is included for that purpose at the end of this standard. Purchasers of American National Standards may receive current information on all standards by writing to the **American National Standards Institute Inc.**, 11 West 42<sup>nd</sup> Street, New York, NY 10036, U.S.A.; by calling (212) 642-4900; by faxing ANSI at (212) 398-0023; or by visiting ANSI's website at <http://www.ansi.org>. To purchase additional copies, visit Techstreet's website at <http://www.techstreet.com/aga>.

## **HISTORY OF DEVELOPMENT OF THE STANDARD FOR SELF-OPERATED DIAPHRAGM-TYPE GAS SERVICE REGULATORS**

In December 1989 at an ad hoc meeting, representatives of the ANSI Z223.1 and Z21 committees, AGA, Gas Appliance Manufacturers Association (GAMA) and several other industry organizations recommended that an ANSI standard for service regulators be developed. It was recognized that a systems approach to pressure control and over-pressure protection was necessary to ensure consistency between the ANSI standards that cover the houseline and the utilization equipment. In April 1990, a revision that added service regulators to the scope of ANSI B109 ASC was approved.

The AGA Operating Section assembled a service regulator standard development task group with representatives from the AGA Distribution Measurement Committee, Customer Service and Utilization Committee, Distribution Engineering Committee and the major service regulator manufacturers. A representative from the Committee on Canadian Gas Service Regulator Standard was also included. Throughout the development, consideration was given to harmonizing the new standard with the Canadian standard. A first draft was completed in 1993. The draft was revised a number of times and was approved by the AGA Operating Section before it was presented to the ANSI B109 Accredited Standard Committee in January 1996.

The ANSI B109 Accredited Standard Committee requested comments on the proposed service regulator standard in May 1996. During a public meeting on Jan. 30, 1997, the committee addressed the comments and approved the standard for submittal to ANSI for endorsement as an American National Standard.

## **ACCREDITED STANDARDS COMMITTEE B109**

### **CHAIR**

**WINSTON MEYER, CenterPoint Energy**

### **REPRESENTING USERS**

Winston Meyer, CenterPoint Energy  
Cathy Chang, Southern California Gas Co.  
Fred Maly, Spire Inc.  
Philip DiGiglio, National Grid PLC  
Patrick Donnelly, NiSource  
Benedict Sherman, Xcel Energy

### **REPRESENTING PRODUCERS**

John Anderson, Emerson Electric Co.  
Bob Bennett, Honeywell International Inc.  
Jon Fickinger, Itron Inc.  
John Michalak, Romet Ltd.  
Ron Strong, General Electric  
Chris Wykle, Sensus USA Inc.

### **REPRESENTING GENERAL INTEREST**

Terry Grimley, Southwest Research Institute  
Scott Merritt, Federal Energy Regulatory Commission  
Ralph Richter, National Institute of Standards & Technology  
Bruce Swiecicki, National Propane Gas Association  
Ardis Bartle, Apex Measurement & Controls LLC

### **SECRETARY**

Michael P. Stablein, Secretariat

## **1.0 Scope**

This standard shall apply to the minimum design, material, performance and testing requirements of 1¼ inches (32 mm) and smaller self-operated diaphragm-type natural gas service regulators operating at inlet pressures up to 125 psig (861.8 kPa). These regulators are used to control the gas delivery pressure (also referred to as set pressure or  $P_2$ ) to pressures at 2 psig or less (13.8 kPa). This standard shall apply only to regulators manufactured after the approval date of this standard.