

FINAL VERSION

VERSION FINALE

Electricity metering equipment (a.c.) – General requirements, tests and test conditions –

Part 11: Metering equipment

Équipement de comptage de l'électricité (c.a.) – Prescriptions générales, essais et conditions d'essai –

Partie 11: Équipement de comptage

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
INTRODUCTION TO AMENDMENT 1	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	10
3.1 General definitions	10
3.2 Definitions related to the functional elements	12
3.3 Definitions of mechanical elements	13
3.4 Definitions related to insulation	14
3.5 Definitions of meter quantities	15
3.6 Definitions of influence quantities	16
3.7 Definition of tests	17
3.8 Definitions related to electromechanical meters.....	17
4 Standard electrical values	18
4.1 Standard reference voltages.....	18
4.2 Standard currents.....	18
4.3 Standard reference frequencies.....	19
5 Mechanical requirements and tests	19
5.1 General mechanical requirements	19
5.2 Case	19
5.3 Window	20
5.4 Terminals – Terminal block(s) – Protective earth terminal	20
5.5 Terminal cover(s)	20
5.6 Clearance and creepage distances.....	20
5.7 Insulating encased meter of protective class II	20
5.8 Resistance to heat and fire.....	21
5.9 Protection against penetration of dust and water	21
5.10 Display of measured values.....	21
5.11 Output device	21
5.12 Marking of meter	22
6 Climatic conditions	24
6.1 Temperature range.....	24
6.2 Relative humidity.....	24
6.3 Tests of the effect of the climatic environments	24
7 Electrical requirements.....	25
7.1 Influence of supply voltage	25
7.2 Heating	26
7.3 Insulation	26
7.4 Immunity to earth fault.....	27
7.5 Electromagnetic compatibility (EMC)	27
8 Type test	31
8.1 Test conditions.....	31
Annex A (normative) Relationship between ambient air temperature and relative humidity.....	32

Annex B (normative) Voltage wave-form for the tests of the effect of voltage dips and short interruptions.....	33
Annex C (normative) Test circuit diagram for the test of immunity to earth fault	34
Annex D (normative) Optical test output.....	35
Annex E (informative) Test set-up for EMC tests.....	36
Annex F (informative) Test schedule – Recommended test sequences	38
Bibliography.....	40
Figure B.1 – Voltage interruptions of $\Delta U = 100\%$, 1 s.....	33
Figure B.2 – Voltage interruptions of $\Delta U = 100\%$, one cycle at rated frequency	33
Figure B.3 – Voltage dips of $\Delta U = 50\%$	33
Figure C.1 – Circuit to simulate earth fault condition in phase 1	34
Figure C.2 – Voltages at the meter under test.....	34
Figure D.1 – Test arrangement for the test output.....	35
Figure D.2 – Waveform of the optical test output.....	35
Figure E.1 – Test set-up for the test of immunity to electromagnetic RF fields	36
Figure E.2 – Test set-up for the fast transient burst test: Voltage circuits	36
Figure E.3 – Test set-up for the fast transient burst test: Current circuits	37
Table 1 – Standard reference voltages.....	18
Table 2 – Standard reference currents	18
Table 4 – Voltage marking	23
Table 5 – Temperature range.....	24
Table 7 – Voltage range.....	25
Table 8 – Change of error due to earth fault	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING EQUIPMENT (AC) –
GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –****Part 11: Metering equipment**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62052-11 bears the edition number 1.1. It consists of the first edition (2003-02) [documents 13/1285/FDIS and 13/1292/RVD] and its amendment 1 (2016-11) [documents 13/1700/FDIS and 13/1714/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 12. A separate Redline version with all changes highlighted is available in this publication.

.

International Standard IEC 62052-11 has been prepared by IEC technical committee 13: Equipment for electrical energy measurement and load control.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 2 years from the date of publication.

INTRODUCTION

This part of IEC 62052 is to be used with relevant parts of the IEC 62052, IEC 62053 and IEC 62059 series, Electricity metering equipment:

IEC 62052-31:2015, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

IEC 62053-11:2002, *Electricity metering equipment (a.c.) – Particular requirements – Part 11: Electromechanical meters for active energy (classes 0,5, 1 and 2)* Replaces particular requirements of IEC 60521:1988 (2nd edition)

IEC 62053-21: 2002, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)* Replaces particular requirements of IEC 61036: 2000 (2nd edition)

IEC 62053-22:2002, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)* Replaces particular requirements of IEC 60687:1992 (2nd edition)

IEC 62053-23:2002, *Electricity metering equipment (a.c.) – Particular requirements – Part 23: Static meters for reactive energy (classes 2 and 3)* Replaces particular requirements of IEC 61268:1995 (1st edition)

IEC 62053-24:2014, *Electricity metering equipment (AC) – Particular requirements – Part 24: Static meters for reactive energy (classes 0,5 S, 1 S and 1)*

IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*

IEC 62053-61:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 61: Power consumption and voltage requirements*

IEC 62059-11:2002, *Electricity metering equipment (a.c.) – Dependability – Part 11: General concepts*

IEC 62059-21:2002, *Electricity metering equipment (a.c.) – Dependability – Part 21: Collection of meter dependability data from the field*

This part is a standard for type testing electricity meters. It covers the general requirements for “normal meters”, being used indoors and outdoors in large quantities worldwide. It does not deal with special implementations (such as metering-part and/or displays in separate housings).

This standard is intended to be used in conjunction with the appropriate part of IEC 62053 for the type of equipment under consideration.

This standard distinguishes between

- meters intended to be used indoors and outdoors; and
- protective class I and protective class II meters;
- meters for use in networks equipped with or without earth fault neutralizers.

The test levels are regarded as minimum values to guarantee the proper functioning of the meter under normal working conditions. For special application, other test levels might be necessary and should be agreed upon between the user and the manufacturer.

INTRODUCTION TO AMENDMENT 1

The purpose of this amendment is to identify and remove all safety related requirements and tests of IEC 62052-11:2003 that are replaced and extended by the complete set of requirements and tests in IEC 62052-31:2015.

ELECTRICITY METERING EQUIPMENT (AC) – GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –

Part 11: Metering equipment

1 Scope

This part of IEC 62052 covers type tests for electricity metering equipment for indoor and outdoor application and applies to newly manufactured equipment designed to measure the electrical energy on 50 Hz or 60 Hz networks, with a voltage up to 600 V.

It applies to electromechanical or static meters for indoor and outdoor application consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s). If the meter has a measuring element for more than one type of energy (multi-energy meters), or when other functional elements, such as maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces, etc. are enclosed in the meter case, then the relevant standards for these elements apply.

It does not apply to:

- a) portable meters;
- b) data interfaces to the register of the meter;
- c) reference meters.

For rack-mounted meters, the mechanical properties are not covered in this standard.

The safety aspect is covered by IEC 62052-31:2015.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:1983, *IEC standard voltages*
Amendment 1:1994,
Amendment 2:1997

IEC 60044-1:1996, *Instrument transformers – Part 1: Current transformers*

IEC 60044-2:1997, *Instrument transformers – Part 2: Inductive voltage transformers*

IEC 60050-300:2001, *International Electrotechnical Vocabulary – Electrical and electronic measurements and measuring instruments – Part 311: General terms relating to measurements – Part 312: General terms relating to electrical measurements – Part 313: Types of electrical measuring instruments – Part 314: Specific terms according to the type of instrument*

IEC 60068-2-1:1990, *Environmental testing – Part 2: Tests – Tests A: Cold*
Amendment 1:1993,
Amendment 2:1994