



PROCESS
INDUSTRY
PRACTICES

TECHNICAL REVISION
April 2017

Hygienic Process

**PIP PHCM0001
Hygienic Process Piping Line Class
Designator System**

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/ purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PRINTING HISTORY

April 2014 *Issued*
April 2017 *Technical Revision*

Not printed with State funds



PIP PHCM0001 Hygienic Process Piping Line Class Designator System

Table of Contents

1. Introduction	2
1.1 Purpose	2
1.2 Scope.....	2
2. Requirements	2
2.1 General	2
2.2 Field Definitions	2
2.3 Example Designation.....	9
2.4 Standard Notes.....	10
2.5 Cover Sheet/Addendum Form.....	10

Appendixes

- Appendix A - Cover Sheet/Addendum Form
- Appendix B - Sample Cover Sheet
- Appendix C - Sample Addendum
- Appendix D - Hygienic Process Piping Line
Class Designator System Summary
Sheet

1. Introduction

1.1 Purpose

This Practice provides the designator system for identifying PIP Hygienic Process Piping line classes.

1.2 Scope

This Practice describes the arrangement of the line class designators for PIP Hygienic Process Piping and the requirements for each field within a designation. Designation requirements are provided for both PIP-developed and owner-developed Hygienic Process Piping line classes. A one-page summary of the PIP Hygienic Process Piping Line Class Designator System specified in this Practice is provided in Appendix D.

2. Requirements

2.1 General

2.1.1 The Hygienic Process Piping line class designator system shall consist of nine alternating alphanumeric fields containing one or two characters each (maximum of ten characters). The first six fields are mandatory while the seventh is optional.

2.1.2 Each field shall describe various features of a Hygienic Process line class.

2.2 Field Definitions

2.2.1 First Field (1 numeric character) – ID Surface Finish (per ASME BPE Table SF-2.4-1)

The first field shall define the ID surface finish based on ASME BPE Tables SF-2.4-1 and SF-3.4-1. The ID Surface Finish code shall consist of one numeric or alpha character in accordance with the following list:

0 = SF0; No finish requirement

1 = SF1; Ra 20 μin (0.51 μm) Mechanical Polish

2 = SF2; Ra 25 μin (0.64 μm) Mechanical Polish

3 = SF3; Ra 30 μin (0.76 μm) Mechanical Polish

4 = SF4; Ra 15 μin (0.38 μm) Mechanical Polish and Electro-polish

5 = SF5; Ra 20 μin (0.51 μm) Mechanical Polish and Electro-polish

6 = SF6; Ra 25 μin (0.64 μm) Mechanical Polish and Electro-polish

A = SFP0; No finish requirement (Polymeric Materials)

B = SFP1; Ra 15 μin (0.38 μm) (Polymeric Materials)

C = SFP2; Ra 25 μin (0.64 μm) (Polymeric Materials)

D = SFP3; Not used – Not applicable to Hygienic function / Not commercially available

E = SPF4; Ra 40 µin (1.01 µm) (Polymeric Materials)

F = SPF5; Ra 50 µin (1.27 µm) (Polymeric Materials)

G = SPF6; Not used – Not applicable to Hygienic function / Not commercially available

2.2.2 Second Field (1 or 2 numeric characters) – Pressure Rating

2.2.2.1 The second field shall define the pressure rating.

2.2.2.2 The pressure rating field shall consist of one or two numeric characters in accordance with Table 1.

Table 1 - Pressure Rating

Symbol	Nominal Pressure Rating or Class
00	Not Applicable / Non-standard Class ASME B16.5 or B16.47 Flange Class
01	150
03	300
04	400
06	600
09	900
15	1500
25	2500
	Hygienic Clamped Joints
14	Refer to ASME BPE Table DT-2-1 for max working pressure API & MSS
08	800
50	5000
70	10000
	ASME 16.1 Cast Iron Flange Class
12	125
13	250
	EN / ISO Pressure Class
P0	PN 10
P1	PN 16
P2	PN 25
P3	PN 40
P4	PN 63
P5	PN 100
P6	PN 160
P7	PN 250
P8	PN 320
P9	PN 400
	Misc. Pressure Class Rating

Symbol	Nominal Pressure Rating or Class (e.g. CWP, SWP, WOG, etc.)
17	175
02	200
10	1,000
16	1,690
20	2,000
26	2,680
30	3,000
40	4,000
45	4,500
60	6,000
68	8,000
80 – 99	Reserved for Owner-Specific Rating Designations

2.2.3 Third Field (1 or 2 alpha characters) – Hygienic Process Piping Material

2.2.3.1 The third field shall define the nominal Hygienic Process Piping material.

2.2.3.2 The nominal Hygienic Process Piping material field shall consist of two alphabetic characters in accordance with Table 2.

2.2.4 Fourth Field (1 numeric character) – Corrosion Allowance

2.2.4.1 The fourth field shall define the corrosion/erosion allowance.

2.2.4.2 The corrosion/erosion allowance field shall consist of one numeric character in accordance with Table 3.

Note: In Hygienic Process Piping, this value is typically 0.