

JIS

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS A 1450 : 2015

(JAFA/JSA)

Test methods for raised access floor

ICS 91.060.30

Reference number : JIS A 1450 : 2015 (E)

PROTECTED BY COPYRIGHT

19 S

A 1450 : 2015

Date of Establishment: 1997-04-20

Date of Revision: 2015-07-21

Date of Public Notice in Official Gazette: 2015-07-21

Investigated by: Japanese Industrial Standards Committee
Standards Board for ISO area
Technical Committee on Architecture

JIS A 1450 : 2015, First English edition published in 2016-09

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2016

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

IH/HN

PROTECTED BY COPYRIGHT

Contents

		Page
1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Test items	2
5	General conditions of tests	2
5.1	Conditions of test location and conditioning of test specimen	2
5.2	Surface finishing material	3
5.3	Measuring instruments	3
5.4	Test specimen	3
5.5	Expression of test results	4
6	Tests	4
6.1	Dimensional measurement	4
6.2	Static load test	5
6.3	Impact test	7
6.4	Rolling load test	10
6.5	Combustion test	13
6.6	Electrostatic propensity test	14
6.7	Leakage resistance test	15
6.8	Vibration test	17
7	Additional information to be included in the test report	21
Annex A (normative)	Dimensional measurement of the floor for which dimensional precision is required	22
Annex B (informative)	Comparison table between previous and current editions of this Standard on technically significant revisions	25

Foreword

This translation has been made based on the original Japanese Industrial Standard revised by the Minister of Economy, Trade and Industry through deliberations at the Japanese Industrial Standards Committee as the result of proposal for revision of Japanese Industrial Standard submitted by Japan Access Floor Association (JAFA)/Japanese Standards Association (JSA) with the draft being attached, based on the provision of Article 12 Clause 1 of the Industrial Standardization Law applicable to the case of revision by the provision of Article 14. Consequently **JIS A 1450:2009** is replaced with this Standard.

This **JIS** document is protected by the Copyright Law.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, applications for a patent after opening to the public or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, applications for a patent after opening to the public or utility model rights.

Test methods for raised access floor

1 Scope

This Japanese Industrial Standard specifies the test methods for raised access floor (hereafter referred to as “floor”).

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this Standard. The most recent editions of the standards (including amendments) indicated below shall be applied.

JIS A 1455 *Anti-static effect of floor coverings and installed floors — Methods of measurement and evaluation*

JIS B 7503 *Mechanical dial gauges*

JIS B 7507 *Vernier, dial and digital callipers*

JIS B 7512 *Steel tape measures*

JIS B 7514 *Steel straightedges*

JIS B 7524 *Feeler gauges*

JIS B 7534 *Carpenter's squares*

JIS B 8922 *Industrial wheels*

JIS K 8101 *Ethanol (99.5) (Reagent)*

JIS L 1021-16 *Textile floor coverings — Part 16 : Assessment of static electrical propensity — Walking test*

JIS L 4406 *Tile carpet*

JIS R 5201 *Physical testing methods for cement*

3 Terms and definitions

For the purposes of this Standard, the following terms and definitions apply.

3.1 raised access floor

double flooring system of which the floor top panels, etc. can be easily detached to allow access to the equipment, etc. in the underfloor space for maintenance purposes

3.2 panel

floor component which forms the upper surface (including surface finishing materials, if applied in the manufacturing process)

3.3 pedestal