



CGA G-3—2017
SULFUR DIOXIDE

SIXTH EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information, contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 00-17
Specialty Gases Committee

NOTE—Technical changes from the previous edition are underlined.

SIXTH EDITION: 2017
FIFTH EDITION: 1995
FOURTH EDITION: 1988
THIRD EDITION: 1964

© 2017 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	1
4 Manufacture, properties, and uses.....	3
4.1 Manufacture.....	3
4.2 Properties	3
4.3 Commercial uses.....	10
5 General regulations.....	11
5.1 United States.....	11
5.2 Canada.....	12
5.3 International.....	12
5.4 Description and classification of sulfur dioxide.....	12
5.5 Containers	12
5.6 Container qualification.....	13
5.7 Filling density.....	13
6 Tank cars.....	13
6.1 Description.....	13
6.2 Fabrication.....	14
6.3 Marking and placarding	16
6.4 Filling density.....	16
6.5 Shipping and receiving	16
6.6 Handling and unloading.....	17
7 Cargo tanks (tank trucks or highway tanks)	19
7.1 Description.....	19
7.2 Fabrication.....	20
7.3 Requalification	20
7.4 Marking and placarding	20
7.5 Filling—filling density	21
7.6 Shipping.....	21
7.7 Unloading	22
7.8 Unhooking procedure	23
7.9 Protection	24
8 Portable tanks	24
8.1 Description.....	24
8.2 Fabrication.....	24
8.3 Requalification	25
8.4 Painting, marking, labeling, and placarding.....	25
8.5 Filling—filling density.....	26
8.6 Shipping.....	26
8.7 Withdrawing sulfur dioxide.....	26
8.8 Storage.....	26
9 Ton containers (multi-unit tank car tanks)	27
9.1 Description.....	27
9.2 Fabrication.....	27
9.3 Appurtenances	28
9.4 Requalification	28
9.5 Marking and labeling	28
9.6 Filling—filling density.....	29
9.7 Storage.....	29
9.8 Shipping.....	29
9.9 Withdrawing sulfur dioxide.....	30
9.10 Manifolding	31

10	Cylinders	31
10.1	Description.....	31
10.2	Appurtenances	32
10.3	Requalification	32
10.4	Marking and labeling	33
10.5	Filling	34
10.6	Storage.....	34
10.7	Shipping and handling.....	34
10.8	Withdrawing sulfur dioxide.....	35
11	Stationary storage	36
11.1	Description.....	36
11.2	Fabrication.....	36
11.3	Nameplate and marking	37
11.4	Installation	38
11.5	Filling density.....	38
11.6	Storage in rail cars.....	38
12	Piping and equipment.....	38
12.1	Materials of construction.....	38
12.2	Piping.....	39
12.3	Liquid expansion.....	39
12.4	Gaskets	39
12.5	Hoses	39
12.6	Pressure relief devices	39
12.7	Flow measurements	40
12.8	Pumps for liquid.....	40
12.9	Compressors (vapor pumps).....	40
12.10	Vaporizers	40
13	Physiological effects and first aid	40
13.1	Exposure limits/odor threshold	40
13.2	Effects of exposure.....	41
13.3	First aid medical management	41
13.4	Medical surveillance/employee training.....	43
14	Safety and security.....	43
14.1	Safety equipment.....	43
14.2	Security.....	44
14.3	OSHA hazard communication standard	44
15	Emergency action.....	44
15.1	In case of accident.....	44
15.2	Spill/leak	44
15.3	Fire	45
15.4	Diking.....	45
15.5	Exposure	45
16	References	45

Tables

Table 1—Physical properties of sulfur dioxide	4
Table 2—Properties of sulfur dioxide at various temperatures [5]	6
Table 3—Solubility of sulfur dioxide in water at various temperatures and 760 mm Hg pressure	10
Table 4—Solubility of water in liquid sulfur dioxide [7]	10
Table 5—Maximum safe volume of liquid sulfur dioxide in a storage tank at various temperatures.....	38

Figures

Figure 1—Vapor pressure of liquid sulfur dioxide (U.S. units) [5]	5
Figure 2—Vapor pressure of liquid sulfur dioxide (SI units) [5]	5
Figure 3—Specific volume and density versus temperature curve for liquid sulfur dioxide	7
Figure 4—Thermal conductivity of sulfur dioxide vapor	8
Figure 5—Heat of vaporization of sulfur dioxide	8
Figure 6—Heat capacity of sulfur dioxide vapor	9
Figure 7—Heat capacity of sulfur dioxide liquid	9
Figure 8—Typical tank car	13
Figure 9—Typical tank car valve arrangement	15
Figure 10—Compressor method of tank car and tank truck unloading	18
Figure 11—DOT specification MC 331 insulated cargo tank	20
Figure 12—Typical sulfur dioxide tank truck connection	23
Figure 13—DOT specification 51 portable tank	24
Figure 14—Typical ton container	27
Figure 15—Typical ton container connection-liquid removal	31
Figure 16—Cross section of a wrench-operated packed valve	32

This page is intentionally blank.

1 Introduction

This publication is one of a series compiled by the Compressed Gas Association, Inc. (CGA) in response to demand for information relating to the properties, transportation, storage, and handling of compressed gases.

2 Scope

The purpose of this publication is to provide information regarding the properties, manufacture, shipping, storage, handling, and use of sulfur dioxide. It also describes related regulatory requirements and safe practices in the United States and Canada. This information is intended to complement but not supplant national, state, provincial/territorial, municipal, and insurance company codes and requirements.

The information in this publication is intended for the use of sulfur dioxide shippers, carriers, distributors, repackagers, consumers, equipment designers or installers, safety administrators, and others desiring an introductory knowledge of the subject. Anyone requiring more detailed or specialized information should consult their sulfur dioxide supplier. See also the references listed in Section 16.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

3.2 Technical definitions

3.2.1 ACME thread

Standard thread having a profile angle of 20 degrees and a flat crest, which is used on power screws.

3.2.2 Adapter

Device or pipe fittings that allows for connection to different size, style, or misalignment of coupling.

3.2.3 Butt joints

Joint between two members aligned approximately in the same plane.

3.2.4 Cargo tank

Bulk packaging that:

- is a tank intended primarily for the carriage of liquids or gases and includes appurtenances, reinforcements, fittings, and closures;