

**SHORT CIRCUIT PERFORMANCE  
OF  
METALLIC SHIELDS AND SHEATHS  
ON  
INSULATED CABLE**

ICEA PUBLICATION P-45-482-2013

Revised February 27, 2013



©2013 by  
INSULATED CABLE ENGINEERS ASSOCIATION, Inc.





Approved as an American National Standard  
ANSI Approval Date: February 27, 2013

**Insulated Cable Engineers Assoc., Publication No. P-45-482-Revised 2013**

*Short Circuit Performance of Metallic Shields and Sheaths on Insulated Cable*

*Published by*

**Insulated Cable Engineers Association**  
P.O. Box 1568  
Carrollton, Georgia 30112  
[www.icea.net](http://www.icea.net)

## **NOTICE AND DISCLAIMER**

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While ICEA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgements contained in its standards and guideline publications.

ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. ICEA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, ICEA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

ICEA has no power, nor does it undertake to police or enforce compliance with the contents of this document. ICEA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to ICEA and is solely the responsibility of the certifier or maker of the statement.

## CONTENTS

	Page
Foreword.....	ii
Section 1 GENERAL.....	1
1.1 SCOPE.....	1
1.2 REFERENCES.....	1
Section 2 FORMULAE AND CALCULATIONS.....	3
Section 3 Tabulated Parameters.....	5

## LIST OF TABLES

Table 1	Formulas for Determining Metallic Shield/Sheath Cross-sectional Area.....	4
Table 2	Parameters for Use in Equations (1), (2) or (3).....	5
Table 3	Values of $T_1$ , Approximate Shield or Sheath Operating Temperature, °C at Various Conductor Temperatures.....	5
Table 4	Values for $T_2$ , Maximum Allowable Shield or Sheath Transient Temperature, °C.....	6
Table 5	M Values for $T_2$ Temperature of 200 °C.....	6
Table 6	M Values for $T_2$ Temperature of 350 °C.....	7

## Foreword

This publication discusses factors for consideration in approximating the operability of insulated and/or covered wire and cable under the influence of uninterrupted short circuit currents encountered as a result of cable or other equipment faults. The duration of such a fault is considered to be up to approximately 2 seconds. Calculation for single short circuits of longer durations will yield increasingly conservative results.

The following items must be considered in order to estimate the short circuit performance of a specific circuit:

1. The magnitude and duration of the fault current including any fault current division due to available conducting paths.
2. The capability of joints, terminations and other accessories in the affected circuit to withstand the thermal and mechanical stresses created by the fault.
3. The interaction between the faulting circuit and surrounding equipment, such as supports, ties and clamps.
4. The capability of the affected cable circuit, as installed, to withstand the electromagnetic forces created during the fault.
5. The maximum temperature that cable components can withstand without incurring damage due to heating caused by fault current flow.
6. Damage to adjacent equipment due to arcing at the site of the fault.
7. For limitations imposed on the short-circuit current in the cable phase conductor see ICEA Publication P-32-382, *Short Circuit Characteristics of Insulated Cable*.

An important simplifying assumption in the formula is the adiabatic nature of the heat generated, *i.e.*, *the duration of the fault is so short that all the heat developed by the fault current during this time is assumed to be completely contained within the sheath or shield*. The amount of heat dissipated from the sheath or shield during continuous, single fault occurrences of relatively short duration is small. A significant amount of heat may be dissipated because of the relatively long cooling periods involved for faults interrupted and reestablished with automatic reclosing of circuit protective devices. A non-adiabatic calculation may be more suitable for these situations and for single, uninterrupted short circuits in excess of 2 seconds requiring close accuracy. Non-adiabatic calculation methods are described in several published works listed in Section 1.2 "References".

The formula (1) described in this publication is based on the thermal capacity of the metallic sheath/shield material and the transient temperature limit of the adjacent cable component materials. The quantity of heat contained in the metallic sheath/shield is that created by the fault current and is also a function of the temperature rise in the metallic sheath/shield. The magnitude of the temperature rise is the difference between the upper temperature of the cable material in contact with the sheath/shield and the operating temperature of the sheath/shield immediately prior to the initiation of the fault.

The operating temperature of the sheath or shield depends on the temperature of the conductor and the insulation thickness which is determined by the cable voltage rating. See Section 3, Table 3 for suggested estimated values.

The maximum transient temperature limits of the cable component materials are those which cause no significant change in the materials. These limits were extrapolated from laboratory test data.

Suggestions for improvements in this publication are welcome, and should be sent to ICEA at the address below.

Insulated Cable Engineers Association, Inc.  
P.O. Box 1568  
Carrollton, GA 30112

<This page intentionally left blank>

## Section 1 GENERAL

### 1.1 SCOPE

Equations and parameters have been established for short circuit calculations for sheaths or shields made of aluminum, bronze, copper, lead, steel, zinc and cupro-nickel alloys. The types of sheaths or shields included are:

- Wires, applied either helically, as braid or serving; or longitudinally with corrugations.
- Helically applied flat tape, not overlapped.
- Helically applied, overlapped, flat tape.
- Corrugated tape, longitudinally applied.
- Tubular sheath.

The types of cable materials in contact with the sheath or shield are: crosslinked (thermoset), thermoplastic, impregnated paper, and varnished cloth.

The materials which determine the maximum allowable short circuit temperatures are: paper, varnished cloth and several thermoplastic and thermosetting materials presently appearing in ICEA standards. Temperature limits, considered safe, were established for the various coverings and insulation materials.

The equations may be used to determine:

- The maximum short circuit current permitted for a specific sheath/shield and short circuit duration.
- The sheath/shield size necessary to carry a specific short circuit current for a given duration.
- The maximum duration a specific sheath/shield can carry a specific short circuit current.

### 1.2 REFERENCES

The following references were reviewed in preparing this document.

*The Transient Temperature Rise of Round Wire Shields of Extruded Dielectric Cables Under Short Circuit Conditions*, M. A. Martin Jr., A.W. Reczek Jr., IEEE-ICC Open Forum at 57 Meeting Nov. 17-19, 1975.

*Optimization of Design of Metallic Shield-Concentric Conductors of Extruded Dielectric Cables Under Fault Conditions*, EPRI EL-3014, Project 1286-2, final Report 4/83.

*Optimization of Metallic Shields for Extruded Dielectric Cables Under Fault Conditions*, IEEE Paper 86 T&D 339-B.