

Australian/New Zealand Standard™

**Electric cables—Reeling and trailing—
For underground coal mining**



AS/NZS 1802:2018

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-023, Electric Equipment for Mines and Quarries. It was approved on behalf of the Council of Standards Australia on 5 March 2018 and by the New Zealand Standards Approval Board on 3 April 2018.
This Standard was published on 9 May 2018.

The following are represented on Committee EL-023:

Australian Cablemakers Association
Australian Chamber of Commerce and Industry
Australian Industry Group
Aviation and Marine Engineers Association
Construction Forestry Miners and Energy Union
Department of Mines, Industry Regulation and Safety (WA)
Department of Natural Resources, Mines and Energy (QLD)
Engineers Australia
National Association of Testing Authorities Australia
NSW Department of Industry , Skills and Regional Development
SafeWork NSW
University of Newcastle
Worksafe New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 1802:2017.

Australian/New Zealand Standard™

Electric cables—Reeling and trailing— For underground coal mining

Originated in Australia as AS C81—1941.
Originated in New Zealand as NZS/AS 1802:1992.
Jointly revised and redesignated as AS/NZS 1802:1995.
Previous edition 2003.
Sixth edition 2018.

COPYRIGHT

© Standards Australia Limited

© The Crown in right of New Zealand, administered by the New Zealand Standards Executive

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, PO Box 1473, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-023, Electric Equipment for Mines and Quarries to supersede AS/NZS 1802:2003, *Electric cables—Reeling and trailing—For underground coal mining*.

This Standard aligns with AS/NZS 2802, *Electric cables—Reeling and trailing—For mining and general use (other than underground coal mining)* for cables that have been developed to meet the special requirements of the Australian surface mining industry.

The objective of this Standard is to specify construction and tests of reeling and trailing cables specifically designed for use in underground coal mines.

Where the method of testing differs from, or has not yet been included in AS/NZS 1660, the test method has been included in Clause 25 and appendices to this Standard.

While the requirements of underground coal mining continue to determine the cables to be incorporated in this Standard, it is recognized that many of these cables will be equally applicable to other installations, for example, underground metalliferous mines, ship loaders, travelling cranes, reclaimers at loading stations and other materials handling plants. Other requirements may apply in these applications.

Appropriate requirements for new types and sizes will be included in this Standard as the need arises.

This Standard differs from the previous edition in the following significant ways:

- (a) Introduction of an earth fault screen.
- (b) Introduction of tests under Clause 25 to test the newly introduced earth fault screen.
- (c) Definition of the maximum volume resistivity for the insulation earth screens.
- (d) Due to increasing cable sizes and thus experience with larger cables, the maximum sheath thickness for all cables is limited to no more than 9.0 mm.

The terms ‘normative’ and ‘informative’ are used in a Standard to define the application of the appendices or annexes to which they apply. A ‘normative’ appendix or annex is an integral part of a Standard, whereas an ‘informative’ appendix or annex is only for information and guidance.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 REFERENCED DOCUMENTS.....	4
3 DEFINITIONS.....	5
4 VOLTAGE DESIGNATION	7
5 DESIGNATION AND APPLICATION.....	7
6 MAXIMUM CONDUCTOR TEMPERATURES	8
7 POWER, EARTH AND PILOT CONDUCTORS (OTHER THAN CENTRAL PILOT/CONTROL CORES AND COMPOSITE EARTH SCREENS)	8
8 CENTRAL PILOT/CONTROL CORES (TYPES 209, 210, 241, 245, 275 AND 280B ONLY).....	9
9 CONDUCTOR SCREEN.....	10
10 INSULATION ON CONDUCTORS (OTHER THAN EARTH CONDUCTORS)....	11
11 TAPE OVER INSULATION OTHER THAN SEMI-CONDUCTIVE TAPE (TYPES 209, 210, 240 AND 260 ONLY).....	11
12 SCREENS.....	12
13 IDENTIFICATION OF CORES	15
14 CRADLE SEPARATORS	16
15 SEMICONDUCTIVE ELASTOMER COVERING FOR INTERSTITIAL EARTH CONDUCTORS (TYPES 241, 245, 275 AND 280B ONLY).....	16
16 LAYING UP OF CORES	17
17 SEMICONDUCTIVE ELASTOMER SCREEN FOR CORE ASSEMBLY (TYPES 241, 245, 275 AND 280B ONLY)	17
18 REINFORCEMENT FOR CORE ASSEMBLY (TYPES 241, 245, 275 AND 280B ONLY).....	17
19 INNER SHEATH (TYPE 260 ONLY).....	18
20 PLIABLE ARMOUR (TYPE 260 ONLY).....	18
21 OUTER SHEATH (ALL CABLES).....	18
22 OPTIONAL OUTER SHEATH REINFORCEMENT (TYPES 209, 240 AND 260 ONLY).....	19
23 CONSTRUCTION AND DIMENSIONS (ALL CABLES).....	19
24 JOINTS IN COMPLETED CABLE LENGTHS	20
25 TESTS	20
26 MARKING (ALL CABLES)	27
27 FIGURES OF CONSTRUCTION AND TABLES OF DIMENSIONS.....	29
 APPENDICES	
A PURCHASING GUIDELINES.....	48
B DETERMINATION OF SHEATH THICKNESS AND PLIABLE ARMOUR STRAND SIZE USING FICTITIOUS CALCULATION METHOD.....	49
C MEASUREMENT OF VOLUME RESISTIVITY	51

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Electric cables—Reeling and trailing—For underground coal mining****1 SCOPE**

This Standard specifies elastomer-insulated, elastomer-sheathed reeling and trailing electric cables for use in underground coal mines. An essential feature of this Standard is the requirement that cables used for alternating current supply be electrically symmetrical.

This Standard is intended to apply only to cables of the types provided for in Table 1 of this Standard.

This Standard also provides the basis of requirements for other sizes of cable not specified in this Standard.

NOTE: Purchasing guidelines are provided in Appendix A.

2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

1931 High voltage test techniques (all parts)

AS/NZS

1125 Conductors in insulated electric cables and flexible cords

1660 Test methods for electric cables, cords and conductors

1660.1 Method 1: Conductors and metallic components

1660.2.1 Method 2.1: Insulation, extruded semi-conductive screens and non-metallic sheaths—Methods for general application

1660.2.2 Method 2.2: Insulation, extruded semi-conductive screens and non-metallic sheaths—Methods specific to elastomeric, XLPE and XLPVC materials

1660.2.5 Method 2.5: Insulation, extruded semi-conductive screens and non-metallic sheaths—Methods specific to cables above 1 kV

1660.3 Method 3: Electrical tests

1660.5.6 Method 5.6: Test for vertical flame propagation for a single insulated wire or cable

2802 Electric cables—Reeling and trailing—For mining and general use (other than underground coal mining)

3808 Insulating and sheathing materials for electric cables

3863 Galvanized mild steel wire for armouring of cables

5000 Electric cables—Polymeric insulated

5000.1 Part 1: For working voltages up to and including 0.6/1 (1.2) kV

ISO

1139 Textiles—Designation of yarns