

Australian/New Zealand Standard™

**Air-handling and water systems of  
buildings— Microbial control**

**Part 3: Performance-based maintenance  
of cooling water systems**

## **AS/NZS 3666.3:2000**

---

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee ME/62, Ventilation and Airconditioning. It was approved on behalf of the Council of Standards Australia on 4 August 2000 and on behalf of the Council of Standards New Zealand on 10 August 2000. It was published on 1 September 2000.

---

The following interests are represented on Committee ME/62:

Air-Conditioning and Refrigeration Equipment Manufacturers Association of Australia  
Australasian Fire Authorities Council  
Australian Buildings Code Board  
Australian Chamber of Commerce and Industry  
Australian Industry Group  
Australian Institute of Building Surveyors  
Australian Institute of Refrigeration AirConditioning and Heating  
Chartered Institution of Building Services Engineers  
Department of Contract and Management Services, W.A.  
enHealth Council  
FPA Australia  
Institute of Refrigeration Heating and Air Conditioning Engineers of New Zealand  
Institute of Engineers Australia  
Plastics and Chemicals Industries Association  
Property Council of Australia  
Thermal Insulation Contractors Association of Australia

Additional interests participating in the preparation of this Standard:

Department of Human Services (Vic)  
Institute of Plant Engineers Australasia  
National Health and Medical Research Council  
NSW Health Department  
Queensland Health  
Telstra Corporation

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

# Australian/New Zealand Standard™

## **Air-handling and water systems of buildings—Microbial control**

### **Part 3: Performance-based maintenance of cooling water systems**

Originated as AS/NZS 3666.3(Int):1998.  
Jointly revised and designated AS/NZS 3666.3:2000.

#### **COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001  
and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 3555 X

## PREFACE

This Standard was prepared by Joint Standards Australia/Standards New Zealand Committee ME/62, Ventilation and Airconditioning.

This Standard forms Part 3 of a series of Standards for microbial control of air-handling and water systems, as follows:

### AS/NZS

3666 Air-handling and water systems of buildings — Microbial control

3666.1 Part 1: Design, installation and commissioning

3666.2 Part 2: Operation and maintenance

3666.3 Part 3: Performance-based maintenance of cooling water systems

The term 'normative' has been used in this Standard to define the application of the appendix to which it applies. A 'normative' appendix is an integral part of a Standard.

## CONTENTS

	<i>Page</i>
FOREWORD .....	4
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE .....	6
1.2 OBJECTIVE .....	6
1.3 FUNCTIONAL STATEMENT .....	6
1.4 PERFORMANCE REQUIREMENTS.....	6
1.5 REFERENCED DOCUMENTS .....	6
1.6 DEFINITIONS .....	7
1.7 TESTING.....	7
<b>SECTION 2 IDENTIFICATION AND ASSESSMENT OF RISK FACTORS</b>	
2.1 SCOPE OF SECTION.....	8
2.2 RISK FACTORS.....	8
2.3 RISK ASSESSMENT .....	8
2.4 WATER TREATMENT.....	8
<b>SECTION 3 PERFORMANCE MONITORING AND CONTROL</b>	
3.1 SCOPE OF SECTION.....	10
3.2 PRESENCE OF LEGIONELLAE .....	10
3.3 PRESENCE OF OTHER HETEROTROPHIC MICROORGANISMS.....	10
3.4 WATER QUALITY MANAGEMENT .....	10
3.5 WATER TEMPERATURE .....	11
3.6 START UP.....	13
3.7 RESULTS AND RECORDS .....	13
3.8 EVIDENCE OF COMPLIANCE.....	13
<b>APPENDICES</b>	
A COOLING WATER SAMPLING PROCEDURE.....	16
B ON-LINE DISINFECTION PROCEDURE FOR COOLING WATER SYSTEMS .....	18
C DECONTAMINATION PROCEDURES FOR COOLING WATER SYSTEMS .....	19

## FOREWORD

AS/NZS 3666.2, *Air-Handling and water systems of buildings—Microbial control, Part 2: Operation and maintenance*, requires shutdown of cooling water systems for periodic cleaning. This is impracticable for many systems, such as the large industrial types serving power stations, co-generation plants and refining plants. However, microbiological control at these plants is usually effective and no reported outbreaks of Legionnaires' disease have been attributed to such sources. The continuous engineering attention they receive means they are generally well maintained. However, it became apparent that the AS/NZS 3666 series should provide for a performance-based alternative to the prescriptive maintenance requirements set out in Clause 2.5 of AS/NZS 3666.2. This performance-based alternative can be applied to any cooling water system for which the specific requirements of this Standard can be met.

This Standard provides such an alternative option. It follows risk management principles including—

- (a) risk identification and assessment
- (b) control; and
- (c) monitoring and corrective actions.

These principles are applied to the key causal factors, understood to lead to a risk of multiplication of legionellae within a system, as set out in the Foreword to AS/NZS 3666.1.

A central issue in the management of health risk arising from microorganisms is the degree of scientific certainty about the underlying causes of growth, dissemination and infection. Control strategies adopted may need to change as new knowledge becomes available.

Sampling for legionellae is not required by AS/NZS 3666.2 but is considered to be a relevant monitoring activity in a performance-based approach. Although the sample taken may not accurately represent the microbial distribution and variety within the system, it is presently the most direct means of assessing the effectiveness of maintenance regimes on the multiplication of legionellae. Such specific tests need to be complemented with other assessments such as total bacterial count (also called heterotrophic colony count) and system water quality characteristics to provide reassurance that the system is well maintained and operating in a hygienic condition.

The concentration level of legionellae required to cause infection has not been established at this time. The risk of disease depends substantially on the susceptibility of the person exposed. However, it is reasonable to assume that increased risk is associated with exposure to increased concentrations of microorganisms. Available data suggest that most outbreaks are associated with a concentration of 1000 cfu/mL or greater, although lower levels may well be associated with sporadic cases of disease. It is the intention of this Standard that cooling water systems operate with non-detectable concentrations of legionellae. This Standard requires corrective actions to be carried out whenever a 'detectable' concentration of legionellae is found (10 cfu/mL or greater) in order to provide confidence that the system is hostile to these microorganisms. More demanding and prompt actions are required when a higher concentration is detected.

The primary aim is to avoid conditions that may allow microorganisms, including legionellae to multiply in the cooling water system thus creating a health risk.

An important strategy in minimizing health risks associated with cooling water systems involves the management of system water quality. Water treatment is designed to preserve the cooling tower and the cooling water system of which it is a part, maintain heat transfer efficiency and help ensure an acceptable standard of occupational and public health. These

factors interact so that properly implemented microbial control, for reasons of disease prevention, should also assist in system longevity and efficiency. The water treatment program for microbial control needs to be well managed, and be more comprehensive than a program for those systems that are routinely cleaned in accordance with AS/NZS 3666.2. Water treatment program management approaches may differ in detail from site to site and, therefore, need to be documented in a specific plan for each site.

This Standard addresses only the maintenance of cooling water systems and is to be read in conjunction with Part 1 and the relevant clauses of Part 2. Aspects such as maintenance manuals, records, log books, safety procedures and the like, are as important for the application of this Standard, as they are for a prescriptive approach to maintaining a clean system.

Further explanatory information regarding the subject of microbial control of cooling water systems can be found in the Standards Australia/Standards New Zealand Handbook SAA/SNZ HB32:1995, *Control of microbial growth in air-handling and water systems of buildings*, and the National Environmental Health Forum Monograph, *Guidance for the control of Legionella*, published by the South Australian Health Commission (1996) on behalf of the Commonwealth Department of Health and Aged Care, and the *Application Manual No. DA18, Water Treatment*, which is published by the Australian Institute of Refrigeration Air-conditioning and Heating Inc (AIRAH).

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

**Australian/New Zealand Standard****Air-handling and water systems of buildings—Microbial control****Part 3: Performance-based maintenance of cooling water systems**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard outlines a performance-based approach to the maintenance of cooling water systems with respect to the control of microorganisms, including Legionellae, within such systems. This approach combines automatically regulated water treatment with monitoring, assessment and control strategies to help create a low risk environment within the cooling water system.

The provisions of this Standard are an alternative to the prescriptive requirements of AS/NZS 3666.2 for the maintenance of cooling water systems.

NOTE: This Standard addresses only the performance of maintenance programs for cooling water systems and is to be read in conjunction with Part 1 and the relevant clauses of Part 2. Aspects such as maintenance manuals, records, log books, safety procedures, and the like, are as important for the application of this Standard as they are for a prescriptive approach to maintaining a clean system.

**1.2 OBJECTIVE**

The objective of this Standard is to provide a performance-based approach to cooling water system maintenance to assist users in the control of microorganisms, including legionellae, within such systems.

**1.3 FUNCTIONAL STATEMENT**

Cooling water systems shall be maintained and monitored to minimize the growth and dissemination of microorganisms, and in particular, legionellae in and by such systems.

**1.4 PERFORMANCE REQUIREMENTS**

The monitoring, assessment and control strategies for key performance indicators shall be in accordance with Section 3.

NOTE: Following these performance requirements is deemed to comply with the prescriptive requirements of Clause 2.5 of AS/NZS 3666.2.

**1.5 REFERENCED DOCUMENTS**

The following documents are referred to in this Standard.

AS

- |          |   |
|----------|---|
| 2031     | Selection of containers and preservation of water samples for chemical and microbiological analysis |
| 2031.2   | Part 2: Microbiological   |
| 4276     | Water microbiology  |
| 4276.3.1 | Method 3.1: Heterotrophic colony count methods—Pour plate method using plate count agar             |