



BSI Standards Publication

Low-voltage electrical installations

Part 8-1: Functional aspects – Energy efficiency (IEC 60364-8-1:2019)

National foreword

This British Standard is the UK implementation of HD 60364-8-1:2019. It is derived from IEC 60364-8-1:2019, incorporating corrigendum May 2019. It supersedes BS HD 60364-8-1:2015, which is withdrawn.

This standard is to be read in conjunction with BS 7671:2018. Appendix 17 of BS 7671:2018 provides an introduction to, and overview of, energy efficiency in electrical installation design and refers to this standard for full details and guidance.

At the time of publication it has been decided to continue to publish this standard and BS 7671 separately.

The UK participation in its preparation was entrusted to Technical Committee JPEL/64, Electrical Installations of Buildings - Joint Committee.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 01067 1

ICS 13.020.01; 27.015; 29.020; 91.140.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2019.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

HARMONIZATION DOCUMENT
DOCUMENT D'HARMONISATION
HARMONISIERUNGSDOKUMENT

HD 60364-8-1

June 2019

ICS 13.020.01; 27.015; 91.140.50

Supersedes HD 60364-8-1:2015

English Version

Low-voltage electrical installations - Part 8-1: Functional aspects
- Energy efficiency
(IEC 60364-8-1:2019)

Installations électriques à basse tension - Partie 8-1:
Fonctionnalité - Efficacité énergétique
(IEC 60364-8-1:2019)

Errichten von Niederspannungsanlagen - Teil 8-1:
Funktionale Aspekte - Energieeffizienz
(IEC 60364-8-1:2019)

This Harmonization Document was approved by CENELEC on 2019-03-13. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 64/2353/FDIS, future edition 2 of IEC 60364-8-1, prepared by IEC/TC 64 "Electrical installations and protection against electric shock" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as HD 60364-8-1:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-12-14
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-06-14

This document supersedes HD 60364-8-1:2015.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60364-8-1:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60034-30-1	NOTE	Harmonized as EN 60034-30-1
IEC 60364 (series)	NOTE	Harmonized as HD 60364 (series)
IEC 60364-5-52:2009	NOTE	Harmonized as HD 60364-5-52:2011 (modified)
IEC 60364-5-55:2011	NOTE	Harmonized as HD 60364-5-559:2012 (modified)
IEC 60364-5-55:2011/A1:2012	NOTE	Harmonized as HD 60364-5-557:2013 (not modified)
IEC 60364-6	NOTE	Harmonized as HD 60364-6
IEC 60947-6-1:2005	NOTE	Harmonized as EN 60947-6-1:2005 (not modified)
IEC 60947-6-1:2005/A1:2013	NOTE	Harmonized as EN 60947-6-1:2005/A1:2014 (not modified)
IEC 61800-9-1	NOTE	Harmonized as EN 61800-9-1
IEC 61800-9-2	NOTE	Harmonized as EN 61800-9-2
IEC 62052-11	NOTE	Harmonized as EN 62052-11
IEC 62586-1	NOTE	Harmonized as EN 62586-1
IEC 62962 ¹	NOTE	Harmonized as EN 62962 ²
IEC 62974-1	NOTE	Harmonized as EN 62974-1
ISO 50001	NOTE	Harmonized as EN ISO 50001

¹ To be published. Stage at the time of publication: IEC PRVC 62962:2018.

² To be published. Stage at the time of publication: prEN 62962:2017.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms, definitions and abbreviated terms	10
3.1 General.....	10
3.2 Electrical energy management	11
3.3 Energy measurement	12
3.4 Sectors of activities.....	13
3.5 Abbreviated terms.....	13
4 General	14
4.1 Fundamental principles	14
4.1.1 Safety of the electrical installation	14
4.1.2 Availability of electrical energy and user decision	14
4.1.3 Design principles	14
4.2 Energy efficiency assessment for electrical installations	15
4.2.1 General	15
4.2.2 Action plan following an assessment according to Annex B	15
5 Sectors of activities	15
6 Design requirements and recommendations	15
6.1 General.....	15
6.2 Determination of load energy profile.....	16
6.3 Determination of the transformer and switchboard location with the barycentre method	16
6.4 HV/LV substation	16
6.4.1 General	16
6.4.2 Optimum number and location of HV/LV substations.....	16
6.4.3 Working point of the transformer.....	17
6.4.4 Efficiency of the transformer	17
6.5 Efficiency of local production and local storage.....	17
6.6 Losses in the wiring	17
6.6.1 Voltage drop.....	17
6.6.2 Cross-sectional areas of conductors	17
6.6.3 Power factor correction.....	18
6.6.4 Reduction of the effects of harmonic currents	18
7 Determination of the zones, usages and meshes	18
7.1 Determining the zones	18
7.2 Determining the usages within the identified zones	19
7.3 Demand response.....	19
7.4 Determining the meshes	19
7.4.1 General	19
7.4.2 Meshes.....	20
7.4.3 Criteria for considering meshes	20
7.5 Driving parameters.....	21
7.5.1 General	21
7.5.2 Occupancy	22

7.5.3	Operating time	22
7.5.4	Environmental conditions	22
7.5.5	Cost of electricity	22
7.6	Impacts on the design of an electrical installation	22
8	Energy efficiency and load management system	22
8.1	General	22
8.2	User specification	23
8.2.1	General	23
8.2.2	Requirements on the loads	23
8.2.3	Requirements on the supplies	23
8.3	Inputs from loads, sensors and forecasts	24
8.3.1	General	24
8.3.2	Communication	28
8.3.3	Data logging	29
8.3.4	Loads	29
8.3.5	Forecasts	31
8.4	Inputs from the supplies: energy availability and pricing	31
8.5	Monitoring the performance of the electrical installation	31
8.6	Management of loads through meshes	31
8.6.1	General	31
8.6.2	Electrical energy management system (EEMS)	31
8.7	Multi-supply source management: grid, local electricity production and storage	32
9	Maintenance and enhancement of the performance of the installation	32
9.1	Methodology	32
9.2	Installation life cycle methodology	34
9.3	Energy efficiency life cycle	34
9.3.1	General	34
9.3.2	Performance maintenance programme	34
9.3.3	Verification	35
9.4	Data management	35
9.5	Maintenance	35
10	Parameters for implementation of efficiency measures	35
10.1	General	35
10.2	Efficiency measures	35
10.2.1	Current-using-equipment	35
10.2.2	Electrical installation	37
10.2.3	Implementation of management systems	38
10.2.4	Local power supply	40
11	Energy efficiency actions	41
Annex A (informative) Determination of transformer and switchboard location using the barycentre method		42
A.1	Barycentre method	42
A.2	Total load barycentre	45
A.2.1	General	45
A.2.2	Sub-distribution board locations	46
A.2.3	Iterative process	46
A.3	Method of average route length	46

Annex B (normative) Method to assess the energy efficiency of an electrical installation	49
B.1 General.....	49
B.2 Electrical installation efficiency classes.....	49
B.3 Determination of the electrical installation efficiency class	49
B.3.1 General	49
B.3.2 Industrial, commercial buildings and infrastructures.....	50
B.3.3 Residential	64
Annex C (informative) List of notes concerning certain countries	70
Bibliography.....	71
Figure 1 – Energy efficiency and load management system overview	23
Figure 2 – Electrical distribution scheme.....	26
Figure 3 – Example of measurement equipment selection in an installation	28
Figure 4 – Iterative process for electrical energy efficiency management	33
Figure A.1 – Example 1: floor plan of production plant with the planned loads and calculated barycentre.....	44
Figure A.2 – Example 2: barycentre calculated	45
Figure A.3 – Example of location of the barycentre in an industrial building	46
Figure A.4 – Example of location of the barycentre using the average route length method	48
Figure B.1 – Level of efficiency of the electrical installation efficiency classes	49
Table 1 – Measurement applications.....	25
Table 2 – Overview of the needs for power metering and monitoring.....	26
Table 3 – Process for electrical energy efficiency management and responsibilities.....	33
Table A.1 – Cable length for supply of DB.....	47
Table B.1 – Electrical installation efficiency classes.....	50
Table B.2 – Energy efficiency measures	51
Table B.3 – Determination of energy consumption: coverage	52
Table B.4 – Main substation: consumption	52
Table B.5 – Main substation: location.....	53
Table B.6 – Voltage drop	53
Table B.7 – Efficiency of transformer	54
Table B.8 – Efficiency of fixed installed current using equipment	55
Table B.9 – Zones	55
Table B.10 – Usages	56
Table B.11 – Demand response: coverage.....	56
Table B.12 – Demand response: duration	56
Table B.13 – Meshes	57
Table B.14 – Measurement by usages	58
Table B.15 – Occupancy coverage.....	58
Table B.16 – Occupancy measurement.....	58
Table B.17 – Energy management system (EEMS)	59
Table B.18 – HVAC control	59

Table B.19 – Lighting control	60
Table B.20 – Performance maintenance process	60
Table B.21 – Frequency of the performance verification process.....	60
Table B.22 – Data management.....	61
Table B.23 – Working point of transformer	61
Table B.24 – Presence of continuous monitoring for large energy using systems	62
Table B.25 – Power factor.....	62
Table B.26 – THD_U	63
Table B.27 – THD_I	63
Table B.28 – Renewable energy	64
Table B.29 – Electrical energy storage.....	64
Table B.30 – Energy efficiency measures parameters	65
Table B.31 – Determination of energy consumption	65
Table B.32 – Zones.....	66
Table B.33 – Demand response coverage.....	66
Table B.34 – Meshes	67
Table B.35 – HVAC control	67
Table B.36 – Lighting control	68
Table B.37 – Measurement by usage	68
Table B.38 – Renewable energy	69
Table B.39 – Electrical energy storage.....	69
Table C.1 – Notes concerning certain countries	70

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –**Part 8-1: Functional aspects – Energy efficiency**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-8-1 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) revision of Annex B;
- b) revision of 4.2: Energy efficiency assessment for electrical installations;
- c) update of 8.3: Input from loads, sensors and forecasts;
- d) introduction of new definitions.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
64/2353/FDIS	64/2360/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

It has the status of a group energy efficiency publication in accordance with IEC Guide 118 and IEC Guide 119.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

The contents of the corrigendum of May 2019 have been included in this copy.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The optimization of electrical energy usage can be facilitated by appropriate design and installation considerations. An electrical installation can provide the required level of service and safety for the lowest electrical consumption. This is considered by designers as a general requirement of their design procedures in order to establish the best use of electrical energy. In addition to the many parameters taken into account in the design of electrical installations, more importance is nowadays focused on reducing losses within the system and its use. The design of the whole installation has therefore to take into account inputs from users, suppliers and utilities.


It is important that this document covers existing electrical installations in buildings, in addition to new installations. It is in the refurbishment of existing buildings that significant overall improvements in energy efficiency can be achieved.

The optimization of the use of electricity is based on energy efficiency management which is based on the price of electricity, electrical consumption and real-time adaptation. Efficiency is checked by measurement during the whole life of the electrical installation. This helps identify opportunities for any improvements and corrections. Improvements and corrections may be implemented by redesign or equipment replacement. The aim is to provide a design for an efficient electrical installation which allows an energy management process to suit the user's needs, and in accordance with an acceptable investment. This document first introduces the different measures to ensure an energy efficient installation based on kWh saving. It then provides guidance on giving priority to the measures depending on the return of investment; i.e. the saving of electrical energy and reducing of electrical power costs divided by the amount of investment.

This document is intended to provide requirements and recommendations for the electrical part of the energy management system addressed by ISO 50001.

It introduces requirements, recommendations and methods for the design and the energy efficiency assessment of an electrical installation within the framework of an energy efficiency management approach in order to get the best permanent functionally equivalent service for the lowest electrical energy consumption and the most acceptable energy availability and economic balance.

The assessment method described in Annex B based on the electrical energy efficiency of the installation allows a classification of energy efficiency installation according to the following levels:



NOTE Account can be taken, if appropriate, of induced works (civil works, compartmentalization) and the necessity to expect, or not, the modifiability of the installation.

This document introduces requirements and recommendations to design the adequate installation in order to give the ability to improve the management of the energy performance of the installation by the tenant/user or for example the energy manager.

All requirements and recommendations of this part of IEC 60364 enhance the requirements contained in Parts 1 to 7 of the IEC 60364 series.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 8-1: Functional aspects – Energy efficiency

1 Scope

This part of IEC 60364 provides additional requirements, measures and recommendations for the design, erection, operation and verification of all types of low voltage electrical installation including local production and storage of energy for optimizing the overall efficient use of electricity.

It introduces requirements, recommendations and methods for the design and the energy efficiency (EE) assessment of an electrical installation within the framework of an energy efficiency management approach in order to get the best permanent functionally equivalent service for the lowest electrical energy consumption and the most acceptable energy availability and economic balance.

These requirements, recommendations and methods apply, within the scope of IEC 60364 (all parts), for new installations and modification of existing installations.

This document is applicable to the electrical installation of a building or system and does not apply to products. The energy efficiency of products and their operational requirements are covered by the relevant product standards.

Where another standard provides specific requirements for a particular system or installation application (e.g. manufacturing system covered by ISO 20140 (all parts)), those requirements may supersede this document.

This document does not specifically address building automation systems.

This group energy efficiency publication is primarily intended to be used as an energy efficiency standard for the low voltage electrical installations mentioned in Clause 1, but is also intended to be used by technical committees in the preparation of standards, in accordance with the principles laid down in IEC Guide 119 and IEC Guide 118.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61557-12, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 12: Power metering and monitoring devices (PMD)*

IEC 61869-2, *Instrument transformers – Part 2: Additional requirements for current transformers*

IEC 62053-21, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)*