

CGA V-10—2019

**HIGH PRESSURE GAS
TRAILER CONNECTIONS**

SEVENTH EDITION

CGA

Compressed Gas Association

The Standard For Safety Since 1913

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information, contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 22-004
Cylinder Valve Committee

NOTE—Technical changes from the previous edition are underlined.

SEVENTH EDITION: 2019
SIXTH EDITION: 2017
FIFTH EDITION: 2015
FOURTH EDITON: 2010

© 2019 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 14501 George Carter Way, Suite 103, Chantilly VA 20151. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	2
4 Standard connections.....	2
5 Conformance and implementation	2
6 Materials.....	3
7 Recommended sealing torque	3
8 Connection standard drawing tolerances	3
9 References	3

Table

Table 1—Maximum pressure ratings for high pressure gas trailer connections	1
--	---

Drawings

CONNECTION NO. 1340.....	5
CONNECTION NO. 1350.....	6
CONNECTION NO. 1440.....	7
CONNECTION NO. 1450.....	8
CONNECTION NO. 1540.....	9
CONNECTION NO. 1550.....	10

This page is intentionally blank.

1 Introduction

This publication provides standard CGA connections for high pressure gas trailers. These connections allow the higher flow rates in trailer operations that are not provided by existing connections in CGA V-1, *Standard for Compressed Gas Cylinder Valve Outlet and Inlet Connections* [1].¹ Although most, if not all, of the fittings in common use on high pressure gas trailers are believed to be designed and manufactured to be safe for their intended use, a high potential for hazardous cross-connections and incompatible uses of the various fittings exists due to the lack of standards.

Several incidents and numerous near misses have been reported related to the partial engagement of similar but not identical fittings and the use of adapters to interconnect the various trailer fittings in use. Also, since various gas providers and users did not have a common fitting for high pressure gas trailer service, they frequently removed fittings and replaced them to be able to perform filling or to use the trailer. Typically, these fittings are attached to the trailer or equipment by a standard tapered pipe thread. Tapered pipe threads are not designed for repeated use and therefore can become worn and unsafe with a high potential to catastrophically discharge when pressurized. Unsafe practices such as changing the fittings at every use to connect trailers or using equipment having different fittings can cause serious accidents due to worn threads or incompatible gases or equipment. These potentially hazardous situations can be minimized or eliminated by the adoption and promulgation of standard CGA connections for the various high pressure gas trailer services.

The maximum pressure ratings for high pressure gas trailer connections as detailed in the fourth edition of this publication were modified as outlined in Table 1.

When the first edition of CGA V-10 was published, the standard gas trailer connections addressed were limited to a maximum pressure rating of 3000 psi at 120 °F (20 680 kPa at 48.9 °C), which is approximately 2640 psi at 70 °F (18 200 kPa at 21.1 °C) [1].² This pressure rating is similar to pressure ratings specified in CGA V-1 [1]. However, tube manufacturing companies currently offer tubes at higher pressure ratings, which can result in higher supply pressures.

In order to use the existing connections at these higher pressures, the pressure ratings of the connections were increased based on original test data, instead of creating new connections for these high pressure gas trailers. The existing connections were originally tested and qualified for a pressure rating at 70 °F (21.1 °C) using CGA V-1 testing criteria [1].

Table 1—Maximum pressure ratings for high pressure gas trailer connections

CGA connection number	Original rating	New rating
1340, 1350, 1440, 1450, 1550	3000 psi at 120 °F (20 680 kPa at 48.9 °C)	3500 psi at 70 °F (24 130 kPa at 21.1 °C)
1540	3000 psi at 120 °F (20 680 kPa at 48.9 °C)	3000 psi at 70 °F (20 680 kPa at 21.1 °C)

2 Scope

This publication provides guidelines for standard CGA connections for various high pressure gas trailer services. It defines the main outlet connection of the trailer unit only.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.

² kPa shall indicate gauge pressure unless otherwise noted as (kPa, abs) for absolute pressure or (kPa, differential) for differential pressure. All kPa value are rounded off per CGA P-11, *Guideline for Metric Practice in the Compressed Gas Industry* [2].