



PROCESS
INDUSTRY
PRACTICES

COMPLETE REVISION
October 2019

Electrical

**PIP ELCGL01
Electrical Design Criteria**

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/ purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

<i>November 2002</i>	<i>Issued</i>	<i>October 2019</i>	<i>Complete Revision</i>
<i>December 2007</i>	<i>Complete Revision</i>		
<i>December 2013</i>	<i>Complete Revision</i>		

Not printed with State funds



PIP ELCGL01 Electrical Design Criteria

Table of Contents

1. Scope	2
2. References	2
2.1 Process Industry Practices	2
2.2 Industry Codes and Standards	3
3. Definitions	5
4. Requirements	5
4.1 System Design	5
4.2 Electrical Area Classification	10
4.3 Power Distribution	10
4.4 Motors	15
4.5 Motor Control	16
4.6 Grounding	17
4.7 Lighting	19
4.8 Power Receptacles, Feeder Breakers, and Convenience Outlets	20

4.9 Wiring Methods	21
4.10 Power and Control Wiring	24
4.11 Instrumentation	25
4.12 Freeze Protection and Process Heat- Tracing Systems	25
4.13 Cathodic Protection	26
4.14 Essential Power Systems	26
4.15 Skid-Mounted or Packaged Systems	28
4.16 Lightning Protection	28
4.17 System Protection	28
4.18 Documentation	30
4.19 Acceptable Manufacturers	31
4.20 Conflict Resolution	31

Data Form

ELCGL01-D – Data Sheet for Electrical
Design Criteria

1. Scope

This Practice describes the general design requirements and basis of design for electrical systems. This Practice includes requirements for system components and typical configurations.

2. References

Applicable parts of the following Practices, industry codes and standards, and references shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP ELEGL01 - *Overall Electrical One-Line Diagram Guideline*
- PIP ELEGL02 - *Arc Flash Hazard Analysis Guideline*
- PIP ELEHA01 - *Engineering Procedure for Developing Electrical Area Classifications*
- PIP ELEMENT01 - *Guidelines for Selecting IEEE and API Standards for AC Motors 250 HP (185kW) and Larger*
- PIP ELIGD000 - *Grounding Installation Details*
- PIP ELILS000 - *Lighting and Receptacle Installation Details for Class I Division 2, Class II Division 2, and Unclassified Areas*
- PIP ELIMTD00 - *Motor Installation Details for Class I, Division 1 Area*
- PIP ELIMTG00 - *Motor Installation Details for Class I, Division 2; Class II, Division 2; and Unclassified Areas*
- PIP ELIMTN00 - *Motor Installation Details - Nameplate Details*
- PIP ELIMTS00 - *Motor Installation Details - Stand*
- PIP ELIMTT00 - *Motor Installation Details - Motor Termination Detail – 600 Volts*
- PIP ELSAP01 - *Design and Fabrication of Battery Chargers*
- PIP ELSAP04 - *Uninterruptible Power Supply (UPS) System Specification*
- PIP ELSAP11 - *Design and Fabrication of Flood Cell Lead-Acid Batteries*
- PIP ELSAP12 - *Design and Fabrication of Valve-Regulated Lead-Acid Batteries*
- PIP ELSAP20 - *Low-Voltage Automatic Transfer Switches*
- PIP ELSBD01 - *Design and Fabrication of Metal- Enclosed Nonsegregated-Phase Bus Duct Assemblies*
- PIP ELSGS01 - *Design and Fabrication of High-Resistance Grounding System (1000 Volts or Below)*
- PIP ELSGS07 - *Design and Fabrication of High Resistance Grounding System (2.4 kV to 15 kV)*
- PIP ELSGS11 - *Design and Fabrication of Low Resistance Neutral Grounding Resistor 2.4 to 15kV*
- PIP ELSHT01 - *Self-Regulated Electric Heat Trace System Specification*