

ASME B31.12-2014
(Revision of ASME B31.12-2011)

Hydrogen Piping and Pipelines

ASME Code for Pressure Piping, B31

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Copyright © 2015 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



INTENTIONALLY LEFT BLANK



ASME B31.12-2014
(Revision of ASME B31.12-2011)

Hydrogen Piping and Pipelines

ASME Code for Pressure Piping, B31

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Copyright © 2015 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: February 20, 2015

The next edition of this Code is scheduled for publication in 2017. This Code will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations, Code Cases, and errata are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued. Interpretations and Code Cases are also included with each edition.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2015 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.



CONTENTS

Foreword		ix
Committee Roster		x
Summary of Changes		xiii
PART GR	GENERAL REQUIREMENTS	
Chapter GR-1	Scope and Definitions	
GR-1.1	Scope	1
GR-1.2	Responsibilities	1
GR-1.3	Intent of the Code	2
GR-1.4	Packaged Equipment Requirements	2
GR-1.5	Terms and Definitions	2
GR-1.6	B31.12 Appendices	11
GR-1.7	Nomenclature	12
Chapter GR-2	Materials	
GR-2.1	General Requirements	13
GR-2.2	Joining and Auxiliary Materials	27
Chapter GR-3	Welding, Brazing, Heat Treating, Forming, and Testing	
GR-3.1	General	28
GR-3.2	Welding and Brazing	28
GR-3.3	Welding and Brazing Materials	31
GR-3.4	Construction of Weldments	31
GR-3.5	Preheating for Weldments	44
GR-3.6	Heat Treatment	44
GR-3.7	Specific and Alternative Heat Treat Requirements	47
GR-3.8	Construction of Brazements	47
GR-3.9	Forming of Pipe Components	50
GR-3.10	Testing	50
Chapter GR-4	Inspection, Examination, and Testing	
GR-4.1	General	51
GR-4.2	Inspection	51
GR-4.3	Examination	51
GR-4.4	Personnel Qualification and Certification	52
GR-4.5	Extent of Required Examination and Testing	53
GR-4.6	Acceptance Criteria	53
GR-4.7	Supplementary Examination	53
GR-4.8	Examinations to Resolve Uncertainty	53
GR-4.9	Defective Components and Workmanship	53
GR-4.10	Progressive Sampling for Examination	53
GR-4.11	Testing	53
GR-4.12	Records	53
GR-4.13	NDE Definitions	53
Chapter GR-5	Operation and Maintenance	
GR-5.1	General	55
GR-5.2	Operation and Maintenance Plan	55
GR-5.3	Maintenance Requirements	57
GR-5.4	Leakage Surveys	59
GR-5.5	Repair Procedures	59
GR-5.6	Injurious Dents and Mechanical Damage	59



GR-5.7	Permanent Repair of Welds With Defects	61
GR-5.8	Permanent Field Repair of Leaks and Nonleaking Corroded Areas	61
GR-5.9	Permanent Field Repair of Hydrogen Stress Cracking in Hard Spots and Stress Corrosion Cracking	61
GR-5.10	Testing and Examination of Repairs	61
GR-5.11	Valve Maintenance	61
GR-5.12	Transmission Pipeline Maintenance	62
GR-5.13	Abandoning of Transmission Facilities	63
GR-5.14	Decommissioning of Transmission Facilities	63
GR-5.15	Recommissioning of Transmission Facilities	63
GR-5.16	Repositioning a Pipeline in Service	63
GR-5.17	Testing for Integrity Assessment of In-Service Pipelines	64
GR-5.18	Distribution Pipeline Maintenance	65
GR-5.19	Leakage Surveys	65
GR-5.20	Leakage Investigation and Action	65
GR-5.21	Repair, Testing, and Examination of Mains Operating at Hoop Stress Levels at or Above 30% of the Specified Minimum Yield Strength	66
GR-5.22	Requirements for Abandoning, Disconnecting, and Reinstating Distribution Facilities	66
GR-5.23	Maintenance of Specific Facilities	67
Chapter GR-6	Quality System Program for Hydrogen Piping and Pipeline Systems	
GR-6.1	Quality System Program	69
GR-6.2	Quality Manual	69
GR-6.3	Quality System Functions	69
Figures		
GR-2.1.2-1	Minimum Temperatures Without Impact Testing for Carbon Steel Materials	20
GR-2.1.2-2	Reduction in Minimum Design Metal Temperature Without Impact Testing	22
GR-3.4.3-1	Geometry of Weld Joint Detail Single Vee Groove Butt With Extended Land	33
GR-3.4.3-2	Geometry of Weld Joint Detail Square Butt Weld	33
GR-3.4.3-3	Unequal Pipe Component Thicknesses, Thicker Components Bored for Alignment	33
GR-3.4.3-4	Geometry of Weld Joint Detail Single Vee Groove Butt, Open Root	33
GR-3.4.3-5	Unequal Pipe Component Thicknesses, Thicker Components Taper-Bored to Align	34
GR-3.4.3-6	Geometry of Weld Joint Detail Single Vee Groove Butt, Continuous Flat Backing Ring	34
GR-3.4.3-7	Geometry of Weld Joint Detail Single Vee Groove Butt, Continuous Tapered Backing Ring	34
GR-3.4.3-8	Geometry of Weld Joint Detail Single Vee Groove Butt, Consumable Insert	35
GR-3.4.3-9	Preparation and Alignment of Pipe Branch to Pipe Header Connection	35
GR-3.4.4-1	Geometry of Weld Deposit Single Vee Groove Butt, Open Root	36
GR-3.4.4-2	Geometry of Weld Deposit Root Single Vee Groove Butt With Extended Land (Without Filler Metal)	36
GR-3.4.4-3	Geometry of Weld Deposit Square Butt End (Without Filler Metal)	36
GR-3.4.5-1	Welding End Transition — Maximum Envelope	37
GR-3.4.6-1	Geometry of Weld Deposit Single Vee Groove Butt, Open Root With Concavity	39
GR-3.4.7-1	Fillet Weld Size	39
GR-3.4.7-2	Typical Details for Double-Welded Slip-On Flanges	40
GR-3.4.7-3	Minimum Welding Dimensions for Socket Welding Components to Pipe Including Fit-Up Detail	40



GR-3.4.9-1	Typical Welded Branch Connections	41
GR-3.4.9-2	Acceptable Details for Pipe Branch Attachment Welds	42
GR-3.4.9-3	Acceptable Detail for Branch Connection of Pipe Fitting	43
GR-3.4.9-4	Acceptable Details for Branch Attachment Suitable for 100% Radiography	43
GR-3.8-1	Joints for Tubular Components	48
Tables		
GR-2.1.1-1	Material Specification Index for Piping and Pipe Components	14
GR-2.1.1-2	Material Specification Index for Pipelines	17
GR-2.1.2-1	Requirements for Low Temperature Toughness Tests for Metals	19
GR-2.1.2-2	Tabular Values for Minimum Temperatures Without Impact Testing for Carbon Steel Materials	21
GR-2.1.3-1	Impact Testing Requirements for Metals	23
GR-2.1.3-2	Charpy Impact Test Temperature Reduction	24
GR-2.1.3-3	Minimum Required Charpy V-Notch Impact Values	25
GR-3.4.6-1	Weld Reinforcement	38
GR-3.5-1	Preheat Temperatures	45
GR-3.6.1-1	Requirements for Postweld Heat Treatment of Weldments	45
PART IP INDUSTRIAL PIPING		
Chapter IP-1 Scope and Responsibilities		
IP-1.1	Scope	72
IP-1.2	Responsibilities	72
IP-1.3	Intent	72
IP-1.4	Determining Code Requirements	72
Chapter IP-2 Design Conditions and Criteria		
IP-2.1	Design Conditions	73
IP-2.2	Design Criteria	74
Chapter IP-3 Pressure Design of Piping Components		
IP-3.1	General	81
IP-3.2	Straight Pipe	81
IP-3.3	Curved and Mitered Segments of Pipe	82
IP-3.4	Branch Connections	83
IP-3.5	Closures	89
IP-3.6	Pressure Design of Flanges and Blanks	89
IP-3.7	Reducers	90
IP-3.8	Pressure Design of Other Components	90
Chapter IP-4 Service Requirements for Piping Components		
IP-4.1	Valves and Specialty Components	92
IP-4.2	Bolting and Tapped Holes for Components	92
Chapter IP-5 Service Requirements for Piping Joints		
IP-5.1	Scope	93
IP-5.2	Welded Joints	93
IP-5.3	Flanged Joints	93
IP-5.4	Expanded Joints	94
IP-5.5	Threaded Joints	95
IP-5.6	Caulked Joints	95
IP-5.7	Brazed and Soldered Joints	95
IP-5.8	Special Joints	96
Chapter IP-6 Flexibility and Support		
IP-6.1	Flexibility of Piping	97
IP-6.2	Piping Supports	102



Chapter IP-7	Specific Piping Systems	
IP-7.1	Instrument Piping	105
IP-7.2	Pressure-Relieving Systems	105
Chapter IP-8	Dimensions and Ratings of Components	
IP-8.1	Dimensional Requirements	106
IP-8.2	Ratings of Components	106
IP-8.3	Reference Documents	106
Chapter IP-9	Fabrication, Erection, and Assembly	
IP-9.1	General	108
IP-9.2	Responsibility	108
IP-9.3	Content and Coverage	108
IP-9.4	Packaged Equipment Piping	108
IP-9.5	Exclusions	108
IP-9.6	Fabrication and Erection	108
IP-9.7	Construction of Weldments	108
IP-9.8	Preheating for Weldments	109
IP-9.9	Heat Treatment	109
IP-9.10	Specific and Alternative Heat Treatment Requirements	109
IP-9.11	Construction of Brazements	109
IP-9.12	Bending and Forming of Pipe and Tube	109
IP-9.13	Assembly and Erection	110
IP-9.14	Threaded Joints	110
IP-9.15	Tubing Joints	110
IP-9.16	Expanded Joints and Special Joints	110
IP-9.17	Pipe Attachments and Supports	111
IP-9.18	Cleaning of Piping	111
Chapter IP-10	Inspection, Examination, and Testing	
IP-10.1	Scope	112
IP-10.2	Responsibility	112
IP-10.3	Inspections by Owner's Inspector	112
IP-10.4	Examination Requirements	112
IP-10.5	Testing	117
IP-10.6	Hydrostatic Leak Test	118
IP-10.7	Pneumatic Leak Test	119
IP-10.8	Hydrostatic-Pneumatic Leak Test	119
IP-10.9	Sensitive Leak Test	119
IP-10.10	Alternative Leak Test	119
IP-10.11	Mechanical and Metallurgical Testing	120
IP-10.12	Records of Testing	120
Figures		
IP-3.3.1-1	Nomenclature for Pipe Bends	82
IP-3.3.3-1	Nomenclature for Miter Bends	82
IP-3.4.2-1	Branch Connection Nomenclature	85
IP-3.4.3-1	Extruded Outlet Header Nomenclature	87
IP-3.6.3-1	Blanks	91
IP-6.1.5-1	Moments in Bends	100
IP-6.1.5-2	Moments in Branch Connections	101
IP-9.14-1	Typical Threaded Joints Using Straight Threads	111
Tables		
IP-2.2.8-1	Increased Casting Quality Factors, E_c	77
IP-2.2.8-2	Acceptance Levels for Castings	77
IP-2.2.9-1	Longitudinal Weld Joint Quality Factor, E_j	78
IP-3.2-1	Values of Coefficient Y for $t < D/6$	81
IP-3.5-1	ASME BPV Code Section VIII, Division 1 References for Closures	89



IP-8.1.1-1	Component Standards	107
IP-9.6.3-1	Hardness Testing Acceptance Criteria	109
IP-10.4.2-1	Required Nondestructive Examinations	113
IP-10.4.3-1	Acceptance Criteria for Weldments and Methods for Evaluating Weld Imperfections	114
IP-10.4.3-2	Hardness Testing Acceptance Criteria for Weldments	115
IP-10.4.3-3	Criterion Value Notes for Table IP-10.4.3-1	115
PART PL PIPELINES		
Chapter PL-1 Scope and Exclusions		
PL-1.1	Scope	121
PL-1.2	Content and Coverage	121
PL-1.3	Exclusions	121
Chapter PL-2 Pipeline Systems Components and Fabrication Details		
PL-2.1	Purpose	122
PL-2.2	Piping System Components	122
PL-2.3	Reinforcement of Fabricated Branch Connections	124
PL-2.4	Multiple Openings and Extruded Outlets	125
PL-2.5	Expansion and Flexibility	126
PL-2.6	Design for Longitudinal Stress	127
PL-2.7	Supports and Anchorage for Exposed Piping	129
PL-2.8	Anchorage for Buried Piping	130
Chapter PL-3 Design, Installation, and Testing		
PL-3.1	Provisions for Design	131
PL-3.2	Buildings Intended for Human Occupancy	131
PL-3.3	Considerations Necessary for Concentrations of People in Location Class 1 or 2	132
PL-3.4	Intent	132
PL-3.5	Risk Assessment	132
PL-3.6	Location Class and Changes in Number of Buildings Intended for Human Occupancy	133
PL-3.7	Steel Pipeline	135
PL-3.8	Hot Taps	141
PL-3.9	Precautions to Prevent Combustion of Hydrogen–Air Mixtures During Construction Operations	141
PL-3.10	Testing After Construction	142
PL-3.11	Commissioning of Facilities	143
PL-3.12	Pipe-Type and Bottle-Type Holders	143
PL-3.13	Control and Limiting of Hydrogen Gas Pressure	144
PL-3.14	Up-rating	146
PL-3.15	Valves	147
PL-3.16	Vault Provisions for Design, Construction, and Installation of Pipeline Components	148
PL-3.17	Location for Customers' Meter and Regulator Installations	149
PL-3.18	Hydrogen Gas Service Lines	149
PL-3.19	Inspection and Examination	150
PL-3.20	Repair or Removal of Defective Welds in Piping Intended to Operate at Hoop Stress Levels of 20% or More of the Specified Minimum Yield Strength	153
PL-3.21	Steel Pipeline Service Conversions	153
Tables		
PL-2.3.2-1	Reinforcement of Fabricated Branch Connections, Special Requirements	126
PL-2.5.2-1	Thermal Expansion of Carbon and Low Alloy Steel	127
PL-2.5.5-1	Modulus of Elasticity for Carbon and Low Alloy Steel	127



PL-3.6.1-1	Location Class	133
PL-3.7.1-1	Basic Design Factor, F (Used With Option A)	135
PL-3.7.1-2	Basic Design Factor, F (Used With Option B)	135
PL-3.7.1-3	Temperature Derating Factor, T , for Steel Pipe	135
PL-3.7.1-4	Nominal Chemical Composition Within a Specification/Grade	137
PL-3.7.1-5	Design Factors for Steel Pipe Construction (Used With Option A)	138
PL-3.7.1-6	Design Factors for Steel Pipe Construction (Used With Option B)	138
PL-3.7.5-1	Maximum Degree of Bending	140

Mandatory Appendices

I	Design of Aboveground Hydrogen Gas Pipeline Facilities	155
II	Reference Standards	159
III	Safeguarding	163
IV	Nomenclature	165
V	(In Preparation)	169
VI	Preparation of Technical Inquiries	170
VII	Gas Leakage and Control Criteria	172
VIII	(In Preparation)	178
IX	Allowable Stresses and Quality Factors for Metallic Piping, Pipeline, and Bolting Materials	179

Nonmandatory Appendices

A	Precautionary Considerations	216
B	Alternative Rules for Evaluating Stress Range	226
C	Recommended Practices for Proof Testing of Pipelines in Place	228
D	Estimating Strain in Dents	231
E	Sample Calculations for Branch Reinforcement in Piping	232
F	Welded Branch Connections and Extruded Headers in Pipeline Systems	236



FOREWORD

Responding to an evident need and at the request of The American Society of Mechanical Engineers, the American Standards Association initiated Project B31 in March 1926, with ASME as sole administrative sponsor. The breadth of the field involved required that membership of the Sectional Committee be drawn from some 40 engineering societies, industries, government bureaus, institutes, and trade associations.

The initial publication in 1935 was the American Tentative Standard Code for Pressure Piping. Revisions from 1942 through 1955 were published as the American Standard Code for Pressure Piping, ASA B31.1. Then it was decided that the various industry sections, beginning with ASA B31.8-1955, Gas Transmission and Distribution Piping Systems, be published as separate documents. The first Petroleum Refinery Piping Code Section was designated ASA B31.3-1959. ASA B31.3 revisions were published in 1962 and 1966. In 1967–1969, the American Standards Association became first the United States of America Standards Institute, then the American National Standards Institute. The Sectional Committee became American National Standards Committee B31, and the Code was renamed the American National Standard Code for Pressure Piping. The next B31.3 revision was designated ANSI B31.3-1973. Addenda were published through 1975. The Standards Committee was reorganized in 1978 as a Committee operating under ASME procedures with ANSI accreditation. It is now the ASME Code for Pressure Piping, B31 Committee. The Section committee structure remains essentially unchanged.

As a result of preliminary studies, it was concluded that gaps exist between existing piping and pipeline codes and standards, and hydrogen infrastructure applications. A Project Team was formed under the B31 Standards Committee to develop a new B31.12 Code for hydrogen piping and pipelines. The Project Team was subsequently restructured under the B31 Standards Committee as a Section Committee.

The first edition of the B31.12 Code applies to design, construction, operation, and maintenance requirements for piping, pipelines, and distribution systems in hydrogen service. Typical applications are power generation, process plants, refining, transportation, distribution, and automotive filling stations. This Code is composed of Part GR, General Requirements, including common requirements referenced by all other parts; Part IP, Industrial Piping; and Part PL, Pipelines, including distribution systems. These Parts incorporate information specific to hydrogen service and either reference or incorporate applicable parts of ASME B31.3, Process Piping; ASME B31.1, Power Piping; ASME B31.8, Gas Transmission and Distribution Piping Systems; ASME B31.8S, Managing System Integrity of Gas Pipelines; and Section VIII, Division 3 of the ASME Boiler and Pressure Vessel Code, where appropriate.

Material performance factors have been included to account for the adverse effects of hydrogen gas on the mechanical properties of carbon and low alloy steels operating within the hydrogen embrittlement range. Many materials included in B31.3 have been omitted from B31.12's tables due to their unsuitability for hydrogen service. Rules have been added for conversion or retrofit of existing pipeline and distribution systems from natural gas or petroleum to hydrogen service. Parts covering commercial, residential, and nonmetallic systems will be added in future editions. Material performance factors will be reevaluated as materials research data is developed and understanding of hydrogen embrittlement of carbon and low alloy steels increases.

ASME B31.12-2008 was approved by the American National Standards Institute on December 3, 2008.

ASME B31.12-2011 was approved by the American National Standards Institute on June 7, 2011.

ASME B31.12-2014 was approved by the American National Standards Institute on October 24, 2014.



ASME B31 COMMITTEE

Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

M. L. Nayyar, *Chair*
J. E. Meyer, *Vice Chair*
N. Lobo, *Secretary*

STANDARDS COMMITTEE PERSONNEL

R. J. T. Appleby , ExxonMobil Development Co.	G. A. Jolly , Flowserve/Gestra, USA
C. Becht IV , Becht Engineering Co.	N. Lobo , The American Society of Mechanical Engineers
A. E. Beyer , Fluor Enterprises	W. J. Mauro , American Electric Power
K. C. Bodenhamer , Willbros Professional Services	J. E. Meyer , Louis Perry & Associates, Inc.
R. Bojarczuk , ExxonMobil Research & Engineering Co.	T. Monday , Team Industries, Inc.
C. J. Campbell , Air Liquide	M. L. Nayyar , NICE
J. S. Chin , TransCanada Pipeline U.S.	G. R. Petru , Enterprise Products
D. D. Christian , Victaulic	E. H. Rinaca , Dominion Resources, Inc.
R. P. Deubler , Fronex Power Systems, LLC	M. J. Rosenfeld , Kiefner/Applus — RTD
W. H. Eskridge, Jr. , Jacobs Engineering	S. K. Sinha , Lucius Pitkin, Inc.
D. J. Fetzner , BP Exploration Alaska, Inc.	W. J. Sperko , Sperko Engineering Services, Inc.
P. D. Flenner , Flenner Engineering Services	F. W. Tatar , FM Global
J. W. Frey , Stress Engineering Services, Inc.	K. A. Vilminot , Black & Veatch
D. R. Frikken , Becht Engineering Co.	G. Antaki , <i>Ex-Officio</i> , Becht Engineering Co., Inc.
R. A. Grichuk , Fluor Enterprises, Inc.	L. E. Hayden, Jr. , <i>Ex-Officio</i> , Consultant
R. W. Haupt , Pressure Piping Engineering Associates, Inc.	A. J. Livingston , <i>Ex-Officio</i> , Kinder Morgan
B. P. Holbrook , Babcock Power, Inc.	R. A. Appleton , <i>Contributing Member</i> , Refrigeration Systems Co.

B31.12 HYDROGEN PIPING AND PIPELINES SECTION COMMITTEE

L. E. Hayden, Jr. , <i>Chair</i> , Consultant	P. E. Robinson , Parker Hannifin Corp.
R. Lucas , <i>Secretary</i> , The American Society of Mechanical Engineers	M. J. Russell , Idaho National Laboratory
C. J. Campbell , Air Liquide	H. Solanky , SGT Inc.
W. P. Collins , WPC Sol, LLC	W. J. Sperko , Sperko Engineering Services, Inc.
J. P. Ellenberger , Retired	D. G. Stalheim , DGS Metallurgical Solutions, Inc.
D. R. Frikken , Becht Engineering Co.	G. K. Vinjamuri , Trade & Technology Transfer, Inc.
K. Grisham , Air Liquide Large Industries U.S. LP	G. B. Rawls, Jr. , <i>Contributing Member</i> , Savannah River National Laboratory
M. Rana , Praxair, Inc.	A. Slifka , <i>Contributing Member</i> , National Institute of Standards and Technology
J. H. Robertson , J. H. Robertson Co.	

B31 EXECUTIVE COMMITTEE

J. E. Meyer , <i>Chair</i> , Louis Perry & Associates, Inc.	R. A. Grichuk , Fluor Enterprises, Inc.
N. Lobo , <i>Secretary</i> , The American Society of Mechanical Engineers	L. E. Hayden, Jr. , Consultant
G. Antaki , Becht Engineering Co., Inc.	G. A. Jolly , Flowserve/Gestra, USA
R. J. T. Appleby , ExxonMobil Development Co.	A. J. Livingston , Kinder Morgan
D. D. Christian , Victaulic	M. L. Nayyar , NICE
J. W. Frey , Stress Engineering Services, Inc.	G. R. Petru , Enterprise Products
D. R. Frikken , Becht Engineering Co.	R. A. Appleton , <i>Contributing Member</i> , Refrigeration Systems Co.



B31 FABRICATION AND EXAMINATION TECHNICAL COMMITTEE

- A. P. Rangus**, *Chair*, Bechtel
J. Swezy, Jr., *Chair*, Boiler Code Tech, LLC
U. D'Urso, *Secretary*, The American Society of Mechanical Engineers
R. D. Campbell, Bechtel
D. Couch, Electric Power Research Institute
J. P. Ellenberger, Retired
R. J. Ferguson, Metallurgist
D. J. Fetzner, BP Exploration Alaska, Inc.
P. D. Flenner, Flenner Engineering Services
J. W. Frey, Stress Engineering Services, Inc.
- S. Gingrich**, URS Corp.
J. Hainsworth, WR Metallurgical
W. W. Lewis, W. G. Yates Construction
S. P. Licud, Consultant
T. Monday, Team Industries, Inc.
A. D. Nalbandian, Thielsch Engineering, Inc.
R. J. Silvia, Process Engineers & Constructors, Inc.
W. J. Sperko, Sperko Engineering Services, Inc.
E. F. Summers, Jr., Babcock & Wilcox Construction Co.
P. L. Vaughan, ONEOK Partners
K. Wu, Stellar Energy Systems

B31 MATERIALS TECHNICAL COMMITTEE

- R. A. Grichuk**, *Chair*, Fluor Enterprises, Inc.
N. Lobo, *Secretary*, The American Society of Mechanical Engineers
R. P. Deubler, Fronex Power Systems LLC
W. H. Eskridge, Jr., Jacobs Engineering
G. A. Jolly, Flowserve/Gestra, USA
C. J. Melo, Technip USA, Inc.
M. L. Nayyar, NICE
- M. B. Pickell**, Willbros Engineers, Inc.
D. W. Raho, CCM 2000
R. A. Schmidt, Canadoil
H. R. Simpson, Stantec
J. L. Smith, Jacobs Engineering
Z. Djilali, *Contributing Member*, Sonatrach

B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

- G. A. Antaki**, *Chair*, Becht Engineering Co., Inc.
J. Minichiello, *Vice Chair*, Bechtel National, Inc.
R. Lucas, *Secretary*, The American Society of Mechanical Engineers
D. Arnett, Fluor Enterprises, Inc.
C. Becht IV, Becht Engineering Co.
R. Bethea, Huntington Ingalls Industries — Newport News Shipbuilding
J. P. Breen, Becht Engineering Co.
P. Cakir-Kavcar, Bechtel Corp. — Oil, Gas, and Chemicals
N. F. Consumo, Sr., Nuclear Engineer
J. P. Ellenberger, Retired
D. J. Fetzner, BP Exploration Alaska, Inc.
D. Fraser, NASA Ames Research Center
J. A. Graziano, Consultant
- R. W. Haupt**, Pressure Piping Engineering Associates, Inc.
B. P. Holbrook, Babcock Power, Inc.
W. J. Koves, Pi Engineering Software, Inc.
R. A. Leishear, Savannah River National Laboratory
G. D. Mayers, Alion Science & Technology
J. F. McCabe, General Dynamics Electric Boat
T. Q. McCawley, TQM Engineering PC
A. W. Paulin, Paulin Research Group
R. A. Robleto, KBR
M. J. Rosenfeld, Kiefner/Applus — RTD
T. Sato, Japan Power Engineering and Inspection Corp.
G. Stevick, Berkeley Engineering & Research, Inc.
H. Kosasayama, *Delegate*, JGC Corp.
E. C. Rodabaugh, *Honorary Member*, Consultant

B31 CONFERENCE GROUP

- A. Bell**, Bonneville Power Administration
R. A. Coomes, Commonwealth of Kentucky, Department of Housing/Boiler Section
D. H. Hanrath
C. J. Harvey, Alabama Public Service Commission
D. T. Jagger, Ohio Department of Commerce — Division of Industrial Compliance
K. T. Lau, Alberta Boilers Safety Association
R. G. Marini, New Hampshire Public Utilities Commission
I. W. Mault, Manitoba Department of Labour
A. W. Meiring, Fire and Building Boiler and Pressure Vessel Division/Indiana
- R. F. Mullaney**, Boiler and Pressure Vessel Safety Branch/Vancouver
P. Sher, State of Connecticut Public Utilities Regulatory Authority
D. A. Starr, Nebraska Department of Labor — Division of Safety
D. J. Stursma, Iowa Utilities Board
R. P. Sullivan, The National Board of Boiler and Pressure Vessel Inspectors
J. E. Troppman, Division of Labor/State of Colorado Boiler Inspections
W. A. M. West, Lighthouse Assistance, Inc.
T. F. Wickham, Rhode Island Department of Labor and Training



B31 QUALIFICATION OF PIPELINE PERSONNEL TECHNICAL COMMITTEE

- A. J. Livingston**, *Chair*, Kinder Morgan
M. Burkhart, *Vice Chair*, Nicor Gas
P. D. Stumpf, *Secretary*, The American Society of Mechanical Engineers
L. B. Ables, Enterprise Products Co.
J. S. Chin, TransCanada Pipeline U.S.
R. L. Cooper, T. D. Williamson, Inc.
K. Denny, Spectra Energy
R. Evans, U.S. Department of Transportation/Pipeline and Hazardous Materials Safety Administration
V. M. Frederick III, Henkels & McCoy
S. A. Goodman, CenterPoint Energy
C. Grimard, TECO Peoples Gas
M. A. Gruenberg, Southwest Gas Corp.
D. Haifleigh, Flint Hills Resources L.P.
B. A. Heck, Miller Pipeline
L. L. Hughes, Laborers–Employers Cooperation and Education Trust
D. D. Lykken, Washington Utilities and Transportation Commission
W. B. McGaughey, Jr., Veriforce
T. Meek, Kinder Morgan
W. Miller, Veriforce, LLC
D. K. Moore, TransCanada
L. P. Murray, R.A.W. Construction, LLC
K. Riddle, Magellan Midstream Partners, L.P.
D. Ristig, Enable Midstream Partners
J. T. Schmitz, Southwest Gas Corp.
R. C. Smith, AGL Resources
R. L. Stump, Consumers Energy
T. Cash, *Contributing Member*, Veriforce
M. R. Comstock, *Contributing Member*
S. C. Gupta, *Contributing Member*, Bharat Petroleum Corp. Ltd.
T. J. Hall, *Contributing Member*, Sunoco Logistics L.P.
G. W. Isbell, *Contributing Member*, ENERGY worldnet, Inc.



ASME B31.12-2014 SUMMARY OF CHANGES

Following approval by the B31 Committee and ASME, and after public review, ASME B31.12-2014 was approved by the American National Standards Institute on October 24, 2014.

Changes given below are identified on the pages by a margin note, **(14)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
2–11	GR-1.5	Definitions of <i>elevated temperature fluid service</i> and <i>ventilated location</i> revised
18, 24	GR-2.1.3	Subparagraph (d) revised
64	GR-5.17	Subparagraph (a) revised
81	IP-3.1	Revised
90	IP-3.8.2	Subparagraph (c) revised
106	IP-8.2.2	Second paragraph added
107	Table IP-8.1.1-1	MSS SP-134 added
108	IP-9.6.1	Subparagraphs (a) through (c) deleted
	IP-9.6.3.1	Revised
109	Table IP-9.6.3-1	Revised
115	Table IP-10.4.3-2	Revised
135, 136	PL-3.7.1	Subparagraphs (b)(1)(-a), (b)(1)(-b), (b)(2)(-c), (b)(2)(-d), and (b)(2)(-e) revised
153, 154	PL-3.21	Subparagraph (o) revised
159, 160	Mandatory Appendix II	(1) Under ASME Standards, API 579/ASME FFS-1 replaced by API 579-1/ASME FFS-1 (2) CSA HGV 4.10-2008 and MSS SP-134-2012 added
216	A-1	(1) Paragraph A-1.1 heading added (2) Paragraph A-1.2 added

NOTE: A separate supplement containing Case 186 follows this edition.



INTENTIONALLY LEFT BLANK



PART GR

GENERAL REQUIREMENTS

Chapter GR-1

Scope and Definitions

GR-1.1 SCOPE

This Code is applicable to piping in gaseous and liquid hydrogen service and to pipelines in gaseous hydrogen service. This Code is applicable up to and including the joint connecting the piping to associated pressure vessels and equipment but not to the vessels and equipment themselves. It is applicable to the location and type of support elements but not to the structure to which the support elements are attached. The design for pressure and temperature shall be in accordance with the requirements of Part IP for industrial piping and Part PL for pipelines. This Code is presented in the following parts and appendices:

(a) *Part GR — General Requirements.* Part GR contains requirements applicable to and referenced by other parts. It contains definitions and requirements for materials, welding, brazing, heat treating, forming, testing, inspection, examination, operation, and maintenance. It also contains quality system topics common to the other parts.

(b) *Part IP — Industrial Piping.* Part IP includes requirements for components, design, fabrication, assembly, erection, inspection, examination, and testing of piping.

(c) *Part PL — Pipelines.* Part PL sets forth requirements for components, design, installation, and testing of hydrogen pipelines.

(d) Mandatory Appendices I through IX

(e) Nonmandatory Appendices A through F

Each part defines requirements for piping or pipelines, as applicable, within its scope. The requirements are different for different aspects of components, design, fabrication, installation, assembly, erection, inspection, examination, and testing. It is required that each part be used in conjunction with the General Requirements section but independent of the other parts. The joint connecting piping governed by two different parts shall

be subject exclusively to the requirements of one of the two parts. It is not intended that this edition of this Code be applied retroactively to existing hydrogen systems.

GR-1.2 RESPONSIBILITIES

GR-1.2.1 Owner

The owner shall have overall responsibility for compliance with this Code and for establishing the requirements for design, construction, examination, inspection, testing, operation, and maintenance of the hydrogen piping or pipeline system.

GR-1.2.2 Designer

The designer is responsible to the owner for assurance that the engineering design of piping or the pipeline system complies with the requirements of this Code and with any additional requirements established by the owner.

GR-1.2.3 Construction Organization

The construction organization of piping and pipeline systems is responsible for providing materials, components, and workmanship in compliance with the requirements of this Code and the engineering design.

GR-1.2.4 Owner's Inspector

The owner's Inspector is responsible to the owner to verify that all required examinations, inspections, and testing are complete. The owner's Inspector verifies that all required certifications and records have been completed. Also, the owner's Inspector is responsible for verification of the construction organization's quality systems program implementation.

