

ANSI/ASSP Z9.14-2020

Testing and Performance-Verification
Methodologies for Biosafety Level 3 (BSL-3)
and Animal Biosafety Level 3 (ABSL-3)
Ventilation Systems



AMERICAN SOCIETY OF
SAFETY PROFESSIONALS



The information and materials contained in this publication have been developed from sources believed to be reliable. However, the American Society of Safety Professionals (ASSP) as secretariat of the ANSI accredited Z9 Committee or individual committee members accept no legal responsibility for the correctness or completeness of this material or its application to specific factual situations. By publication of this standard, ASSP or the Z9 Committee does not ensure that adherence to these recommendations will protect the safety or health of any persons, or preserve property.

ANSI®
ANSI/ASSP Z9.14 –2020

American National Standard

**Testing and Performance-Verification Methodologies
for Biosafety Level 3 (BSL-3) and
Animal Biosafety Level 3 (ABSL-3) Ventilation Systems**

Secretariat

American Society of Safety Professionals
520 N. Northwest Highway
Park Ridge, Illinois 60068

Approved March 31, 2020

American National Standards Institute

American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution. The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he/she has approved the standards or not, from manufacturing, marketing, purchasing or using products, processes or procedures not conforming to the standards. The American National Standards Institute does not develop standards and will in no circumstance give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretation should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published April 2020 by

**American Society of Safety Professionals
520 N. Northwest Highway
Park Ridge, Illinois 60068
(847) 699-2929 • www.assp.org**

Copyright ©2020 by American Society of Safety Professionals
All Rights Reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

FOREWORD (This Foreword is not part of the American National Standard ANSI/ASSP Z9.14–2020.)

The Z9.14 Subcommittee was chartered to develop the American National Standard, Testing and Performance-Verification Methodologies for Biosafety Level 3 (BSL-3) and Animal Biosafety Level 3 (ABSL-3) Ventilation Systems.

Over 1,000 BSL-3/ABSL-3 laboratories and animal facilities have been constructed in the United States. The design for their ventilation systems has been largely guided by the criteria defined in successive versions of *Biosafety in Microbiological and Biomedical Laboratories (BMBL)* from the Department of Health and Human Services (DHHS), the Centers for Disease Control and Prevention (CDC), and the National Institutes of Health (NIH) (*Biosafety in Microbiological and Biomedical Laboratories (BMBL) n.d.*)¹; the American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) standards²; *U.S. Department of Agriculture Animal Research Service (USDA ARS) 242.1 Manual*³; *World Health Organization (WHO) Biosafety Guidelines: Biosafety Manual*⁴; and the *National Institutes of Health Design Requirements Manual (DRM)*.⁵ Many of these guidelines offer design requirements, but lack the testing and performance-verification methodology to ensure the safe operation of the ventilation system for these laboratories.

Using a risk assessment and performance-based approach, this standard provides the technical specifications and background information needed to address the technical, engineering, and associated systems for ventilation within a BSL-3/ABSL-3 laboratory. As such, it is fully compatible with biorisk-management systems and national and international health and safety management systems without duplicating or contradicting their requirements.

The purpose of the ventilation system is to provide the necessary environment for biocontainment, occupational health, and animal health in accordance with standards and containment guidelines. It specifically is designed to prevent unintended release of aerosolized infectious biological agents.

The ANSI/ASSP Z9.14 standard provides the combined knowledge acquired over the years by biosafety professionals, design professionals, and owners/operators of BSL-3/ABSL-3 laboratories, which establishes the requirements and methodologies for the testing and performance verification of the ventilation system.

The ANSI/ASSP Z9.14 standard focuses specifically on the ventilation system features of BSL-3/ABSL-3 facilities. Because the ventilation system is affected by and has an effect on other systems and equipment in a laboratory, those systems and equipment may be included in the standard, to some extent, as an associated system.

ANSI/ASSP Z9.14 provides testing standardization, uniformity, and consistency through the use of minimal performance-based testing and verification methodologies for BSL-3/ABSL-3 ventilation systems in facilities.

How to Read This Standard

ANSI/ASSP Z9.14 is presented in a two-column format. Beginning with section 5.0, Applicability and Conformance, the left column presents the requirements of the standard; the right column provides clarification and explanation of the requirements and information on “how to comply” to the standard. The standard contains appendices that are informative and are not considered a mandatory part of the standard. The standard is not meant to be all-encompassing. Rather, it establishes minimum acceptable criteria for completing the verification process and documenting the necessary information for regulatory and historical purposes. It is somewhat general in nature so that it can be applied to any BSL-3/ABSL-3 laboratory. We hope, however, that future versions will continue to expand and amplify these concepts as additional experience is gained. Suggestions for improvement of this standard are welcome, they should be sent to: American Society of Safety Professionals, 520 N. Northwest Highway, Park Ridge, IL 60068.

This standard was processed and approved for submittal to ANSI by the American National Standards Committee on Ventilation Systems. Approval of the standard does not necessarily imply (nor is it required) that all Committee members voted for its approval. At the time ANSI approved this standard, the Z9 Committee had the following members:

Geoffrey Raifsnider, P.E., Chair

Terry Ketchum, Vice Chair

Ovidiu Munteanu, Secretary

Timothy R. Fisher, CSP, CHMM, CPEA, CAE, ARM, STS, Assistant Secretary

Jennie Dalesandro, Administrative Technical Support

Organization Represented

Name of Representative

American Foundry Society

Robert Scholz

American Industrial Hygiene Association

Thomas Slavin, CIH, CSP, CSHM, CPEA

American Society of Safety Professionals

Lou DiBerardinis, CIH, CSP

Paul Osley, P.E., CSP, CIH, CHMM

ASHRAE

Jeffrey Nesbitt, CIH, CSP

AstraZeneca

Thomas Smith

Victor D'Amato

Burton, D. Jeff

Matthew Thomas

Covestro LLC

D. Jeff Burton, P.E.

Figueroa, Crescente

Terry Ketchum

Global Finishing Solutions

Crescente Figueroa, Ph.D., CIH

Geoffrey Raifsnider, P.E.

Job Safety Associates, LLC

Brian Schadrie, P.E.

Knutson Ventilation Inc.

Peter Engelbert, CIH, CSP, CHST, CET

Theodore Knutson, MS, P.E.

Gerhard Knutson, Ph.D., CIH

National Association for Surface Finishing

National Institute for Occupational Safety & Health

National Institutes of Health

NorthWest Occupational Health & Safety

Price, John

Robson Forensic, Inc.

Rutgers University

Saint-Gobain Abrasives Inc.

Sherwin-Williams Company

Thermo Fisher Scientific

Kyle Hankinson

Kenneth Hankinson

Michael Elliott, Ph.D., P.E., CIH

Farhad Memarzadeh, Ph.D., P.E.

Neil McManus, DSc, CIH, ROH, CSP

John (Jack) Price

Ronald Schaible, CSP, CIH

Alejandro Ruiz, CIH, CSP, CHMM, CET, SMS

Holly Colt

Brian Haynack

Jay Dick

Daniel Kallin

Non-Voting Members:

EI Group, Inc.

U.S. Department of Labor - OSHA

Lindsay Cook

James Nelson, P.E.

The Z9.14 Subcommittee

The Z9.14 Subcommittee on Testing and Performance-Verification Methodologies for Biosafety Level 3 (BSL-3) and Animal Biosafety Level 3 (ABSL-3) Ventilation Systems that developed this standard was comprised of the following members:

Farhad Memarzadeh, Ph.D., P.E., Chair, National Institutes of Health (NIH)
Director, Division of Technical Resources

Louis DiBerardinis, CIH, CSP, Vice Chair, Massachusetts Institute of Technology (MIT)
Director, Environment, Health and Safety Office

Organization Represented

Name of Representative

Affiliated Engineers Metro DC, Inc.

Kansas State University

National Institutes of Health

Sandia National Laboratories

SCB Compose

Tulane University

U.S. Department of Agriculture

University of Alabama

University of California, Irvine

Krishnan Ramesh

John Henneman

Nika Lilley

Vibeke Hakjaer-Knudsen

Sheri Bernstein

Angela Birnbaum

Kirk Martin, DPM, CBSP

Joseph Kozlovac

Julie Gibbs-Erwin

Gary Landucci

| Contents | SECTION..... | PAGE |
|-----------------|---|------|
| | 1. Executive Summary | 1 |
| | 2. Purpose..... | 2 |
| | 3. Scope..... | 2 |
| | 4. Definitions | 3 |
| | 5. Applicability and Conformance | 13 |
| | 5.1 Applicability | 13 |
| | 5.2 Conformance..... | 15 |
| | 5.3 Verification of Conformance to Regulations..... | 17 |
| | 6. Overview | 18 |
| | 6.1 Ventilation-Testing Performance Categories..... | 18 |
| | 6.2 Generic Typical Sequence of Testing and Performance- Verification..... | 19 |
| | 6.3 Roles, Responsibilities, and Qualifications..... | 23 |
| | 6.3.1 Role/Responsibility as It Relates to a BSL-3/ ABSL-3 Facility | 26 |
| | 7. Risk Assessment and Corrective Action Plan..... | 29 |
| | 7.1 Risk Assessment Overview for Work with Hazardous Agents/Materials (refer to Appendices A-B)..... | 29 |
| | 7.2 Corrective Action Plan (refer to Appendix C) | 31 |
| | 8. Guidelines for Implementing Testing and Performance Verification..... | 32 |
| | 8.1 Verification..... | 32 |
| | 8.2 Documentation | 33 |
| | 8.2.1 Required and Recommended Documentation | 34 |
| | 8.2.2 Evidence of Documentation | 35 |
| | 8.2.3 Ventilation-Testing Documentation Verification..... | 38 |
| | 8.3 Visual Inspection of Ventilation and Related Systems..... | 40 |
| | 8.3.1 Visual Inspection and Evaluation of Engineering Controls | 41 |
| | 8.3.2 Visual Inspection and Evaluation of Architectural Features | 43 |
| | 8.3.3 Visual Inspection of Directional Airflow | 45 |
| | 8.3.4 Visual Inspection of Exhaust Air System..... | 47 |
| | 8.3.5 Visual Inspection of Supply Air System..... | 53 |
| | 8.3.6 Visual Inspection of Critical Control System Air and Power | 58 |
| | 8.3.7 Primary Containment Equipment | 61 |
| | 8.3.8 Visual Inspection of High-Efficiency Particulate Air (HEPA) Filters..... | 63 |
| | 8.3.9 Control Systems/Fail-Safe Operation..... | 67 |
| | 8.3.10 Visual Inspection: Special Considerations for ABSL-3 Facilities | 67 |

| | | |
|--------|--|-----|
| 8.4 | Testing Ventilation and Associated Systems General Requirements | 68 |
| 8.4.1 | Testing for Directional Airflow During Normal Operation ... | 69 |
| 8.4.2 | Testing for Directional Airflow During System Failures..... | 74 |
| 8.4.3 | Testing for Anterooms..... | 81 |
| 8.4.4 | Testing of Primary Containment Equipment..... | 83 |
| 8.4.5 | Testing of Heating, Ventilating, and Air-Conditioning (HVAC) System and Controls | 88 |
| 8.4.6 | Testing of Electrical Systems Related to Heating, Ventilating, and Air-Conditioning (HVAC)..... | 107 |
| 8.4.7 | Testing of High-Efficiency Particulate Air (HEPA) Filters. | 112 |
| 8.4.8 | Testing of Ductwork and Room-Air Leakage | 118 |
| 8.4.9 | Testing of Specialized Heating, Ventilating, and Air-Conditioning (HVAC) Components of ABSL-3 Facilities.. | 123 |
| 8.4.10 | Testing of Heating, Ventilating, and Air-Conditioning (HVAC) Systems of Containment Support Areas | 127 |
| | Appendices | 129 |
| A | The Risk Assessment Process | 129 |
| B | Risk Assessment Methodologies..... | 138 |
| C | Corrective Action Plan | 140 |
| D | Checklists..... | 143 |
| E | How to Compile a Standard Operating Procedure (SOP) | 177 |
| F | Index of Acronyms..... | 180 |
| G | References..... | 182 |

American National Standard for Testing and Performance-Verification Methodologies for Biosafety Level 3 (BSL-3) and Animal Biosafety Level 3 (ABSL-3) Ventilation Systems

1 EXECUTIVE SUMMARY

Testing and verification of the ventilation system of laboratories that operate at Biosafety Level 3 (BSL-3)/Animal Biosafety Level 3 (ABSL-3) are necessary processes for ensuring that the performance and operation of the systems consistently maintain a safe environment for human occupants, research animals, and the internal and external environment. Because each facility is unique, testing and verification acceptance criteria will differ among facilities. Therefore, a risk-based approach to testing and verification of the ventilation system is recommended. It is highly encouraged that each facility develops and maintains standard operating procedures (SOPs) that address testing and verification of the ventilation system and associated components. Additionally, there should be SOPs for performing a risk assessment and for the sequence of testing and performance verification. Risk assessments should be performed initially and at least annually throughout the life cycle of the facility.

ANSI Z9.14 provides recommendations for testing methodologies, guidance on the ventilation system components that should be inspected visually, and what is needed to verify that the system components operate such that the overall system's performance (i.e., directional inward airflow, response to failures, minimizing leakage, etc.) can be verified to ensure safe operation of the facility's ventilation system. A verification program needs to consider and compare federal, state, and local regulations for future use, best practices, and organizational requirements.

This standard provides the user with:

- Testing standardization, uniformity, and consistency through the use of minimal performance-based testing and verification methodologies for BSL-3/ABSL-3 ventilation systems
- Technical background and information that addresses the engineering and associated systems for ventilation within a BSL-3/ABSL-3 laboratory using the many tenants of a risk assessment and performance-based approach that is fully compatible with biorisk-management systems and national and international health and safety-management systems without duplicating or contradicting their requirements
- Risk assessment guidance and methodologies to identify hazards that can be evaluated in terms of the likelihood that a problem may occur and

the damage from such an event that may occur

- The collective knowledge of biosafety and design professionals and owners/operators who recognize the need to establish uniformity in the requirements and methodologies for the testing and performance verification of the ventilation system of BSL-3/ABSL-3 laboratories

The criteria contained herein should be supplemented, expanded, or consolidated as required to adapt to the specific testing and verification effort, the organization, and the specific regulatory and policy requirements that may apply in each case. Suggested acceptance criteria, where available, are provided in the standard. Establishment of acceptance criteria is the responsibility of facility management.

Acceptance criteria should be based on site-specific risk assessment and performance objectives.

2 PURPOSE

The purpose of ANSI Z9.14 is to provide a “one-stop” resource for guidance to inspect and test the performance of a BSL-3/ABSL-3 laboratory ventilation system.

3 SCOPE

Methodologies are provided to perform visual inspection and evaluation of:

1. Directional airflow
2. Anterooms

3. Primary containment systems
4. Building ventilation system
5. Heating, ventilation, and air-conditioning (HVAC) testing
6. Filtration
7. ABSL-3 and integration of individually ventilated caging, static caging systems, other elements; and downdraft tables
8. Document verification
9. Pressure reversal
10. Failure testing
11. Leakage issues related to HVAC
12. Qualifications of testers

ANSI Z9.14 focuses on performance verification of ventilation system-engineering controls and related systems within a BSL-3/ABSL-3 laboratory.

Testing and verification of ventilation systems in BSL-3/ABSL-3 labs include:

- Supply
- Exhaust
- Directional airflow
- Biosafety cabinets
- Air filtration
- Exhaust stacks
- Fan failure scenarios
- Redundancy
- Canopy hoods (autoclaves)
- Specific ABSL-3 requirements

Testing and verification of related systems within BSL-3/ABSL-3 labs include:

- Optimizing maintenance of pressure gradients and maintaining temperature and humidity
- Physical integrity