



BSI Standards Publication

Communication networks and systems for power utility automation

Part 90-12: Wide area network engineering guidelines

National foreword

This Published Document is the UK implementation of IEC TR 61850-90-12:2020. It supersedes PD IEC/TR 61850-90-12:2015, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/57, Power systems management and associated information exchange.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 539 02142 4

ICS 33.200

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2020.

Amendments/corrigenda issued since publication

| Date | Text affected |
|------|---------------|
|------|---------------|



IEC TR 61850-90-12

Edition 2.0 2020-07

TECHNICAL REPORT



Communication networks and systems for power utility automation – Part 90-12: Wide area network engineering guidelines

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-8657-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|--|----|
| FOREWORD..... | 12 |
| INTRODUCTION..... | 14 |
| 1 Scope..... | 16 |
| 2 Normative references | 16 |
| 3 Terms, definitions, abbreviated terms, acronyms, and symbols..... | 21 |
| 3.1 Terms and definitions..... | 21 |
| 3.2 Abbreviated terms and acronyms | 25 |
| 3.3 Network diagram symbols | 34 |
| 4 Wide area communication in electrical utilities..... | 36 |
| 4.1 Executive summary..... | 36 |
| 4.2 Network and application example: ENDESA, Andalusia (Spain) | 38 |
| 4.3 Typical interface between a substation and the WAN | 40 |
| 4.4 WAN characteristics and actors | 41 |
| 4.5 Smart Grid Architecture Model (SGAM) Mapping | 42 |
| 4.6 Network elements and voltage level..... | 44 |
| 4.7 WAN interfaces in substation automation (IEC 61850-5) | 45 |
| 4.8 Logical interfaces and protocols in the architecture in IEC TR 62357-200 | 46 |
| 4.9 Network traffic and ownership | 47 |
| 5 WAN metrics | 48 |
| 5.1 Traffic types..... | 48 |
| 5.2 Quality of Service (QoS) of TDM and PSN | 48 |
| 5.3 Latency calculation | 48 |
| 5.3.1 Latency components..... | 48 |
| 5.3.2 Propagation delay..... | 49 |
| 5.3.3 Residence delay | 49 |
| 5.3.4 Latency accumulation | 49 |
| 5.3.5 Example: latency of a microwave system..... | 49 |
| 5.3.6 Latency and determinism..... | 50 |
| 5.3.7 Latency classes in IEC 61850-5..... | 50 |
| 5.4 Jitter | 52 |
| 5.4.1 Jitter definition..... | 52 |
| 5.4.2 Jitter classes in IEC 61850 | 53 |
| 5.5 Latency symmetry and path congruency | 53 |
| 5.6 Medium asymmetry..... | 53 |
| 5.7 Communication speed symmetry..... | 54 |
| 5.8 Recovery delay | 54 |
| 5.9 Time accuracy | 54 |
| 5.9.1 Time accuracy definition..... | 54 |
| 5.9.2 Time accuracy classes..... | 55 |
| 5.10 Tolerance against failures..... | 56 |
| 5.10.1 Failure | 56 |
| 5.10.2 Reliability..... | 57 |
| 5.10.3 Redundancy principles..... | 57 |
| 5.10.4 Redundancy and reliability..... | 58 |
| 5.10.5 Redundancy checking..... | 59 |
| 5.10.6 Redundant layout: single point of failure | 59 |

| | | |
|---------|--|-----|
| 5.10.7 | Redundant layout: cross-redundancy | 60 |
| 5.10.8 | Maintainability | 61 |
| 5.10.9 | Availability | 61 |
| 5.10.10 | Integrity | 63 |
| 5.10.11 | Dependability..... | 64 |
| 5.10.12 | Example: Dependability of GOOSE transmission | 64 |
| 6 | Use cases and WAN communication requirements | 65 |
| 6.1 | List of generic use cases | 65 |
| 6.2 | Teleprotection (IF2 & IF11) | 66 |
| 6.2.1 | Teleprotection schemes..... | 66 |
| 6.2.2 | Teleprotection data kinds..... | 66 |
| 6.2.3 | Current differential teleprotection for multi-terminal transmission line | 66 |
| 6.2.4 | Teleprotection communication requirements | 67 |
| 6.3 | Wide area monitoring system (IF13)..... | 69 |
| 6.3.1 | WAMS overview | 69 |
| 6.3.2 | WAMS topology | 70 |
| 6.3.3 | WAMS communication requirements..... | 72 |
| 6.4 | Wide area monitoring, protection, and control (WAMPAC) IF13..... | 74 |
| 6.4.1 | Functional description..... | 74 |
| 6.4.2 | WAMPAC communication requirements | 76 |
| 6.5 | Fault Location | 76 |
| 6.5.1 | Functional description..... | 76 |
| 6.5.2 | Fault location communication requirements | 78 |
| 6.6 | Distribution Automation | 78 |
| 6.6.1 | Functional description..... | 78 |
| 6.6.2 | Distribution automation communication requirements | 79 |
| 6.7 | Condition monitoring and diagnostics (CMD) and asset management (IF7) | 80 |
| 6.7.1 | Functional description..... | 80 |
| 6.7.2 | CMD communication requirements | 80 |
| 6.8 | Telecontrol (SCADA)..... | 81 |
| 6.8.1 | Functional description..... | 81 |
| 6.8.2 | Telecontrol communication requirements | 81 |
| 6.9 | Control centre to control centre (IF12) | 82 |
| 6.9.1 | Functional description..... | 82 |
| 6.9.2 | Inter control centre communication requirements | 83 |
| 6.10 | Smart metering / advanced metering infrastructure | 84 |
| 6.10.1 | Functional description..... | 84 |
| 6.10.2 | Smart metering communication requirements | 84 |
| 6.11 | WAN communication requirements summary | 85 |
| 7 | Wide-area and real-time network technologies..... | 86 |
| 7.1 | General..... | 86 |
| 7.2 | Topology..... | 86 |
| 7.3 | Overview..... | 87 |
| 7.4 | Layer 1 (physical) transmission media | 89 |
| 7.4.1 | Summary | 89 |
| 7.4.2 | Installation guidelines | 89 |
| 7.4.3 | Metallic lines | 89 |
| 7.4.4 | Power line carrier (PLC) | 91 |
| 7.4.5 | Radio transmission | 101 |

| | | |
|--------|---|-----|
| 7.4.6 | Fibre optics..... | 112 |
| 7.4.7 | Layer 1 redundancy | 118 |
| 7.4.8 | Application example: diverse redundancy against extreme contingencies (Hydro-Quebec)..... | 119 |
| 7.4.9 | Layer 1 security | 120 |
| 7.5 | Layer 1,5 (physical) multiplexing | 120 |
| 7.6 | Layer 2 (link) technologies | 121 |
| 7.6.1 | Telephony technologies | 121 |
| 7.6.2 | SDH/SONET | 123 |
| 7.6.3 | Optical Transport Network | 133 |
| 7.6.4 | Ethernet | 135 |
| 7.6.5 | Ethernet over TDM | 144 |
| 7.6.6 | Carrier Ethernet..... | 146 |
| 7.6.7 | Audio-video bridging | 147 |
| 7.6.8 | Provider Backbone Bridge (PBB) | 147 |
| 7.6.9 | Multiprotocol Label Switching (MPLS)..... | 149 |
| 7.7 | Layer 3 (network) technologies | 157 |
| 7.7.1 | Internet Protocol (IP) | 157 |
| 7.7.2 | IP QoS..... | 167 |
| 7.7.3 | IP multicast..... | 170 |
| 7.7.4 | IP redundancy | 171 |
| 7.7.5 | IP security | 171 |
| 7.7.6 | IP communication for utilities | 173 |
| 7.7.7 | IP summary | 175 |
| 7.8 | Layer 4 (transport) protocols | 176 |
| 7.8.1 | Transport layer encapsulation..... | 176 |
| 7.8.2 | UDP | 176 |
| 7.8.3 | TCP..... | 177 |
| 7.8.4 | Layer 4 redundancy | 178 |
| 7.8.5 | Layer 4 security | 178 |
| 7.9 | Layer 5 (session) and higher..... | 178 |
| 7.9.1 | Session layer..... | 178 |
| 7.9.2 | Routable GOOSE and SMV | 179 |
| 7.9.3 | Example: C37.118 transmission..... | 179 |
| 7.9.4 | Session protocol for voice and video transmission | 180 |
| 7.9.5 | Application interface redundancy | 180 |
| 7.9.6 | Application device redundancy | 181 |
| 7.10 | Protocol overlay – tunnelling | 181 |
| 7.10.1 | Definitions | 181 |
| 7.10.2 | Tunnelling principle | 182 |
| 7.10.3 | Tunnelling Layer 2 over Layer 3..... | 182 |
| 7.10.4 | Application Example: Tunnelling GOOSE and SMV in IEC 61850 | 183 |
| 7.11 | Virtual private networks (VPNs) | 184 |
| 7.11.1 | VPN principles..... | 184 |
| 7.11.2 | L2VPNs | 184 |
| 7.11.3 | L2VPN multicast on MPLS | 186 |
| 7.11.4 | L3VPN..... | 186 |
| 7.11.5 | VPN mapping to application..... | 188 |
| 7.12 | Cyber security..... | 192 |

| | | |
|---------|---|-----|
| 7.12.1 | Security circles | 192 |
| 7.12.2 | Network security | 193 |
| 7.12.3 | Access control | 195 |
| 7.12.4 | Threat detection and mitigation..... | 195 |
| 7.12.5 | Security architecture | 199 |
| 7.12.6 | Application (end-to-end) communication security | 200 |
| 7.12.7 | Security for synchrophasor (PMU) networks (IEC TR 61850-90-5) | 201 |
| 7.12.8 | Additional recommendations | 202 |
| 7.13 | QoS and application-specific engineering..... | 202 |
| 7.13.1 | General | 202 |
| 7.13.2 | SDH/SONET QoS and SLA..... | 202 |
| 7.13.3 | PSN QoS and SLA..... | 202 |
| 7.13.4 | Application and priority | 203 |
| 7.13.5 | QoS chain between networks..... | 203 |
| 7.13.6 | QoS mapping between networks | 204 |
| 7.13.7 | QoS engineering | 205 |
| 7.13.8 | Customer restrictions..... | 206 |
| 7.13.9 | Clock services | 206 |
| 7.14 | Configuration and OAM..... | 206 |
| 7.14.1 | Network configuration | 206 |
| 7.14.2 | OAM | 206 |
| 7.15 | Time synchronization | 208 |
| 7.15.1 | Oscillator stability | 208 |
| 7.15.2 | Mutual synchronization | 209 |
| 7.15.3 | Direct synchronization | 209 |
| 7.15.4 | Radio synchronization | 210 |
| 7.15.5 | GNSS synchronization | 210 |
| 7.15.6 | Frequency distribution | 210 |
| 7.15.7 | Time distribution | 212 |
| 7.15.8 | PTP telecommunication profiles..... | 218 |
| 7.15.9 | PTP over MPLS | 219 |
| 7.15.10 | Comparison of time distribution profiles based on IEC 61588..... | 219 |
| 7.15.11 | Application example: synchrophasor time synchronization | 220 |
| 7.15.12 | Application example: Atomic clock hierarchy..... | 221 |
| 8 | Technology mapping to applications | 222 |
| 8.1 | Overview..... | 222 |
| 8.2 | Current differential teleprotection for multi-terminal transmission lines | 222 |
| 8.2.1 | General | 222 |
| 8.2.2 | Deterministic fibre-optic PDH loop network | 223 |
| 8.2.3 | Dedicated Gigabit Ethernet network..... | 223 |
| 8.2.4 | Carrier Ethernet with wide-area time synchronization..... | 224 |
| 8.2.5 | MPLS based wide area network | 225 |
| 8.3 | Wide area monitoring, protection, and control (WAMPAC)..... | 227 |
| 8.3.1 | General | 227 |
| 8.3.2 | Wide area stabilizing control using legacy network | 227 |
| 8.3.3 | PMU-based WAMPAC using time-synchronized Layer 2 and Layer 3 network..... | 229 |
| 8.4 | Fault location | 231 |
| 8.5 | SCADA and facility maintenance..... | 232 |

| | | |
|-----------------------|--|-----|
| 8.6 | Distribution automation | 234 |
| 8.7 | Smart metering | 234 |
| 9 | Network migration..... | 237 |
| 9.1 | TDM to packet switched network..... | 237 |
| 9.1.1 | General | 237 |
| 9.1.2 | Overview | 237 |
| 9.1.3 | Drivers for network migration..... | 237 |
| 9.1.4 | Considerations for network migration..... | 238 |
| 9.1.5 | Migration concepts | 240 |
| 9.1.6 | Implementation details..... | 246 |
| 9.2 | From IPv4 to IPv6..... | 250 |
| 9.2.1 | IPv4 to IPv6 evolution..... | 250 |
| 9.2.2 | IPv4 to IPv6 migration | 250 |
| 9.2.3 | IEC 61850 stack with IPv4 and IPv6 | 251 |
| Annex A (informative) | Future promising or upcoming technologies..... | 252 |
| A.1 | 5G | 252 |
| A.1.1 | General | 252 |
| A.1.2 | Different performance requirements..... | 253 |
| A.2 | Deterministic networking technologies | 256 |
| Bibliography | | 257 |
| Figure 1 | – Symbols | 35 |
| Figure 2 | – Substation locations in Andalusia..... | 38 |
| Figure 3 | – Topology of the Andalusia network..... | 39 |
| Figure 4 | – Cabinet of a substation edge node | 40 |
| Figure 5 | – Communication interfaces in a SEN | 41 |
| Figure 6 | – Communicating entities | 42 |
| Figure 7 | – SGAM communication model..... | 43 |
| Figure 8 | – Principle of grid voltage level and network technology..... | 44 |
| Figure 9 | – Communication paths and interfaces..... | 45 |
| Figure 10 | – IEC TR 62357 Interfaces, protocols, and applications..... | 46 |
| Figure 11 | – Composition of end-to-end latency in a microwave relay | 49 |
| Figure 12 | – Example of latency in function of traffic | 50 |
| Figure 13 | – Jitter for two communication delay types | 52 |
| Figure 14 | – Precision and accuracy definitions | 55 |
| Figure 15 | – Redundancy of redundant systems..... | 58 |
| Figure 16 | – Redundancy calculation | 59 |
| Figure 17 | – Redundancy layout with single point of failure..... | 59 |
| Figure 18 | – Redundancy layout with cross-coupling..... | 60 |
| Figure 19 | – Availability definitions..... | 61 |
| Figure 20 | – Residual error rate as a function of BER | 63 |
| Figure 21 | – Network configurations for multi-terminal line protection..... | 67 |
| Figure 22 | – Principle of synchrophasor transmission..... | 71 |
| Figure 23 | – PMUs and data flow between TSO and regional data hubs..... | 72 |
| Figure 24 | – Target phenomena for WAMPAC..... | 74 |

| | |
|---|-----|
| Figure 25 – Example of main function and general information flow | 75 |
| Figure 26 – Network configuration for a fault locator system | 77 |
| Figure 27 – System configuration for distribution automation | 79 |
| Figure 28 – Network configurations for CMD and asset management..... | 80 |
| Figure 29 – Logical network configuration for telecontrol (SCADA) | 81 |
| Figure 30 – Network configurations for inter-control centre | 83 |
| Figure 31 – System configuration for smart metering | 84 |
| Figure 32 – Network ring topology example | 87 |
| Figure 33 – Narrowband channel plans for LV PLC Europe vs. North America | 93 |
| Figure 34 – HF allocated frequency spectrum plans for LV BPL | 93 |
| Figure 35 – Narrowband spectrum usage vs. standards and regulation areas [57] | 94 |
| Figure 36 – HV PLC link building blocks..... | 96 |
| Figure 37 – Phase-to-ground coupling for PLC..... | 97 |
| Figure 38 – HV PLC coupling with suspended line traps | 97 |
| Figure 39 – Phase-to-phase signal coupling for PLC | 98 |
| Figure 40 – Phase-to-phase signal coupling..... | 98 |
| Figure 41 – Power line carrier, line traps..... | 99 |
| Figure 42 – Terrestrial microwave link | 102 |
| Figure 43 – Layer 2 transport on microwave radio systems | 103 |
| Figure 44 – DMR (Digital Mobile Radio) | 106 |
| Figure 45 – LoRaWAN™ Protocol Stack | 108 |
| Figure 46 – ADSS fibre cable..... | 113 |
| Figure 47 – ADSS installation with splicing box..... | 113 |
| Figure 48 – OPGW in ground cable..... | 114 |
| Figure 49 – OPGW with two "C"-tubes each with 32 fibers | 114 |
| Figure 50 – OPGW fibers | 115 |
| Figure 51 – Splicing box | 116 |
| Figure 52 – WDM over one fibre | 117 |
| Figure 53 – OCh optical components | 117 |
| Figure 54 – Optical link with microwave back-up | 119 |
| Figure 55 – Photograph of a partially destroyed 735 kV line..... | 120 |
| Figure 56 – E1 and E2 channels | 122 |
| Figure 57 – Digital transmission hierarchy (T-standards)..... | 122 |
| Figure 58 – Digital transmission hierarchy (E-standard) | 123 |
| Figure 59 – Example of an SDH network for utilities..... | 124 |
| Figure 60– SONET multiplexing hierarchy..... | 125 |
| Figure 61 – SDH multiplexing hierarchy | 125 |
| Figure 62 – SDH/SONET with point-to-point topology | 127 |
| Figure 63 – SDH/SONET with linear topology | 127 |
| Figure 64 – BLSR/BSHR topology in normal conditions (from A to D)..... | 129 |
| Figure 65 – BLSR/BSHR topology in failure conditions..... | 129 |
| Figure 66 – SNCP/UPSR topology in normal conditions | 130 |
| Figure 67 – SNCP/UPSR topology in failure conditions | 131 |

Figure 68 – Example of information flow relationship in OTN 134

Figure 69 – IEEE 802.3 (Ethernet) frame format 135

Figure 70 – IEEE 802.3 (Ethernet) topology with RSTP switches 136

Figure 71 – IEEE 802.1Q-tagged Ethernet frame format 137

Figure 72 – Direct Ethernet with VLAN in substation-to-substation transmission 138

Figure 73 – Substation-to-substation Layer 2 transmission tunnelled over IP 139

Figure 74 – PRP structure (within and outside a substation) 140

Figure 75 – HSR ring connecting substations and control centre 141

Figure 76 – MACsec frame format 142

Figure 77 – IEEE 802.1X principle 143

Figure 78 – Ethernet for substation-to-substation communication 144

Figure 79 – Packets over TDM 145

Figure 80 – IEEE 802.1Q/ad/ah network configuration 148

Figure 81 – Basic MPLS architecture 150

Figure 82 – Example of MPLS frame format with IPv4 payload 150

Figure 83 – MPLS building blocks 151

Figure 84 – MPLS network architecture for utilities 153

Figure 85 – IP/MPLS and MPLS-TP features 154

Figure 86 – MPLS-TP redundant routing 156

Figure 87 – Ethernet frame with IP network header 157

Figure 88 – Mapping of IPv4 to Ethernet frames 158

Figure 89 – Mapping of IPv6 to Ethernet frames 161

Figure 90 – IPv6 unicast address structure 162

Figure 91 – IPv6 ULA address structure 163

Figure 92 – IPv6 link local address structure 163

Figure 93 – Mapping of IPv4 to IPv6 addresses 166

Figure 94 – DiffServ codepoint field 169

Figure 95 – Unidirectional protocol independent multicast 170

Figure 96 – Bidirectional protocol independent multicast 171

Figure 97 – Frame format for IPsec (authenticated) 172

Figure 98 – Frame format for IPsec (encrypted) 172

Figure 99 – Layer 3 direct connection within same address space 173

Figure 100 – Connecting substations to SCADA by a NAT 174

Figure 101 – Substation to SCADA connection over ALG 175

Figure 102 – Ethernet frame with UDP transport layer 176

Figure 103 – UDP header 177

Figure 104 – TCP header 177

Figure 105 – Session and presentation layers for MMS 179

Figure 106 – Session and presentation layers for R-GOOSE 179

Figure 107 – IEEE C37.118 frame over UDP 180

Figure 108 – Redundant network transmission handled by the application layer 180

Figure 109 – Tunnelling in IEC TR 61850-90-1 182

Figure 110 – L2TP transporting Layer 2 frames over IP 183

| | |
|--|-----|
| Figure 111 – Tunneling SMV over IP in IEC TR 61850-90-5 | 184 |
| Figure 112 – L2VPNs VPWS and VPLS | 185 |
| Figure 113 – L3VPN | 186 |
| Figure 114 – Emulation of L3VPN by L2VPN and global router | 188 |
| Figure 115 – Tele-protection over VPWS | 190 |
| Figure 116 – WAMS over VPLS | 190 |
| Figure 117 – VPN for IP-based SCADA/EMS traffic | 191 |
| Figure 118 – VPN deployment options | 194 |
| Figure 119 – IP network separator | 196 |
| Figure 120 – Security architecture (using segmentation and perimeter security) | 200 |
| Figure 121 – QoS chain | 204 |
| Figure 122 – Timing pulse transmission methods of legacy teleprotection devices | 209 |
| Figure 123 – SyncE application..... | 211 |
| Figure 124 – Synchronous Ethernet architecture..... | 211 |
| Figure 125 – SNTP clock synchronization and network delay measurement..... | 213 |
| Figure 126 – Model of GMC, two BCs in series and SC over Layer 3 | 216 |
| Figure 127 – Timing diagram of PTP (end-to-end, 2-step, TC and BC)..... | 216 |
| Figure 128 – Timing diagram of PTP (peer-to-peer, 2-step TCs) | 217 |
| Figure 129 – Substations synchronization over WAN | 221 |
| Figure 130 – Example of synchronization network..... | 222 |
| Figure 131 – Distributed loop configuration for HV multi-terminal line protection | 223 |
| Figure 132 – Current differential teleprotection for HV multi-terminal transmission line using Layer 2 network | 224 |
| Figure 133 – Configuration of wide area current differential primary and backup teleprotection system employing Carrier Ethernet and IEC 61588 time synchronization | 225 |
| Figure 134 – Current differential protection communication via MPLS network..... | 226 |
| Figure 135 – System configuration for wide area stabilizing control system..... | 228 |
| Figure 136 – Appearance of typical CCE cubicle..... | 228 |
| Figure 138 – IEEE 802.1Q/ad utility network..... | 232 |
| Figure 139 – Mixed SDH/MPLS network for SCADA and facility maintenance services | 233 |
| Figure 140 – Wired technology solutions for distribution automation | 234 |
| Figure 141 – Wireless technology solutions for distribution automation (Radio network in feeder automation)..... | 234 |
| Figure 142 – Multi-hop wireless system | 235 |
| Figure 143 – NB-PLC system..... | 235 |
| Figure 144 – Cellular services used for a low-density residential area..... | 235 |
| Figure 145 – WAN communication protocols for smart metering..... | 236 |
| Figure 146 – Migration path from TDM to Packet in the Power Utility Operational Network | 243 |
| Figure 147 – Ethernet or MPLS beside SDH over separate fibre or wavelength..... | 244 |
| Figure 148 – Ethernet or MPLS-TP and SDH in a Hybrid platform..... | 244 |
| Figure 149 – Pseudo-wire principle | 247 |
| Figure 150 – Non-IP voice communication over PSN | 248 |
| Figure 151 – Circuit emulation over PSN | 249 |

| | |
|---|-----|
| Figure 152 – IPv6 evolution | 250 |
| Figure 153 – IEC 61850 stack with IPv4 and IPv6 (doubly attached) | 251 |
| Figure A.1 – Software network technologies in 5G overall architecture | 253 |
| Figure A.2 – 5G Conceptual Diagram – NGMN | 254 |
| Figure A.3 – NB-IOT deployment models | 255 |
| | |
| Table 1 – Latency classes in IEC 61850-5 | 51 |
| Table 2 – Latency classes in IEC TR 61850-90-1 | 51 |
| Table 3 – Latency classes for WANs | 52 |
| Table 4 – Jitter classes in IEC TR 61850-90-1 | 53 |
| Table 5 – Jitter classes for WAN | 53 |
| Table 6 – Recovery delay classes for WAN | 54 |
| Table 7 – IEC TR 61850-90-1 time accuracy classes | 55 |
| Table 8 – IEC 61850-5 time accuracy classes for IED synchronization | 56 |
| Table 9 – WAN time synchronization classes | 56 |
| Table 10 – Latency for line protection | 68 |
| Table 11 – Summary of operational requirements of line protection | 68 |
| Table 12 – Summary of communication requirements for teleprotection | 69 |
| Table 13 – Summary of synchrophasor requirements | 73 |
| Table 14 – Summary of communication requirements for wide area monitoring | 74 |
| Table 15 – Typical communication requirements for WAMPAC | 76 |
| Table 16 – Requirements for fault location | 78 |
| Table 17 – Requirements for distribution automation communication | 79 |
| Table 18 – Communication requirements for CMD | 80 |
| Table 19 – Communication requirements for CC to SS/PS | 82 |
| Table 20 – Latency and timing requirements from IEC TR 61850-90-2 | 82 |
| Table 21 – Communication requirements for inter-control centre communications | 83 |
| Table 22 – Requirements for smart metering communication | 84 |
| Table 23 – Classification of communication requirements | 85 |
| Table 24 – Communication requirements of wide-area applications | 86 |
| Table 25 – Communication technologies | 88 |
| Table 26 – Physical communication media | 89 |
| Table 27 – DSL communication over twisted pairs | 90 |
| Table 28 – Trade-offs in copper cable communication | 90 |
| Table 29 – Power Line Telecommunication advantages and disadvantages | 91 |
| Table 30 – HF spectrum allocated for HV/MV PLC systems | 92 |
| Table 31 – HF spectrum used for narrowband LV PLC and associated standards | 92 |
| Table 32 – Characteristics of common NB-PLC standards | 95 |
| Table 33 – HV/MV APLC/DPLC/BPL technology performance | 101 |
| Table 34 – Microwave link performance | 103 |
| Table 35 – Terrestrial microwave advantages and disadvantages | 104 |
| Table 36 – Terrestrial mobile radio technologies | 104 |
| Table 37 – Terrestrial radio advantages and disadvantages | 105 |

| | |
|---|-----|
| Table 38 – DMR advantages and disadvantages | 106 |
| Table 39 – Satellite radio advantages and disadvantages | 107 |
| Table 40 – LPWAN technology capabilities | 110 |
| Table 41 – Wireless technologies used for customer-side communications in Japan | 111 |
| Table 42 – Optical fibres: advantages and disadvantages | 118 |
| Table 43 – SONET and SDH hierarchies | 126 |
| Table 44 – Summary of SDH/SONET | 133 |
| Table 45 – Ethernet physical layers | 135 |
| Table 46 – Payload mapping using SDH/SONET and Next Generation SDH/SONET | 145 |
| Table 47 – Carrier Ethernet summary | 147 |
| Table 48 – IP/MPLS characteristics | 154 |
| Table 49 – MPLS-TP characteristics | 155 |
| Table 50 – MPLS summary | 156 |
| Table 51 – Differences between IPv4 and IPv6 | 164 |
| Table 52 – IPv6 vs IPv4 addresses (RFC 4291) | 165 |
| Table 53 – List of DiffServ codepoint field values | 169 |
| Table 54 – IP Summary | 175 |
| Table 55 – VPN services | 189 |
| Table 56 – IEC 62351 series | 201 |
| Table 57 – Example of simple application priority assignment | 203 |
| Table 58 – Typical oscillator stability | 208 |
| Table 59 – IEC 61588 option comparison | 217 |
| Table 60 – Precision time distribution protocols based on IEC 61588 | 219 |
| Table 61 – Main system specifications for wide area stabilizing control system | 229 |
| Table 62 – Main system specifications for PMU-based WAMPAC system | 231 |
| Table 63 – Requirements for the YONDEN IP network | 233 |
| Table 64 – Technologies for the YONDEN IP network | 233 |
| Table 65 – Pseudowire protocols | 250 |
| Table A.1 – 3GPP machine type communications | 255 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS
FOR POWER UTILITY AUTOMATION –****Part 90-12: Wide area network engineering guidelines****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61850-90-12, which is a technical report, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) extension of use case with respect to distribution and customer-side applications;
- b) extensions of wireless access technologies as well as power line communication ones applicable to the above-mentioned use case;

- c) revisions regarding radio communication technology performance;
- d) extension of network migration with respect to packet switched network;
- e) a new mapping of multiprotocol label switching technology to teleprotection.

The text of this technical report is based on the following documents:

| | |
|---------------|------------------|
| Enquiry draft | Report on voting |
| 57/2136/DTR | 57/2203/RVDTR |

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<https://www.webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Utilities use data networks to interconnect equipment between their premises, over distances from under a kilometre to thousands of kilometres, called a "Wide Area Network" or WAN.

WANs encompass communication means of different natures (optical, radio, power line carrier, copper, etc.), with a variety of topologies (rings, trees, meshes, etc.), using different protocols (SDH/SONET, Ethernet, IP, MPLS, etc.), medium sharing (packet switching, time division multiplex, etc.) and for different applications (teleprotection, SCADA, voice, video, etc.).

This contrasts with substation automation networks as described in the LAN Engineering Guidelines (IEC TR 61850-90-4), which are based on one technology (switched Ethernet), make extensive use of Layer 2 multicast (GOOSE, SMV, PTP, etc.) and use Layer 3 communication (MMS, FTP, etc.), typically without routers within the substation.

The IEC 61850 series sets up numerous requirements on the network but does not state how to achieve them:

- IEC 61850-5 specifies the basic requirements for data networks used in Power Utility Automation networks;
- IEC 61850-7 focuses on data modelling, leaving out physical interconnection details;
- IEC 61850-8-1 and IEC 61850-9-2 specify interoperable communication within substations;
- IEC TR 61850-90-1 describes substation-to-substation traffic, specifies the requirements for communication, defines object models for substation-to-substation teleprotection, models the gateway and the tunneller, but leaves the WAN undefined;
- IEC TR 61850-90-2¹ provides substation to control centre network configuration for IEDs, proxies and applications;
- IEC TR 61850-90-5 (synchrophasor transmission) addresses the transport of synchrophasor data between PMUs and control centres and defines a tunnelling protocol as well as a data security method;
- IEC TR 61850-90-4 provides guidelines for network engineering focused on Ethernet-based real-time and highly available networks in substations. Some of these guidelines are applicable to networks outside of the substation;
- IEC 61870-6 (TASE2), IEC 61968 and IEC 61970 (CIM) describe the information interchange at the application layer without specifying the network.

Each of these documents deals separately with application, transport, or network layer mechanism. There exist no comprehensive engineering guides for wide-area and real-time networks for control and protection. The growing success of IEC 61850 calls for guidelines for engineering the WANs.

IEC TR 61850-90-4 provides guidelines for engineering of IEC 61850-based, local-area substation networks. In contrast, this Technical Report proposes guidelines for wide-area and real-time networks for various IEC 61850-based applications including teleprotection, wide area measurement, protection, and control (WAMPAC), power system monitoring (WASA, WAMS), operation SCADA, and condition monitoring and diagnosis (CMD) and non-operational traffic.

This document is based on existing standards for semantics, services, protocols, system configuration language and architecture. It is based on work done by various IEC working groups including:

- Power system IED communication and associated data models;

¹ In preparation. Stage at the time of publication: IEC TR/PWI 61850-90-2:2019.

- Energy management system application program interface;
- Data and communications security;
- Interoperability within TC 57 in the long term;
- Industrial networks;
- Highly Available Automation Networks.

Contributions were included from:

- IEEE 802.1 WG (Higher layer LAN protocols);
- IEEE 1588 WG (Precise Networked Clock Synchronization);
- IEEE Power System Relaying Committee (PSRC);
- UCA International Users Group;
- The North American Synchrophasor Initiative (NASPI);
- CEN/CENELEC/ETSI Smart Grids Coordination Group;
- CIGRE working groups D2.26, D2.28, D2/B5.30, D2.35; and
- Different utilities, providers and research institutes, in particular the Central Research Institute of Electric Power Industry (Japan), Hydro-Quebec [50]² (Canada), Swissgrid (Switzerland) and ENEL (Italy).

² Numbers in square brackets refer to the bibliography.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-12: Wide area network engineering guidelines

1 Scope

This part of IEC 61850, which is a Technical Report, is intended for an audience familiar with electrical power automation based on IEC 61850 and related power system management, and particularly for data network engineers and system integrators. It is intended to help them to understand the technologies, configure a wide area network, define requirements, write specifications, select components, and conduct tests.

This document provides definitions, guidelines, and recommendations for the engineering of WANs, in particular for protection, control and monitoring based on IEC 61850 and related standards.

This document addresses substation-to-substation communication, substation-to-control centre, and control centre-to-control centre communication. In particular, this document addresses the most critical aspects of IEC 61850 such as protection related data transmission via GOOSE and SMVs, and the multicast transfer of large volumes of synchrophasor data.

The document addresses issues such as topology, redundancy, traffic latency and quality of service, traffic management, clock synchronization, security, and maintenance of the network.

This document contains use cases that show how utilities tackle their WAN engineering.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60834-1, *Teleprotection equipment of power systems – Performance and testing – Part 1: Command systems*

IEC 60870-5-104, *Telecontrol equipment and systems – Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles*

IEC 61400-25 (all parts), *Wind energy generation systems – Communications for monitoring and control of wind power plants*

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61588:2009, *Precision clock synchronization protocol for networked measurement and control systems*

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*