

ANSI/IES RP-7-20



**Illuminating**  
ENGINEERING SOCIETY

**RECOMMENDED PRACTICE:**  
**LIGHTING INDUSTRIAL FACILITIES**  
AN AMERICAN NATIONAL STANDARD



[www.ies.org](http://www.ies.org)

**ANSI/IES RP-7-20**

**RECOMMENDED PRACTICE:  
LIGHTING INDUSTRIAL FACILITIES**  
AN AMERICAN NATIONAL STANDARD

Publication of this Recommended Practice  
has been approved by IES.  
Suggestions for revisions  
should be directed to IES.

**Prepared by**  
**The IES Industrial Lighting Committee**



*Copyright 2020 by the Illuminating Engineering Society.*

*Approved by the IES Standards Committee October 11, 2019 as a Transaction of the Illuminating Engineering Society.*

*Approved March 23, 2020 as an American National Standard.*

*All rights reserved.* No part of this publication may be reproduced in any form, in any electronic retrieval system or otherwise, without prior written permission of the IES.

Published by the Illuminating Engineering Society, 120 Wall Street, New York, New York 10005.

IES Standards are developed through committee consensus and produced by the IES Office in New York. Careful attention is given to style and accuracy. If any errors are noted in this document, please forward them to Brian Liebel, IES Director of Standards, at [standards@ies.org](mailto:standards@ies.org) or the above address for verification and correction. The IES welcomes and urges feedback and comments.

Printed in the United States of America.

ISBN# 978-0-87995-064-4

---

## DISCLAIMER

IES publications are developed through the consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on lighting recommendations. While the IES administers the process and establishes policies and procedures to promote fairness in the development of consensus, it makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

The IES disclaims liability for any injury to persons or property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document.

In issuing and making this document available, the IES is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the IES undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The IES has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the IES list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or statement of compliance with the requirements of this document shall not be attributable to the IES and is solely the responsibility of the certifier or maker of the statement.

## AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether that person has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation to any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

**Prepared by the IES Industrial Lighting Committee**

**Graeme G. Lister, *Chair***

**Roger Lane, *Vice Chair***

**William T. Busch, *Secretary***

**Members**

J. D. Green

R. W. Kauffman

G. A. Ortt

D. Paulin

N. Smirnov

R. J. Stillwell

J. F. Wall

**Advisory Members**

F. Agraz

L. Asselin

P. R. Chavdarian

R. Conyers

O. D. Cruz

M. Illangasooriya

P. J. Kravec

R. Larivee

J. Lowe

P. Mikus

T. Salter

A. P. Welch

---

# CONTENTS

|   |           |
|---|-----------|
| <b>Foreword</b> .....   | <b>1</b>  |
| <b>1.0 Introduction and Scope</b> .....                               | <b>1</b>  |
| 1.1 Introduction.....   | 1         |
| 1.2 Purpose and Scope.....  | 2         |
| <b>2.0 Lighting the Industrial Environment</b> .....                  | <b>2</b>  |
| 2.1 General Design Considerations for Lighting Industrial Areas ..... | 2         |
| 2.2 Code Compliance .....   | 3         |
| <b>3.0 Quality of Lighting in Industrial Facilities</b> .....         | <b>3</b>  |
| 3.1 Luminance and Luminance Ratios .....                              | 3         |
| 3.2 Modeling of Objects.....  | 5         |
| 3.3 Glare and Visual Comfort.....                                     | 5         |
| 3.4 Material Characteristics .....                                    | 5         |
| 3.5 Shadows .....   | 6         |
| 3.6 Source/Task/Eye Geometry.....                                     | 7         |
| 3.7 Task Visibility: Flicker and Strobe.....                          | 7         |
| 3.8 Light Source Color.....   | 9         |
| 3.8.1 Color Temperature and Correlated Color Temperature.....         | 9         |
| 3.8.2 Color Rendering .....   | 10        |
| 3.8.3 Safety Colors.....  | 11        |
| <b>4.0 Light Sources</b> .....  | <b>11</b> |
| 4.1 Daylight.....   | 11        |
| 4.2 Electric Light Sources.....                                       | 12        |
| 4.2.1 Light Emitting Diodes (LEDs) .....                              | 12        |
| 4.2.2 Fluorescent Systems .....                                       | 13        |
| 4.2.3 Induction Systems .....   | 14        |
| 4.2.4 High Intensity Discharge (HID) Lighting Systems .....           | 14        |
| 4.2.5 Other Light Sources .....                                       | 15        |

|             |  |           |
|-------------|--|-----------|
| <b>5.0</b>  | <b>Lighting Equipment – Luminaires</b> .....   | <b>16</b> |
| 5.1         | General Luminaire Characteristics and Performance .....  | 16        |
| 5.2         | Operating Considerations .....   | 17        |
| 5.3         | Indoor Industrial Luminaires .....   | 17        |
| 5.3.1       | Classification by Light Distribution.....  | 17        |
| 5.3.2       | Classification by Luminaire Type .....   | 18        |
| 5.4         | Exterior Industrial Luminaires .....   | 20        |
| <br>        |  |           |
| <b>6.0</b>  | <b>Electrical System Considerations</b> .....  | <b>21</b> |
| <br>        |  |           |
| <b>7.0</b>  | <b>Lighting Controls</b> .....   | <b>22</b> |
| <br>        |  |           |
| <b>8.0</b>  | <b>Building Construction Features That Influence Luminaire Selection and Luminaire Placement</b> ..... | <b>22</b> |
| <br>        |  |           |
| <b>9.0</b>  | <b>Lighting System Economic Analysis</b> .....   | <b>24</b> |
| <br>        |  |           |
| <b>10.0</b> | <b>Lighting System Maintenance</b> .....   | <b>24</b> |
| 10.1        | Maintenance in an Industrial Environment .....   | 25        |
| 10.2        | Maintenance Safety .....   | 25        |
| <br>        |  |           |
| <b>11.0</b> | <b>Special Considerations in Industrial Applications</b> .....   | <b>26</b> |
| 11.1        | Lighting and Space Conditioning .....  | 26        |
| 11.2        | Classified Areas .....   | 26        |
| 11.2.1      | Hazardous Location Classes .....   | 27        |
| 11.2.2      | Hazardous Location Conditions.....   | 27        |
| 11.2.3      | The Nature of Hazardous Substances .....   | 27        |
| 11.2.4      | Classified Location Luminaires.....  | 28        |
| 11.3        | High Humidity or Corrosive Atmospheres .....   | 28        |
| 11.4        | High Ambient Temperatures .....  | 28        |
| 11.5        | Low Ambient Temperatures.....  | 29        |
| 11.6        | Clean Rooms .....  | 29        |
| 11.7        | Food and Drug Processing .....   | 29        |
| <br>        |  |           |
| <b>12.0</b> | <b>Lighting Criteria</b> .....   | <b>30</b> |
| 12.1        | Illuminance: Horizontal, Vertical, and Intermediate Planes .....                                       | 31        |
| 12.1.1      | Horizontal Illuminance .....   | 31        |
| 12.1.2      | Vertical Illuminance .....   | 31        |
| 12.2        | Initial and Maintained Illuminance .....   | 32        |
| 12.3        | Visual Age of Occupants.....   | 32        |

|             |  |           |
|-------------|--|-----------|
| <b>12.4</b> | <b>Illuminance Measurements</b> .....                                      | <b>33</b> |
| 12.4.1      | Light Measurement Equipment.....   | 33        |
| 12.4.2      | Measurement Point Grids .....  | 33        |
| <b>13.0</b> | <b>General Lighting</b> .....  | <b>34</b> |
| <b>14.0</b> | <b>Supplementary Task Lighting</b> .....                                   | <b>35</b> |
| 14.1        | Portable Luminaires.....   | 35        |
| <b>15.0</b> | <b>Special Effects and Techniques</b> .....                                | <b>36</b> |
| 15.1        | Classification of Visual Tasks and Lighting Techniques.....                | 36        |
| 15.2        | Color Contrast.....  | 36        |
| 15.3        | Lighting Techniques for Inspection Tasks.....                              | 36        |
| <b>16.0</b> | <b>Emergency, Safety and Security Lighting</b> .....                       | <b>41</b> |
| 16.1        | Emergency Lighting.....  | 41        |
| 16.2        | Safety Lighting.....   | 42        |
| 16.3        | Security Lighting.....   | 42        |
| <b>17.0</b> | <b>Lighting for Specific Tasks</b> .....                                   | <b>43</b> |
| 17.1        | Molding of Metal and Plastic Parts .....                                   | 43        |
| 17.1.1      | Foundry Molding (Sand Casting).....  | 43        |
| 17.1.2      | Molding Parts of Die-Cast Aluminum and Injection Molded Plastic.....       | 44        |
| 17.1.3      | Inspection of Sand Castings .....  | 44        |
| 17.1.4      | Inspection of Die Castings and Opaque Injection Molded Plastic Parts ..... | 44        |
| 17.2        | Parts Manufacturing and Assembly .....                                     | 45        |
| 17.3        | Machining Metal Parts .....  | 46        |
| 17.4        | Lighting and Visibility Issues for Sheet Metal Fabrication.....            | 46        |
| 17.4.1      | Punch Press.....   | 46        |
| 17.4.2      | Shear .....  | 47        |
| 17.5        | Lighting for Large Component Subassembly and Final Assembly.....           | 47        |
| 17.6        | Control Rooms .....  | 48        |
| 17.7        | Manufacturing Electronic Assemblies .....                                  | 48        |
| <b>18.0</b> | <b>Lighting for Specific Visual Tasks</b> .....                            | <b>49</b> |
| 18.1        | Convex Surfaces.....   | 49        |
| 18.2        | Flat Surfaces .....  | 49        |
| 18.3        | Scribed Marks.....   | 49        |
| 18.4        | Center-Punch Marks.....  | 50        |
| 18.5        | Concave Specular Surfaces .....  | 50        |
| 18.6        | Flat Specular Surfaces .....   | 50        |
| 18.7        | Convex Specular Surfaces .....   | 51        |

|             |  |            |
|-------------|--|------------|
| <b>19.0</b> | <b>Warehouse and Storage Area Lighting</b> .....             | <b>51</b>  |
| <b>19.1</b> | <b>Types of Warehouse Area and Storage Systems</b> .....     | <b>51</b>  |
| <b>19.2</b> | <b>Warehouse Illuminance</b> .....                           | <b>52</b>  |
| 19.2.1      | Vertical Illuminance .....                                   | <b>52</b>  |
| 19.2.2      | Horizontal Illuminance .....                                 | <b>53</b>  |
| <b>19.3</b> | <b>Warehouse Lighting Design Considerations</b> .....        | <b>53</b>  |
| 19.3.1      | Intermittent Use .....                                       | <b>53</b>  |
| 19.3.2      | Lighting Design Considerations by Area .....                 | <b>53</b>  |
| 19.3.3      | Other Lighting Design Considerations .....                   | <b>54</b>  |
| <br>        |  |            |
| <b>20.0</b> | <b>Outdoor Area Lighting</b> .....                           | <b>54</b>  |
| <b>20.1</b> | <b>Lighting Zones</b> .....                                  | <b>54</b>  |
| <b>20.2</b> | <b>Projected Lighting System</b> .....                       | <b>55</b>  |
| <b>20.3</b> | <b>Distributed Lighting System</b> .....                     | <b>55</b>  |
| <b>20.4</b> | <b>Outdoor Tower Platforms, Stairways, and Ladders</b> ..... | <b>56</b>  |
| <b>20.5</b> | <b>Special Equipment</b> .....                               | <b>56</b>  |
| <b>20.6</b> | <b>Low Illuminance and Visual Acuity Outdoors</b> .....      | <b>56</b>  |
| <br>        |  |            |
|             | <b>Annex A – Illuminance Recommendations</b> .....           | <b>57</b>  |
|             | <b>Annex B – Ingress Protection (IP) Ratings</b> .....       | <b>99</b>  |
| <br>        |  |            |
|             | <b>References</b> .....                                      | <b>100</b> |

## Foreword

---

This Foreword is not part of ANSI/IES RP-7-20. It is provided for informational purposes only.

This Recommended Practice (RP) does not provide general lighting information that is included in other IES documents. If the reader does not already have this information, it may be obtained as needed from the following IES Standards:

The Lighting Science Series:

- *ANSI/IES LS-1-20, Lighting Science: Nomenclature and Definitions for Illuminating Engineering*
- *ANSI/IES LS-2-20, Lighting Science: Concepts and Language of Lighting*
- *ANSI/IES LS-3-20, Lighting Science: Physics and Optics of Radiant Power*
- *ANSI/IES LS-4-20, Lighting Science: Measurement of Light – The Science of Photometry*
- *ANSI/IES LS-5-20, Lighting Science: Color*
- *ANSI/IES LS-6-20, Lighting Science: Calculation of Light and Its Effects*
- *ANSI/IES LS-7-20, Lighting Science: Vision – Eye and Brain*
- *ANSI/IES LS-8-20: Lighting Science: Vision – Perceptions and Performance*

The Lighting Practice Series:

- *ANSI/IES LP-1-20, Lighting Practice: Designing Quality Lighting for People and Buildings*
- *ANSI/IES LP-2-20, Lighting Practice: Designing Quality Lighting for People in Outdoor Environments*
- *ANSI/IES LP-3-20, Lighting Practice: Designing and Specifying Daylighting for Buildings*
- *ANSI/IES LP-4-20, Lighting Practice: Electric Light Sources – Properties, Selection, and Specification*
- *ANSI/IES LP-6-20, Lighting Practice: Lighting Control Systems – Properties, Selection, and Specification*
- *ANSI/IES LP-7-20, Lighting Practice: The Lighting Design and Construction Process*
- *ANSI/IES LP-8-20, Lighting Practice: The Commissioning Process Applied to Lighting and Control Systems*

- *ANSI/IES LP-9-20, Lighting Practice: Upgrading Lighting Systems in Commercial and Industrial Facilities*
- *ANSI/IES LP-10-20, Lighting Practice: Sustainable Lighting – An Introduction to the Environmental Impacts of Lighting*
- *ANSI/IES LP-11-20, Lighting Practice: Environmental Considerations for Outdoor Lighting*

## 1.0 Introduction and Scope

---

### 1.1 Introduction

A well-designed lighting system can make an important contribution to the success of an industrial facility. The success of the well-lighted industrial environment can affect productivity, employee performance, safety, energy efficiency, health, maintenance costs, and the number of errors and lost-time accidents. Many features of a lighting system other than the quantity of light provided can make a significant contribution to the efficiency and safety of the industrial worker.

In the design of lighting for industrial environments, horizontal illuminance has commonly been the only consideration. However, many industrial tasks take place in planes with various orientations and in areas with overhead obstructions. Placement of the luminaires is critical to providing light of the proper quality, as well as quantity and direction, to allow fast, easy recognition of operations. These operations may be taking place at high speeds in areas of the production machinery or industrial products where ambient light cannot easily penetrate.

Selection of the luminaire and its photometric distribution can be important to rendering the visual task properly when that task is multidimensional rather than flat, and when the task occurs in a plane other than horizontal. The operation of the lighting system should be understood to ensure that the proper light sources are selected. Improper light source choice can result in difficult and potentially dangerous conditions caused by long warm-up periods, shadows, or stroboscopic effects created where rotating parts are involved. The ability of the light to render colors accurately can have an effect

on the recognition of colors, including safety colors, or product components. Many industrial operations take place in hostile environments, and the lighting products and hardware used in these locations should be designed and manufactured to survive in these conditions and be easy to maintain.

For these reasons, and many others, great care is required in order to provide an effective, efficient and readily maintainable lighting system for all industrial spaces, and to help modern industrial workers operate at the peak of their ability in a safe environment.

### 1.2 Purpose and Scope

Industrial facilities can at times be hazardous environments; special-case needs and considerations should be given in general for safety, general lighting, moving components, and supplemental, task, safety and emergency lighting. Emergency egress can at times be very time consuming due to workstation requirements. The primary purpose of this standard is to serve as a guide and educational tool for the design of permanently installed lighting systems for industrial facilities. This Recommended Practice deals entirely with lighting and does not give advice on the construction of a facility. The scope of this practice covers the design of new indoor and outdoor lighting systems for new industrial facilities as well as the redesign of lighting systems in existing industrial facilities. Recommendations are based on quality lighting practices, including: the safe movement of vehicles and people, enhancing the productivity and comfort of employees, conserving energy, and minimizing maintenance. Recommended minimum maintained lighting levels and maximum uniformity ratio guidelines are provided but are subject to variation for special circumstances when based upon sound engineering judgment.

This Practice does not include all information for mixed application areas such as parking lots, offices, outdoor environments, commercial facilities, or daylighting design. For these crossover applications, the associated Recommended Practice documents should be used in conjunction with this Practice to provide the lighting recommendations.

In short, this Recommended Practice will help the reader make intelligent choices to achieve the lighting goals with a minimum of expense of time and capital.

## 2.0 Lighting the Industrial Environment

---

Providing a successful lighting design for a modern industrial facility is a complex task. Much is known about lighting and its positive effects on the wellbeing of people. The goal of providing an efficient, reliable and easily maintainable lighting system, making use of all of the knowledge available to the designer today, is one that requires experience and considerable planning.

Industrial facilities include manufacturing areas, such as fabrication, assembly, sub-assembly, and finishing, as well as quality control, warehousing and logistics. Related areas can also be laboratories, pharmaceutical and/or chemical production facilities (including "clean rooms"), and vehicle maintenance and repair facilities.

### 2.1 General Design Considerations for Lighting Industrial Areas

The designer of an industrial lighting system should carefully consider all of the following design criteria, which could be important in planning a successful industrial lighting installation. (These criteria are not necessarily arranged in order of importance, since priorities will vary for different industries or locations within an industrial complex.)

- Determine the *quality* of illumination for the manufacturing processes involved. (See **Section 3.0 Quality of Lighting in Industrial Facilities.**)
- Determine the *quantity* of illumination for the manufacturing processes involved. (See **Section 12.0 Lighting Criteria** and **Annex A.**)
- Determine the lighting required for *safety*, and ensure that quality, quantity, and safety are properly weighted and addressed in the final design.
- Select listed or approved lighting equipment that will provide the requirements of quality and quantity, including photometric characteristics, as