

ANSI/IES LM-41-20



Illuminating
ENGINEERING SOCIETY

APPROVED METHOD:
PHOTOMETRIC TESTING OF
INDOOR FLUORESCENT LUMINAIRES
AN AMERICAN NATIONAL STANDARD



www.ies.org

ANSI/IES LM-41-20

**APPROVED METHOD:
PHOTOMETRIC TESTING OF
INDOOR FLUORESCENT LUMINAIRES
AN AMERICAN NATIONAL STANDARD**

Publication of this report
has been approved by IES.
Suggestions for revisions
should be directed to IES.

**Prepared by the
IES Testing Procedures Committee**



Copyright 2020 by the Illuminating Engineering Society.

Approved by the IES Standards Committee January 6, 2020 as a Transaction of the Illuminating Engineering Society.

Approved March 19, 2020 as an American National Standard.

All rights reserved. No part of this publication may be reproduced in any form, in any electronic retrieval system or otherwise, without prior written permission of the IES.

Published by the Illuminating Engineering Society, 120 Wall Street, New York, New York 10005.

IES Standards are developed through committee consensus and produced by the IES Office in New York. Careful attention is given to style and accuracy. If any errors are noted in this document, they should be forwarded to Brian Liebel, Director Standards, at standards@ies.org or the above address for verification and correction. The IES welcomes and urges feedback and comments.

Printed in the United States of America.

ISBN# 978-0-87995-207-5

DISCLAIMER

IES publications are developed through the consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on lighting recommendations. While the IES administers the process and establishes policies and procedures to promote fairness in the development of consensus, it makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

The IES disclaims liability for any injury to persons or property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document.

In issuing and making this document available, the IES is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the IES undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The IES has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the IES list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or statement of compliance with the requirements of this document shall not be attributable to the IES and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether that person has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation to any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Prepared by the IES Testing Procedures Committee

Becky Kuebler, *Chair*

Andrew Jackson, *Vice Chair*

David N. Randolph, *Secretary*

Jianzhong Jiao, *Treasurer*

Members

C. K. Andersen

R. P. Bergin

R. S. Bergman

E. Bretschneider

D. J. Ellis

K. C. Fletcher

M. L. Grather

Y. H. Hiebert

J. Hospodarsky

J. N. Hulett

P.-C. Hung

M. Kotrebai

J. E. Leland

K. M. Liepmann

S. Longo

J. P. Marella

P. McCarthy

G. McKee

C. C. Miller

S. Mitsuhashi

Advisory Members

L. M. Ayers

J. Baker

C. A. Bloomfield

B. Boudreaux

P.-T. Chou

P. Cruz

M. Damle

L. Davis

J. J. Demirjian

M. E. Duffy

V. Eberhard

P. Elizondo

A. A. Feldman

J. Frazer

L. J. Hemmi

S. Hua

G. John

J. Juhasz

H. Kashaninejad

T. Kawabata

R. Kelley

J. D. Kramer

K. C. Lerbs

J. Lockner

Y. Ohno

E. Page

D. Park

E. S. Perkins

M. Piscitelli

T. W. Rasinski

M. P. Royer

T. Schneider

A. W. Serres

G. A. Steinberg

L. Swainston

J. S. Swiernik

S.-H. Teoh

A. Thorseth

R. C. Tuttle

J. E. Walker

Y. Zong

CONTENTS

1.0	Introduction and Scope	1
1.1	Introduction	1
1.2	Scope	1
2.0	Normative References	1
2.1	ANSI C78.375A-2014	1
2.2	ANSI C78.81-2016	1
2.3	ANSI C82.3-2016	1
2.4	ANSI/IES LS-1-20	1
2.5	ANSI/IES LM-9-20	1
2.6	ANSI/IES LM-54-20	1
3.0	Definitions	1
4.0	Ambient and Physical Conditions	1
4.1	General	1
4.2	Temperature	2
4.3	Air Movement	2
5.0	Electrical Conditions and Instrumentation	2
5.1	Wave Shape	2
5.2	Voltage Regulation	2
5.3	Power Source Impedance	2
5.4	Instrumentation for Electrical Measurements	2
5.4.1	Uncertainties	2
6.0	Test Requirements	2
6.1	Selection and Preparation of Luminaire	2
6.2	Luminaire Luminance Characteristics	3
6.3	Test Lamps	3
6.3.1	Special Considerations for Luminaires with Compact Fluorescent Lamps (CFLs)	3
6.3.2	Lamp Transfer	3
6.3.3	Lamp Seasoning	4

6.4	Photometric Equipment	4
6.4.1	The Goniophotometry System.....	4
6.4.2	Photometer.....	4
6.4.3	Automated Goniophotometer.....	4
6.4.4	Photometer Head (Photodetector).....	4
6.5	Luminaire Mounting	4
6.6	Lamp Circuit Connections	4
6.7	Stray Light	4
6.8	Luminaire or Lamp – Pre-burning and Stabilization	4
6.8.1	Pre-burning.....	4
6.8.2	Stabilization.....	5
7.0	Photometric Test Procedures	5
7.1	Test Distance	5
7.2	Position Sensitivity	5
7.3	Calibration of Photometer – Relative and Absolute Photometry	6
7.3.1	Relative Photometry – Calibration Factor.....	6
7.3.2	Relative Photometry – The Calibration Process.....	7
7.3.3	Relative Photometry – Special Considerations When Testing Lamps That Produce Maximum Light Output in an Ambient Temperature Other Than 25 °C.....	8
7.3.4	Absolute Photometry.....	8
7.4	Ballast Factor	8
7.4.1	Ballast Factor Defined.....	8
7.4.2	Determination of Ballast Factor.....	9
7.4.3	Effect of Ballast Factors on Photometric Test Results.....	9
7.4.4	Application of Ballast Factors.....	9
7.5	Luminaire Photometry	9
7.5.1	Mounting.....	9
7.5.2	Position of Luminaire during Test.....	10
7.5.3	Angles for Measurement.....	10
7.5.4	Planes for Measurement.....	10
7.5.5	Polarization Measurements.....	10
7.6	Luminance Measurements	10
7.7	Computation of Luminous Intensity Distribution Test Results	10
7.8	Computing Zonal Lumens	11
7.9	Overall Luminaire Efficiency	11
7.10	Coefficients of Utilization	11
8.0	Test Reports	11
9.0	Additional Reading	12

Annex A – Zonal Lumen Constants	13
Annex B – Special Considerations for Compact Fluorescent Lamps (CFLs)	13
Informative References	16

1.0 Introduction and Scope

1.1 Introduction

This guide is intended to provide uniform guidance useful for evaluating the performance of fluorescent luminaires for general lighting. Luminaire characteristics are to be reported in terms of intensity distribution, flux distribution and efficiency. These performance data may be developed into factors and/or tables that allow the predetermination of illuminance and luminance for any conventional plane or boundary surface.

1.2 Scope

This guide provides adequate and uniform methods for determining and reporting the photometric characteristics of indoor fluorescent luminaires. It describes characteristics of luminaires and some components, as well as the requirements for the thermal environment and proper control of the electrical and mechanical systems involved in testing. This document is also concerned with general test conditions and the testing procedure best suited for achieving accurate and consistent photometric results.

2.0 Normative References

2.1 ANSI C78.375A-2014

American National Standards Institute. American National Standard for Electric Lamps – Fluorescent Lamps – Guide for Electrical Measurements. New York: National Electrical Manufacturers Association; 2014.

2.2 ANSI C78.81-2016

American National Standard for Electric Lamps – Double-Capped Fluorescent Lamps – Dimensional and Electrical Characteristics. New York: National Electrical Manufacturers Association; 2016.

2.3 ANSI C82.3-2016

American National Standards Institute. American National Standard Specification for Electric Lamps – Reference Ballasts for Fluorescent Lamps. New York: National Electrical Manufacturers Association; 2016.

2.4 ANSI/IES LS-1-20

Illuminating Engineering Society. Lighting Science: Nomenclature and Definitions for Illuminating Engineering. New York: IES; 2020.

2.5 ANSI/IES LM-9-20

Illuminating Engineering Society. Approved Method: Electrical and Photometric Measurements of Fluorescent Lamps. New York: IES; 2020.

2.6 ANSI/IES LM-54-20

Illuminating Engineering Society. Approved Method: Guide to Lamp Seasoning. New York: IES; 2020.

3.0 Definitions

The units of electrical measurement used in this approved method are the volt, the ampere, and the watt. The units of photometric measurement are the lumen and the candela (see ANSI/IES LS-1-20; see **Section 2**). Color is specified in terms of CIE recommended systems.

The industry-accepted point for making an initial rating of a discharge lamp occurs after the lamp's first 100 hours of operation per ANSI C78.81-2016 (see **Section 2**).

The cold chamber or cold spot is the location inside a fluorescent lamp with the lowest operating temperature. Both the location and temperature of the cold spot are critical for optimizing lamp performance.

4.0 Ambient and Physical Conditions

4.1 General

The photometric values and electrical characteristics of fluorescent lamps and luminaires are sensitive to ambient temperature and air movement.