



BSI Standards Publication

## Technical specification for flame detector system of boiler

---

## National foreword

This Published Document is the UK implementation of IEC PAS 63312:2021.

The UK participation in its preparation was entrusted to Technical Committee GEL/65, Measurement and control.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2021  
Published by BSI Standards Limited 2021

ISBN 978 0 539 16786 3

ICS 27.060

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 January 2021.

### Amendments/corrigenda issued since publication

| Date | Text affected |
|------|---------------|
|------|---------------|

---



# IEC PAS 63312

Edition 1.0 2021-01

# PUBLICLY AVAILABLE SPECIFICATION PRE-STANDARD



---

**Technical specification for flame detector system of boiler**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 27.060

ISBN 978-2-8322-9241-9

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

|                                                                                                                             |    |
|-----------------------------------------------------------------------------------------------------------------------------|----|
| FOREWORD.....                                                                                                               | 5  |
| INTRODUCTION.....                                                                                                           | 7  |
| 1 Scope.....                                                                                                                | 8  |
| 2 Normative references .....                                                                                                | 8  |
| 3 Terms and definitions .....                                                                                               | 9  |
| 4 General .....                                                                                                             | 12 |
| 4.1 General requirements .....                                                                                              | 12 |
| 4.2 Power supply .....                                                                                                      | 12 |
| 4.3 Functions and performance of flame detector.....                                                                        | 12 |
| 4.4 Signal output.....                                                                                                      | 13 |
| 4.5 Interchangeability .....                                                                                                | 13 |
| 4.6 Installation .....                                                                                                      | 13 |
| 4.7 Commissioning .....                                                                                                     | 13 |
| 4.8 Inspection and maintenance .....                                                                                        | 13 |
| 4.9 Tests .....                                                                                                             | 14 |
| 5 Classification and requirements (design) .....                                                                            | 14 |
| 5.1 Classification of flame detectors .....                                                                                 | 14 |
| 5.1.1 Classification principle.....                                                                                         | 14 |
| 5.1.2 Classification according to detection principle.....                                                                  | 14 |
| 5.1.3 Classification according to the structure of flame detector .....                                                     | 15 |
| 5.1.4 Classification according to installation method.....                                                                  | 15 |
| 5.1.5 Classification according to safety level .....                                                                        | 15 |
| 5.2 Technical requirements of flame detectors .....                                                                         | 15 |
| 5.2.1 Basic functional requirements.....                                                                                    | 15 |
| 5.2.2 Basic performance requirements .....                                                                                  | 17 |
| 5.2.3 Reliability requirements .....                                                                                        | 18 |
| 5.3 Technical requirements of cooling system (optional, depending upon the<br>actual requirements of flame detectors) ..... | 20 |
| 5.3.1 Functional requirements of cooling air system .....                                                                   | 20 |
| 5.3.2 Performance requirements of cooling air system.....                                                                   | 21 |
| 6 Installation and commissioning requirements.....                                                                          | 22 |
| 6.1 System installation requirements .....                                                                                  | 22 |
| 6.1.1 Installation preparations .....                                                                                       | 22 |
| 6.1.2 Installation of flame detectors.....                                                                                  | 23 |
| 6.1.3 Acceptance of installation .....                                                                                      | 26 |
| 6.2 Commissioning requirements after installation .....                                                                     | 27 |
| 6.2.1 Static commissioning .....                                                                                            | 27 |
| 6.2.2 Dynamic commissioning .....                                                                                           | 29 |
| 6.2.3 Contents of system dynamic commissioning .....                                                                        | 29 |
| 6.2.4 Acceptance of system commissioning.....                                                                               | 31 |
| 7 Requirements on inspection, operation and maintenance .....                                                               | 32 |
| 7.1 System inspection and maintenance requirements .....                                                                    | 32 |
| 7.1.1 Preparations.....                                                                                                     | 32 |
| 7.1.2 Power supply inspection .....                                                                                         | 33 |
| 7.1.3 Installation inspection of flame detectors .....                                                                      | 33 |
| 7.1.4 Dismantlement and inspection of optical fibers .....                                                                  | 33 |

|                       |                                                                         |    |
|-----------------------|-------------------------------------------------------------------------|----|
| 7.1.5                 | Inspection and maintenance of analysis and processing unit .....        | 34 |
| 7.1.6                 | Inspection and maintenance of cables .....                              | 35 |
| 7.1.7                 | Inspection and maintenance of cooling air system .....                  | 35 |
| 7.2                   | System test requirements .....                                          | 36 |
| 7.2.1                 | Power system test .....                                                 | 36 |
| 7.2.2                 | Inspection on the analysis and processing unit .....                    | 36 |
| 7.2.3                 | Inspection and tests on flame detector probes .....                     | 36 |
| 7.2.4                 | Basic functional tests.....                                             | 37 |
| 7.2.5                 | Parameter adjustment test.....                                          | 37 |
| 7.2.6                 | Check of parameter settings .....                                       | 37 |
| 7.2.7                 | Tests on cooling fans.....                                              | 37 |
| 7.3                   | System operation .....                                                  | 38 |
| 7.3.1                 | Restart .....                                                           | 38 |
| 7.3.2                 | Maintenance during operation.....                                       | 38 |
| 7.3.3                 | Inspections before boiler shutdown.....                                 | 39 |
| 7.4                   | System maintenance requirements .....                                   | 39 |
| 7.4.1                 | Routine maintenance .....                                               | 39 |
| 7.4.2                 | Regular maintenance.....                                                | 39 |
| 7.5                   | Archives.....                                                           | 40 |
| 8                     | Test methods and requirements.....                                      | 41 |
| 8.1                   | Test methods .....                                                      | 41 |
| 8.1.1                 | General .....                                                           | 41 |
| 8.1.2                 | Test reference conditions .....                                         | 41 |
| 8.1.3                 | Test instruments and equipment.....                                     | 41 |
| 8.1.4                 | Test items and methods.....                                             | 42 |
| 8.2                   | Equipment factory acceptance test.....                                  | 44 |
| 8.2.1                 | Test items.....                                                         | 44 |
| 8.2.2                 | Judgment of eligibility .....                                           | 44 |
| 8.3                   | Type test.....                                                          | 44 |
| 8.3.1                 | General .....                                                           | 44 |
| 8.3.2                 | Situations requiring type test .....                                    | 44 |
| 8.3.3                 | Sampling principles .....                                               | 44 |
| 8.3.4                 | Judgment of eligibility in type test.....                               | 45 |
| Annex A (informative) | Composition of flame detector system .....                              | 46 |
| A.1                   | General.....                                                            | 46 |
| A.2                   | Flame detector.....                                                     | 46 |
| A.3                   | Signal transmission components and cables .....                         | 47 |
| A.4                   | Analysis and engineering tools.....                                     | 47 |
| A.5                   | Power system .....                                                      | 47 |
| A.6                   | Cooling air system (optical, depending on design requirements) .....    | 47 |
| Annex B (informative) | Marking, packaging, transportation and storage of flame detectors ..... | 48 |
| B.1                   | Marking.....                                                            | 48 |
| B.2                   | Packaging .....                                                         | 48 |
| B.3                   | Transportation .....                                                    | 48 |
| B.4                   | Storage.....                                                            | 48 |

|                                                                                                                 |    |
|-----------------------------------------------------------------------------------------------------------------|----|
| Figure A.1 – Schematic diagram of a typical light signal-based flame probe.....                                 | 46 |
| Figure A.2 – Schematic diagram of an imaging-based flame detector probe.....                                    | 46 |
| Table 1 – Configuration of monitoring and interlocking instruments of flame detector<br>cooling air system..... | 20 |
| Table 2 – Installation acceptance criteria of flame detector system .....                                       | 26 |
| Table 3 – Commissioning acceptance items of flame detector system.....                                          | 32 |
| Table 4 – Test instruments and equipment.....                                                                   | 41 |
| Table 5 – Requirements on insulation resistance tester .....                                                    | 42 |

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**TECHNICAL SPECIFICATION FOR FLAME DETECTOR SYSTEM OF BOILER****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

A PAS is an intermediate specification made available to the public and needing a lower level of consensus than an International Standard to be approved by vote (simple majority).

IEC PAS 63312 has been processed by subcommittee 65B: Measurement and control devices, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this PAS is based on the following document:

This PAS was approved for publication by the P-members of the committee concerned as indicated in the following document

| <b>Draft PAS</b> | <b>Report on voting</b> |
|------------------|-------------------------|
| 65B/1175/DPAS    | 65B/1180/RVDPAS         |

Following publication of this PAS, which is a pre-standard publication, the technical committee or subcommittee concerned may transform it into an International Standard.

This PAS shall remain valid for an initial maximum period of 2 years starting from the publication date. The validity may be extended for a single period up to a maximum of 2 years, at the end of which it shall be published as another type of normative document, or shall be withdrawn.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

The flame detector is the key testing equipment for the boiler furnace safety protection and burner interlock control. In the whole combustion process of the boiler (especially in the variable operating condition), it detects the change of the combustion condition, and the corresponding control measures are taken through the connected terminal devices; so its reliability is related to the safety of the combustion system and the quality of the terminal products. Due to the difference in combustion conditions in the furnace, the reliability of the flame detector itself and the quality of the installation and maintenance, many problems are exposed during the operation, such as peeping of fire detection signals, missed detection, instability, false alarm information, fiber overheating loss, etc. All of these will bring safety hazards to the industrial production.

The purpose of this PAS is to develop comprehensive technical specifications for the functions and performance of industrial boiler flame detectors, as well as the technical requirements related to design, manufacture, installation, testing, operation, maintenance, etc., so as to provide the technical basis for flame detector system users.

# TECHNICAL SPECIFICATION FOR FLAME DETECTOR SYSTEM OF BOILER

## 1 Scope

This PAS deals with the general requirements, classification and technical requirements, installation and commissioning requirements, inspection and maintenance requirements, test methods and requirements of radiant energy sensing flame detectors (including IR, UV, visible light, and imaging-based flame detectors).

This PAS is applicable to the type selection, design, installation, commissioning, inspection, maintenance and acceptance of the radiant energy sensing flame detectors, which monitor the flame status of burners.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-30-1, *Rotating electrical machines – Part 30-1: Efficiency classes of line operated AC motors (IE code)*

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61010-1, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61326-1, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61326-2-5, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-5: Particular requirements – Test configurations, operational conditions and performance criteria for field devices with field bus interfaces according to IEC 61784-1*

NFPA 85, *Boiler and Combustion Systems Hazards Code*