



BSI Standards Publication

Mechanical structures for electrical and electronic equipment — Aisle containment for it cabinets

Part 3: Aspects of operational and personal safety

National foreword

This Published Document is the UK implementation of IEC TS 62966-3:2021.

The UK participation in its preparation was entrusted to Technical Committee EPL/48, Electromechanical components and mechanical structures for electronic equipment.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 04932 9

ICS 31.240

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 28 February 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



TECHNICAL SPECIFICATION



**Mechanical structures for electrical and electronic equipment – Aisle
containment for it cabinets –
Part 3: Aspects of operational and personal safety**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 31.240

ISBN 978-2-8322-9318-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD..... 3

INTRODUCTION..... 5

1 Scope..... 6

2 Normative references 7

3 Terms and definitions 7

4 Safety requirements of an aisle containment..... 8

 4.1 General safety requirements 8

 4.2 Escape routes, emergency exits, escape doors, escape and evacuation plan 8

 4.2.1 Recommended dimensions of escape routes and escape doors/emergency exits..... 8

 4.2.2 Functional aspects of escape doors 11

 4.2.3 Lighting and signposting of escape routes 11

 4.2.4 Escape and evacuation plan 12

 4.3 General – Fire protection in an aisle containment 12

 4.3.1 Overview 12

 4.3.2 Fire prevention 13

 4.3.3 Fire and smoke detection..... 13

 4.3.4 Fire fighting device 16

 4.3.5 Arrangement of extinguishing nozzles..... 17

 4.4 Lighting conditions 19

Bibliography..... 20

Figure 1 – Minimum width of escape routes in an aisle containment..... 10

Figure 2 – Minimum height of escape routes in an aisle containment 10

Figure 3 – Typical arrangement of an aisle containment representing a walk-in-equipment solution..... 13

Figure 4 – Cold and hot aisle containment (showing air flow and temperature areas)..... 14

Figure 5 – Arrangement of aspirating smoke detectors (ASDs) in a cold aisle containment with or without raised floor 15

Figure 6 – Arrangement of aspirating smoke detectors (ASDs) in a hot aisle containment..... 16

Figure 7 – Arrangement of extinguishing nozzles in a cold aisle containment with or without raised floor (showing flow-direction of extinguishing gas)..... 18

Table 1 – Minimum width of escape routes and maximum reduction of clearance..... 9

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MECHANICAL STRUCTURES FOR ELECTRICAL
AND ELECTRONIC EQUIPMENT –
AISLE CONTAINMENT FOR IT CABINETS –****Part 3: Aspects of operational and personal safety**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62966-3, which is a Technical Specification, has been prepared by subcommittee 48D: Mechanical structures for electrical and electronic equipment, of IEC technical committee 48: Electrical connectors and mechanical structures for electrical and electronic equipment.

The text of this Technical Specification is based on the following documents:

DTS	Report on voting
48D/725/DTS	48D/731/RVDTS

Full information on the voting for the approval of this Technical Specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62966 series, published under the general title *Mechanical structures for electrical and electronic equipment – Aisle containment for IT cabinets*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This Part 3 of IEC 62966 serves as a guide for a consideration from a safety viewpoint of the dimensional and air conditioning aspects of cold and hot aisle containments in data centres described in IEC 62966-1 and IEC 62966-2.

Where aspects of this Technical specification conflict with national regulations and laws of the member states concerned, the provisions of these national regulations shall apply.

Consideration is given to safety-related aspects, such as:

- a) escape and evacuation plans;
- b) escape routes;
- c) emergency exits;
- d) functional aspects of escape doors;
- e) lighting conditions;
- f) lighting and signposting of escape routes;
- g) fire protection;

taking into account the existing stringent requirements placed on the protection of IT equipment and the availability of the data the equipment contains.

MECHANICAL STRUCTURES FOR ELECTRICAL AND ELECTRONIC EQUIPMENT – AISLE CONTAINMENT FOR IT CABINETS –

Part 3: Aspects of operational and personal safety

1 Scope

This part of IEC 62966 defines the requirements for operational and personal safety of aisle containments for IT cabinets.

The aim is to provide physical security for the IT equipment installed in the containment using the criteria “availability” and “safety”.

The requirements apply to all operational, working and maintenance procedures.

This document does not apply to ordinary persons, when using installations and equipment.

The requirements described herein are also intended to ensure that it is possible for authorized personnel to enter and remain in the containment (as accessible equipment) and to maintain or upgrade the systems installed in the containment without risk. It should also be possible to evacuate the containment quickly and safely at any time, especially in the event of a fire or any other hazardous situation, whilst reducing the health risk to personnel to a minimum.

Aspects relating to computing, data processing, data storage, building protection or the data centre itself do not fall within the scope of this document. Only those additional aspects arising from the integration of an aisle containment are considered.

The design and positioning of an aisle containment, which is integrated in the data centre, has influence on the following different aspects of operational safety:

- a) escape and evacuation plans;
- b) escape routes;
- c) emergency exits;
- d) functional aspects of escape doors;
- e) lighting conditions
- f) lighting and signposting of escape routes;
- g) fire protection.

In this document, these operational safety requirements and recommendations are considered.

To achieve the highest effectiveness, all these requirements are considered as much as possible during the design of an aisle containment.

This document applies to normal operations, not to the initial installation of the containment.