



BSI Standards Publication

Fixed firefighting systems — Automatic sprinkler systems — Guidance for earthquake bracing

National foreword

This Published Document is the UK implementation of CEN/TS 17551:2021.

The UK participation in its preparation was entrusted to Technical Committee FSH/18/2, Sprinkler Systems.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 05425 5

ICS 13.220.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 March 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CEN/TS 17551

March 2021

ICS 13.220.20

English Version

**Fixed firefighting systems - Automatic sprinkler systems -
Guidance for earthquake bracing**

Installations fixes de lutte contre l'incendie - Systèmes
d'extinction automatiques du type sprinkleur -
Recommandation pour le contreventement sismique

Ortsfeste Brandbekämpfungsanlage - Automatische
Sprinkleranlagen - Leitfaden für Erdbebensicherungen

This Technical Specification (CEN/TS) was approved by CEN on 4 January 2021 for provisional application.

The period of validity of this CEN/TS is limited initially to three years. After two years the members of CEN will be requested to submit their comments, particularly on the question whether the CEN/TS can be converted into a European Standard.

CEN members are required to announce the existence of this CEN/TS in the same way as for an EN and to make the CEN/TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the CEN/TS) until the final decision about the possible conversion of the CEN/TS into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents		Page
European foreword		3
Introduction		4
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Design principles	5
5	Sway bracing and sprinkler pipe support	6
5.1	General	6
5.2	Sway brace design	7
5.3	Anchorage for in rack sprinklers	23
5.4	Type, attachment and locations of hangers	24
6	Flexibility	25
6.1	General	25
6.2	Flexible Couplings	26
6.3	Seismic separation assemblies	27
7	Clearance	29
7.1	Clearance around piping through walls or floors	29
7.2	Clearance at sprinklers	29
8	Other provisions	29
8.1	Suspended ceilings	29
8.2	Water supply	29

European foreword

This document (CEN/TS 17551:2021) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to announce this Technical Specification: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This document specifies requirements for earthquake protection of automatic sprinkler systems in accordance with EN 12845 and fire hose piping systems. Requirements made herein are intended to greatly improve the likelihood that the fire protection systems will remain in working condition during earthquake and minimize or prevent any potential water damage from fixed firefighting systems leakage due to an earthquake.

1 Scope

This document specifies requirements for earthquake protection of automatic sprinkler systems in accordance with EN 12845. This document applies only to locations in earthquake zones in accordance to EN 1998-1:2004, 3.2.1¹ and for area subject to peak ground acceleration above 9 % of g.

This document does not cover all legislative requirements. In certain countries specific national regulations apply and take precedence over this document. Users of this document are advised to inform themselves of the applicability or non-applicability for this document by their national responsible authorities.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1998-1:2004, *Eurocode 8: Design of structures for earthquake resistance - Part 1: General rules, seismic actions and rules for buildings*¹

EN 12845, *Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1998-1:2004¹ and EN 12845 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

4 Design principles

Requirements given in this document fall into the following seven principles:

- brace sprinkler piping and equipment to minimize uncontrolled differential movement between these installations and the attached structure; and
- provide flexibility on piping systems and on equipment where differential movement between portions of those piping systems or equipment is expected; and
- provide clearance between sprinkler piping and structural members, walls, floors or other objects so that potential damage from impact is minimized; and
- provide anchorage or restraint to minimize potential sliding and/or overturning of equipment such as the booster pump, jockey pump, tanks, controller, battery package and diesel tank; and
- use types of pipe hangers and sway bracing in accordance to EN 12845 to minimize the potential for pull-out, properly locate them and attach them to structural members only; and

¹ As impacted by EN 1998-1:2004/AC:2009 and EN 1998-1:2004/A1:2013.