



BSI Standards Publication

Lightning Protection System Components (LPSC)

Part 1: Testing requirements for metal sheets' joints used in LPS

National foreword

This Published Document is the UK implementation of CLC/TS 50703-1:2021. It supersedes PD CLC/TS 50703-1:2019, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/81, Protection against lightning.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 15749 9

ICS 91.120.40

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 June 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Lightning Protection System Components (LPSC) - Part 1: Testing requirements for metal sheets' joints used in LPS

Blitzschutzsystembauteile (LPSC) – Teil 1:
Prüfanforderungen für in Blitzschutzsystemen

(LPS) verwendete Verbindungsstellen
zwischen Metallblechen

This Technical Specification was approved by CENELEC on 11 May 2021.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	iii
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Classification	7
5 Requirements	7
5.1 General	7
5.2 Installation instructions	7
5.3 Marking	7
5.4 Lightning current carrying capability	8
6 Tests	8
6.1 General condition on tests	8
6.2 Installation instructions	8
6.2.1 General conditions for tests	8
6.2.2 Acceptance criteria	9
6.3 Marking test	9
6.3.1 General conditions for tests	9
6.3.2 Acceptance criteria for marking completeness	9
6.3.3 Acceptance criteria for marking durability and legibility	9
6.4 Test preparation	9
6.4.1 Arrangement of specimen	9
6.4.2 Conditioning / ageing	10
6.4.3 Lightning current test	10
6.4.4 Acceptance criteria according to the ability to pass the lightning current tests H or N with respect to perforation NP or P	11
7 Structure and content of the test report	11
7.1 General	11
7.2 Report identification	11
7.3 Specimen description	12
7.4 Material	12
7.5 Standards and references	12
7.6 Test procedure	12
7.7 Testing equipment description	12
7.8 Measuring instruments description	13
7.9 Requirements for an approved measuring system	13
7.10 Results and parameters recorded	13
7.11 Statement of pass / fail	13
Annex A (informative) Examples of form-locked electrical non-durable joints of metal sheets used in LPS	14
Annex B (informative) Summary of the requirements and corresponding tests	16
Annex C (normative) Conditioning / ageing for form-locked and non-locked electrical non-durable joints of metal sheets	17
Annex D (normative) Flow Chart of tests for form-locked electrical non-durable joints of metal sheets	18
Bibliography	19

European foreword

This document (CLC/TS 50703-1:2021) has been prepared by CLC/TC 81X “Lightning protection”.

This document supersedes CLC/TS 50703-1:2019.

The document includes the following significant changes with respect to the previous edition:

- a) precise terms / definitions are given for the reader to understand and distinguish the under discussion types of the joints of metal sheets;
- b) conditioning tests have been added which contribute significant on the lightning current capability;
- c) two new classifications have been added as per the ability of the joints of metal sheets to withstand the lightning current with or without perforation;
- d) [Table 1](#) – Clarifications that are more precise are given for parameters of the test current;
- e) requirements for approved measuring system have been added under [clause 7.9](#).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

1 Scope

This document defines the requirements and testing for joints of metal sheets, with or without insulating coatings, used as natural components in roofs, facades or walls of buildings, suitable to conduct lightning current in LPS where the interconnection of these metal sheets does not ensure durable electrical connection.

NOTE This document does not deal with the lightning interception capabilities of these components. The connection clamps for connecting the metallic sheet with the down conductor to the earth termination system are LPSC, tested according to EN 62561-1.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60068-2-52:1996, *Environmental testing - Part 2: Tests - Test Kb: Salt mist, cyclic (sodium chloride solution)* (IEC 60068-2-52:1996)

EN 62305-3:2011, *Protection against lightning - Part 3: Physical damage to structures and life hazard* (IEC 62305-3:2010)

EN 62561-1:2017, *Lightning Protection System Components (LPSC) - Part 1: Requirements for connection components* (IEC 62561-1:2017)

ISO 22479:2019, *Corrosion of metals and alloys - Sulfur dioxide test in a humid atmosphere (fixed gas method)*

ISO 6957:1988, *Copper alloys - Ammonia test for stress corrosion resistance*

3 Terms and definitions

For the purpose of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1 joint of metal sheets

electrical and mechanical connection between metal sheets with or without insulating coating

Note 1 to entry: Typical joints are shown in [Figures A.1](#) and [A.2](#) in [Annex A](#).

Note 2 to entry: A thin coating of protective paint or about 1 mm asphalt or 0,5 mm PVC is not regarded as an insulator.

3.2 durability

ability to perform as required, under given conditions of use and maintenance, until the end of useful life

3.3 material connected metal sheets

connection between two metal sheets (e.g. by means of welding, brazing or soldering), which allows no relative movement of metal sheets due to thermal expansion and to environmental load, e.g. snow, ice, wind where the interconnection of these metal sheets does assure durable electrical connection