



PROCESS  
INDUSTRY  
PRACTICES

TECHNICAL REVISION  
*August 2021*

***Process Control***

**PIP PCCCV001  
Control Valves Selection Criteria**

---

## PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/ purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

### **PUBLISHING HISTORY**

*October 1995*

*Issued*

*December 2009*

*Complete Revision*

*August 2021*

*Technical Revision*

*March 2003*

*Complete Revision*

*March 2016*

*Complete Revision*

Not printed with State funds



## PIP PCCCV001 Control Valves Selection Criteria

---

### Table of Contents

<b>1. Scope .....</b>	<b>2</b>	4.6 Bonnet .....	13
<b>2. References .....</b>	<b>2</b>	4.7 Valve Sizing.....	15
2.1 Process Industry Practices.....	2	4.8 Noise .....	17
2.2 Industry Codes and Standards.....	2	4.9 Actuators .....	19
2.3 Government Regulations.....	3	4.10 Positioner/Electro-Pneumatic Positioners.....	22
<b>3. Definitions .....</b>	<b>4</b>	4.11 Accessories .....	23
<b>4. Requirements .....</b>	<b>5</b>	4.12 Marking, Identification, and Nameplate .....	26
4.1 General.....	5	4.13 Valve Testing .....	27
4.2 Valve Body .....	5	4.14 Cleaning, Packaging, and Shipping..	27
4.3 Globe Valves .....	8	4.15 Valve Receipt, Job Site Inspection, and Storage.....	27
4.4 Rotary Valves .....	10	4.16 Installation .....	28
4.5 Trim.....	11		

## 1. Scope

---

This Practice describes requirements for selection and sizing of pneumatically actuated control valves, including requirements for body, bonnet, trim, actuator, accessories, and noise considerations.

This Practice does not cover requirements for motor-operated valves, on-off valves, on-off valves intended for emergency isolation, or valves with hydraulic actuators. For these types of on-off valve applications see *PIP PCECV003, Guidelines for Application of Remotely Actuated On-Off Valves*.

## 2. References

---

Applicable parts of the following Practices, industry codes and standards, and government regulations shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

### 2.1 Process Industry Practices (PIP)

- PIP PCECV001 - *Guidelines for Application of Control Valves*
- PIP PCSCV001 - *Purchasing Requirements for Control Valves (includes Data Sheets)*
- PIP PCSIP001 - *Instrument Tubing Material Specification*

### 2.2 Industry Codes and Standards

- American Society for Mechanical Engineers (ASME)
  - *Boiler and Pressure Vessel Code, Section VIII, Division 1*
  - *ASME B16.5 - Pipe Flanges and Flanged Fittings*
  - *ASME B31.3 - Process Piping*
- American Society for Testing and Materials (ASTM)
  - *A193 - Standard Specification for Alloy-Steel and Stainless Steel Bolting for High Temperature or High Pressure Service and Other Special Purpose Applications*
  - *A269 - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service*
- Fluid Controls Institute Inc. (FCI)
  - *FCI 70-2 - Control Valve Seat Leakage*
- The International Society of Automation (ISA)
  - *ISA 20 - Specification Forms for Process Measurement and Control Instruments, Primary Elements and Control Valves*
  - *ANSI/ISA 75.01.01 - Flow Equations for Sizing Control Valves*
  - *ANSI/ISA 75.05.01- Control Valve Terminology*
  - *ANSI/ISA 75.08.01 - Face-to-Face Dimensions for Integral Flanged Globe-Style Control Valve Bodies (Classes 125, 150, 250, 300, and 600)*
  - *ANSI/ISA 75.08.02 - Face-to-Face Dimensions for Flanged and Flangeless Rotary Control Valves (Classes 150, 300, and 600 and PN 10, PN 16, PN 25, PN 40, PN 63 and PN 100)*