



CGA P-9—2022
**THE INERT GASES: ARGON,
NITROGEN, AND HELIUM**
SIXTH EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 21-015
Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined.

SIXTH EDITION: 2022
FIFTH EDITION: 2015
FOURTH EDITION: 2008
THIRD EDITION: 2001
SECOND EDITION: 1992

© 2022 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	1
4 Argon.....	1
4.1 Properties	1
4.2 Production	2
4.3 Commercial uses.....	2
5 Nitrogen.....	3
5.1 Properties	3
5.2 Production	4
5.3 Commercial uses.....	4
6 Helium	4
6.1 Properties	4
6.2 Production	4
6.3 Commercial uses.....	5
7 Oxygen-deficient atmospheres.....	5
8 Inert gas containers.....	6
8.1 Regulations.....	6
8.2 Cylinders.....	7
8.3 Tank cars.....	8
8.4 Highway vehicles.....	9
9 High pressure inert gas cylinders	9
9.1 Storage and handling	9
9.2 Use	10
9.3 Disposition of empty cylinders.....	11
10 Estimating container contents	11
10.1 Gas cylinders.....	11
10.2 Liquid cylinders.....	11
11 Liquefied inert gases	12
11.1 Storage and handling	12
11.2 Handling liquefied inert gases in transfer systems or in open containers.....	13
12 Storing, handling, and using liquefied inert gas cylinders	13
12.1 General rules.....	13
12.2 Filling.....	14
12.3 Moving cylinders.....	14
12.4 Storage and use of cylinders.....	14
12.5 Disposition of empty cylinders.....	15
13 Inert gas piping and manifold systems	15
14 Bulk inert gas systems	16
15 References	16
16 Additional references.....	17
 Tables	
Table 1—Physical constants of argon.....	2
Table 2—Physical constants of nitrogen.....	3
Table 3—Physical constants of helium	5

1 Introduction

This publication is one of a series compiled by the Compressed Gas Association (CGA) to provide information on the transportation, handling, and storage of compressed gases, cryogenic liquids, and related products.

2 Scope

The purpose of this publication is to present information regarding the characteristics and handling of the three major inert gases—argon, nitrogen, and helium. Requests for specialized technical information should be directed to any one of the manufacturers of these gases.

This publication is intended primarily for users of the inert gases. Some of the requirements do not apply to the manufacturers or distributors of these gases.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

4 Argon

4.1 Properties

Argon is a colorless, odorless, and tasteless, monatomic gas that comprises approximately 1% of the atmosphere (0.934% by volume).

Argon is nontoxic, chemically inert, and only slightly soluble in water. It is nonflammable and inhibits combustion. It can act as an asphyxiant by displacing the amount of oxygen necessary to support life.

Argon gas is approximately 38% more dense than air. It can be liquefied to a colorless liquid that boils at $-302.6\text{ }^{\circ}\text{F}$ ($-185.9\text{ }^{\circ}\text{C}$) at atmospheric pressure. Liquid argon at its normal boiling point is 39% heavier than water. Above its critical temperature of $-188.1\text{ }^{\circ}\text{F}$ ($-122.3\text{ }^{\circ}\text{C}$), argon can exist only as a gas regardless of pressure.

Argon is classed according to type and grade (quality verification level [QVL]). Gaseous argon is denoted as Type I and liquefied argon as Type II. The grade (QVL) indicates the maximum amount of impurities that can be present. For more details, see CGA G-11.1, *Commodity Specification for Argon* [1].¹

Some of the physical constants of argon are listed in Table 1.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.