



**CGA P-91—2021**  
**PLANT INTEGRITY**  
**MANAGEMENT**

**FIRST EDITION**

## PREFACE

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-91, *Plant Integrity Management*, jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 190, *Plant Integrity Management*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

### PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 17-120  
Atmospheric Gases and Equipment Committee

NOTE—Appendices A and B (Informative) are for information only.

FIRST EDITION: 2021

© 2021 – Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

<b>Contents</b>	<b>Page</b>
1 Introduction.....	1
2 Scope and purpose .....	1
2.1 Scope .....	1
2.2 Purpose .....	2
3 Definitions.....	2
4 Plant integrity management programme .....	2
4.1 General.....	2
4.2 Organisational arrangements for integrity management .....	4
4.3 Technical arrangements for integrity management .....	5
5 Data gathering.....	5
6 Risk assessment .....	6
6.1 Operational excursions and fitness for service assessment.....	6
6.2 Modifications.....	6
7 Inspection plan .....	7
7.1 Selection of inspection types .....	7
7.2 Strategies for determining testing or inspection interval.....	8
8 Inspection .....	8
8.1 Individuals involved .....	9
8.2 Inspections during plant shutdowns .....	9
8.3 Management of findings during inspection .....	9
9 Post assessment .....	10
9.1 Assessment of deterioration.....	10
9.2 Changes to subsequent inspections .....	10
9.3 Assessment record.....	10
9.4 Repair, rerate, or retire .....	11
9.5 Incomplete or postponement of inspections .....	11
10 Inspection, testing, and preventive maintenance reporting .....	11
11 Record keeping .....	12
12 Integrity management of electrical, control, and instrumentation and safety systems .....	13
12.1 Degradation mechanism of electrical, control, and instrumentation systems and equipment.....	13
12.2 Integrity management.....	14
13 Degradation mechanism .....	14
13.1 General or local corrosion .....	15
13.2 Atmospheric corrosion.....	15
13.3 Galvanic corrosion.....	15
13.4 Erosion corrosion.....	15
13.5 Stress corrosion cracking .....	15
13.6 Pitting (crevice) corrosion .....	16
13.7 Fatigue cracking .....	16
13.8 Corrosion fatigue .....	16
13.9 Erosion .....	16
13.10 Cavitation corrosion.....	16
13.11 Carbon dioxide (sweet) corrosion.....	16
13.12 Hydrogen sulfide (sour) corrosion .....	17
13.13 Microbiological corrosion .....	17
13.14 Metal dusting .....	17
13.15 Creep.....	17
13.16 Concrete degradation .....	17
13.17 High temperature hydrogen attack .....	17
13.18 Aluminum sensitisation.....	18

14 Detection and sizing of defects and damages.....18  
    14.1 Inspection procedures .....18  
    14.2 Inspection methods .....18

15 References .....19

16 Additional references.....21

**Figure**  
Figure 1—Integrity management work process .....5

**Appendices**  
Appendix A—Cryogenic coldbox located pressure equipment (Informative) .....22  
Appendix B—Cryogenic bulk storage tanks at production sites (Informative) .....23

## 1 Introduction

This publication has been prepared by industrial gas companies to establish a common position and give guidance on plant integrity management. This topic is also referred to as plant ageing and is increasingly included in authority inspections of plants subject to regulations such as *Directive 2012/18/EU on the control of major-accident hazards involving dangerous substances* (Seveso III Directive) and Occupational Safety and Health Administration (OSHA) Process Safety Management (PSM) in Title 29 of the U.S. *Code of Federal Regulations*, etc. [1, 2].<sup>1</sup>

Ageing is not about the age of the equipment. It is about its condition and how that changes over time. Ageing is the effect whereby equipment suffers some form of material deterioration and damage (usually, but not necessarily, associated with time in service) with an increasing likelihood of failure over the lifetime. For more information, see HSE RR823, *Plant Ageing Study – Phase 1 Report* and HSE RR823 Summary Report, *Managing Ageing Plant—A Summary Guide* [3, 4].

The integrity of equipment can be ensured by:

- operation of the equipment within design conditions;
- documented programme of procedures, training, inspections, tests; and
- preventive/predictive maintenance including inspection based upon good engineering practice, applicable codes, standards, specifications, and manufacturers' recommendations.

It is important to recognise that equipment can be subject to ageing, can contribute to the health, safety, and environmental performance of a plant, and/or can compromise the performance if they fail or collapse. Therefore, a broad view is required when assessing the potential impact of ageing at a given installation.

## 2 Scope and purpose

### 2.1 Scope

This publication gives general guidance on integrity management of process plants including, but not limited to, air separation plants, HYCO plants, cylinder filling plants, and carbon dioxide, acetylene, and nitrous oxide plants. The goal is to keep hazardous fluids and energy contained in order to maintain safe working conditions for personnel and prevent unacceptable environmental releases. The information contained in this publication applies to both new and existing equipment. Integrity management starts when the equipment is first put into service and continues throughout its lifecycle.

This includes:

- piping;
- static and rotating equipment;
- equipment civil structures and foundations;
- electrical, control, and instrumentation equipment;
- pressure vessels; and
- combinations thereof.

The user is cautioned that this publication is not a design handbook and does not exclude the need for competent engineering judgement and interpretation. To the extent that they exist, national laws may supersede the information included in this publication.

---

<sup>1</sup> References are shown by bracketed numbers and are listed in order of appearance in the reference section