



BSI Standards Publication

**State of the art on the use of flammable
refrigerant alternatives, in particular from
class A3, in refrigeration, air conditioning
and heat pump equipment**

National foreword

This Published Document is the UK implementation of CEN/TR 17608:2022.

The UK participation in its preparation was entrusted to Technical Committee RHE/18, Refrigeration safety.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2022
Published by BSI Standards Limited 2022

ISBN 978 0 539 19821 8

ICS 71.100.45

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 June 2022.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

TECHNICAL REPORT

CEN/TR 17608

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

April 2022

ICS 71.100.45

English Version

**State of the art on the use of flammable refrigerant
alternatives, in particular from class A3, in refrigeration,
air conditioning and heat pump equipment**

État de l'art sur l'utilisation de fluides frigorigènes
inflammables de substitution, en particulier de la
classe A3, dans les équipements de réfrigération, de
climatisation et de pompes à chaleur

Stand der Technik über die Verwendung von
brennbaren Kältemitteln, insbesondere der Klasse A3,
als Alternativen in Kälte-, Klima- und
Wärmepumpenanlagen

This Technical Report was approved by CEN on 20 March 2022. It has been drawn up by the Technical Committee CEN/TC 182.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Segmentation of the Industry Sector	7
4.1 General	7
4.2 Commercial applications	7
4.2.1 Commercial Refrigeration	7
4.2.2 Professional Refrigerated Products	7
4.2.3 Commercial versus professional cabinets	8
4.3 Industrial applications	8
4.4 Chillers and heat pumps with water heat sink, indirect systems	9
4.5 Air to air air conditioning and heat pumps	9
4.6 Transport applications	10
5 Current practice in the sector	10
6 Design measures for flammable refrigerants	12
6.1 General	12
6.2 Design measures	13
7 Assessment of the way risk analysis is used	17
7.1 General	17
7.2 Risk assessment techniques	17
7.3 Risk acceptance criteria	18
7.4 Assessment of the use of risk-analysis in existing standards	19
7.5 Review of available risk assessment and potential additional research needs	20
7.6 Analysis of relationship between risk and increased charge	20
7.7 Acceptability of increased risk	21
7.7.1 General	21
7.7.2 Method of assessing risk in other applications	22
7.8 Additional mitigation requirements	23
7.8.1 General	23
7.8.2 Options for additional mitigation requirements	23
8 Relevant Legislation and Standards	24
8.1 Relevant legislation	24
8.2 European legislative framework	25
8.3 Relevant standards	25
8.3.1 General	25
8.3.2 Risk assessment standards	26
8.3.3 Safety standards	27
8.3.4 Other standards	27
8.4 Review of work programmes	30
8.5 Identify standards that should be further developed or updated	30
8.5.1 General	30

8.5.2	High priority	31
8.5.3	Medium priority	31
8.5.4	Low priority	32
9	Assessment of safety-related barriers	32
9.1	European Directives	32
9.2	Competence of service personnel – EN13313	32
9.3	National and regional regulations.....	33
9.4	EN 378.....	33
9.5	IEC 60335-2-40	34
9.6	IEC 60335-2-89	34
9.7	Transport refrigeration	34
10	Options	34
10.1	Options for additional mitigation requirements	34
10.2	Options for performance based requirements.....	38
10.3	Options for risk minimisation.....	38
10.4	Options for installation, operation, service, and decommissioning	38
10.4.1	Charge size limits.....	38
10.4.2	Associated risk mitigation requirements	38
10.4.3	Design of rooms.....	39
10.4.4	Marking of installation	39
10.4.5	Additional measures to ensure ongoing risk mitigation.....	39
11	Recommendation.....	39
	Annex A (informative) Risk analysis.....	41
	Annex B (informative) Segmentation of the industry sector	88
	Annex C (informative) Assessment of safety-related barriers to adoption.....	94
	Annex D (informative) Design measures	99
	Annex E (informative) Relevant Standards and Legislation used in this sector	101
	Annex F (informative) Review of work programmes	105
	Annex G (informative) Assessment of the way risk analysis is used.....	110
	Annex H (informative) Transport refrigeration.....	130
	Annex I (informative) Calculations and assumptions for section G.6 - Air conditioning and heat pumps.....	143
	Annex J (informative) AREA CLASSIFICATION.....	153
	Bibliography	155

European foreword

This document (CEN/TR 17608:2022) has been prepared by Technical Committee CEN/TC 182 “Refrigerating systems, safety and environmental requirements”, the secretariat of which is held by DIN.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

Introduction

CEN and CENELEC implemented standardisation request M/555 - IMPLEMENTING DECISION of 14 November 2017 on a standardisation request to the European Committee for Standardisation and to the European Committee for Electrotechnical Standardisation as regards use of flammable refrigerants in refrigeration, air conditioning and heat pump equipment. CEN/TC 182 took the lead and established a liaison with CENELEC/TC 61.

The two European Standardization Organizations CEN and CENELEC have responded positively to standardisation request M/555 regarding use of flammable refrigerants in refrigeration, air conditioning and heat pump equipment.

CEN/TC 182 and CENELEC/TC 61 were tasked to address the standardisation request. A new working group (WG12) was set up under CEN/TC 182 with active participation of experts nominated by CENELEC/TC 61.

The technical information was gathered by six ad hoc groups two of which were led by CENELEC/TC 61 experts. The ad hoc groups analysed the current status of risk assessment in general, commercial refrigeration, transport refrigeration, industrial refrigeration, air conditioning and heat pumps, and chillers. Each of the groups finalized their summary with conclusions about existing barriers and recommendations for additional options.

The Technical Committee reviewed guidance for the risk assessment in general and for refrigeration appliances in particular. This includes reviews of guidance and standards that apply for flammable gases in general. Also, the risk assessment was reviewed of global organisations like the risk approach of the Organisation for Economic Co-operation, Development and United Nations Development Programme and United Nations Environment Programme.

The requirements of the Standardisation Request M/555 were reviewed carefully. Having reviewed the documentation, the working group agree that, responding to the standardisation request, the following deliverables were to be prepared:

- 1) A Technical Specification for the installation of refrigeration, air conditioning and heat pump equipment containing flammable refrigerants, complementing existing standards.
- 2) A Technical Specification for the operation, servicing, maintenance, repair and decommissioning of refrigeration, air conditioning and heat pump equipment containing flammable refrigerants, complementing existing standards.

The recommendations about transport refrigeration are beyond the standardisation request M/555. CEN/TC 413 will develop of a specific EN standard dedicated to transport refrigeration risk assessment.

1 Scope

This document provides the results of a comprehensive assessment of the state of the art on the use of flammable refrigerants, in particular from class A3.

Refrigerants from class B (toxic) are excluded from this scope.

This document includes the following elements:

- A segmentation of the refrigeration, air conditioning and heat pump market, making use of existing studies and research, including an assessment of safety-related barriers to the uptake of flammable refrigerants in particular from class A3 across all relevant applications;
- An assessment of the way risk assessments is used in existing standards for refrigeration, air conditioning and heat pump equipment and in other standards and a review of available risk assessment research to be taken into account including identification of potential needs for additional research;
- Analysis of:
 - the relationship between risk and increased charge;
 - the acceptability of increased risk compared to the risk presented by other technologies;
 - the options for additional mitigation methods if the risk increase is unacceptable;
- Review of existing standards and work programmes and identification of standards that should be further updated under existing or future standardisation requests based on relevant product safety legislation, in particular with regard to allowable charge sizes of flammable refrigerants, taking into account available technology as well as emerging research and development;
- Identification of options for performance based requirements that result from risk assessments to enable the use of all flammable substances;
- Identification of options for risk minimisation and for offering flexibility in application of mitigation measures.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>